



CITY COUNCIL WORKSHOP CITY OF BAY CITY

Tuesday, December 06, 2022 at 4:30 PM
COUNCIL CHAMBERS | 1901 5th Street

COUNCIL MEMBERS

Mayor: Robert K Nelson

Mayor Pro Tem: Jim Folse

Council Members: Floyce Brown, Bradley Westmoreland, Becca Sitz, Blayne Finlay

Vision Statement

Through a united and collaborative effort, we seek to grow the City of Bay City with a diverse culture that is proud to call Bay City home. We envision a thriving family-centered community where citizens are involved in the future development of our city. We desire our citizens to work, play, worship and shop in the community in which we live. Visitors are welcomed and encouraged to enjoy the friendly environment and amenities the citizens and business owners have created together.

AGENDA

THE FOLLOWING ITEM WILL BE ADDRESSED AT THIS OR ANY OTHER MEETING OF THE CITY COUNCIL UPON THE REQUEST OF THE MAYOR, ANY MEMBER(S) OF COUNCIL AND/OR THE CITY ATTORNEY:

ANNOUNCEMENT BY THE MAYOR THAT COUNCIL WILL RETIRE INTO CLOSED SESSION FOR CONSULTATION WITH CITY ATTORNEY ON MATTERS IN WHICH THE DUTY OF THE ATTORNEY TO THE CITY COUNCIL UNDER THE TEXAS DISCIPLINARY RULES OF PROFESSIONAL CONDUCT OF THE STATE BAR OF TEXAS CLEARLY CONFLICTS WITH THE OPEN MEETINGS ACT (TITLE 5, CHAPTER 551, SECTION 551.071(2) OF THE TEXAS GOVERNMENT CODE).

CALL TO ORDER

CERTIFICATION OF QUORUM

PUBLIC COMMENTS

REGULAR ITEMS FOR DISCUSSION, CONSIDERATION AND / OR APPROVAL

1. Discuss plan for Public Works to have drainage reviewed prior to project being submitted to Drainage District #1.
2. Presentation and discussion regarding arsenic. Jeremy Gaston, Garver Engineering
3. Discuss an update on the Wastewater Treatment Plant Project. Dan Olson, Garver Engineering

ADJOURNMENT

CERTIFICATION OF POSTING

This is to certify that the above notice of a City Council Workshop Meeting was posted on the front window of the City Hall of the City of Bay City, Texas on **Friday, December 2, 2022 before 5:00 pm**. Any questions concerning the above items, please contact the Mayor and City Manager's office at (979) 245-2137.

Summary of Findings Memorandum

City of Bay City Arsenic Removal Evaluation

Prepared by:



12141 Wickchester Lane, Suite 200
Houston, TX 77079

November 2022

Engineer's Certification

We hereby certify that this Summary of Findings Memorandum for the Arsenic Removal Project was prepared by Garver under our direct supervision for the City of Bay City.

DRAFT ONLY



A handwritten signature in blue ink, appearing to read "Jeremy S. Gaston".

Jeremy Gaston, PE
State of Texas PE License #127302



Table of Contents

Engineer’s Certification 2

Table of Contents 3

List of Figures 4

List of Tables 4

List of Appendices 4

1.0 Project Background 5

2.0 Evaluation of Existing Water Plants 5

 2.1 6th Street and Avenue I 5

 2.2 6th Street and Katy Avenue 6

3.0 Additional Water Quality Sampling 7

4.0 Water Quality Modeling (Blending Optimization) 8

 4.1 Blending Model Inputs 9

 4.2 Blend Development 11

 4.3 Blending Recommendations 13

 4.4 Treatment Evaluation/Findings 14

5.0 Alternatives Evaluation 14

 5.1 Adsorption 15

 5.1.1 Rapid Small Scale Column Test 19

 5.2 Ion Exchange 21

 5.3 Reverse Osmosis 22

 5.4 Coagulation/Microfiltration 24

 5.5 Summary of Alternatives 25

 5.6 Centralized Treatment System 26

 5.6.1 Overall Centralized Treatment System 26

 5.6.2 Combined Treatment System (6th St & Avenue I and 6th St & Katy Avenue) 27

 5.7 Estimated Capital Construction Cost Comparison 27

6.0 Recommendation 28



List of Figures

Figure 1: Bay City 6th St and Ave I WTP Existing Site Layout..... 6
 Figure 2: Bay City 6th St and Katy Ave WTP Existing Site Layout..... 7
 Figure 3: Plan View of Proposed Iron Adsorption Media System 16
 Figure 4: 6th Street and Avenue I WTP Proposed Adsorption Treatment System..... 17
 Figure 5: 6th Street and Avenue I WTP 18
 Figure 6 : 6th Street & Katy Ave. WTP 19
 Figure 7: Arsenic Breakthrough Curve using Bayoxide E33 and Dry GFH 21
 Figure 8: Plan View of Proposed Microfiltration System..... 24

List of Tables

Table 1: Water Quality Data..... 8
 Table 2: Entry Point Capacities..... 9
 Table 3: Entry Point Water Quality Data from 2019 to 2022..... 9
 Table 4: Chemical Stability Indices for Entry Points 10
 Table 5: TCEQ Classification System..... 10
 Table 6: Arsenic Levels for Blends Assuming Maximum Production at Entry Points’ Rated Capacities.... 12
 Table 7: Optimized Blends with 0.007 mg/L Arsenic 12
 Table 8: Chemical Stability Indices for Optimized Blends 13
 Table 9: Summary of Blended Treated and Untreated Water for 6th St. & Ave. I 6th St. & Katy Avenue... 14
 Table 10: Projected Design and Operating Criteria for Adsorption System at Each WTP Site..... 15
 Table 11: Summary of Arsenic Treatment Alternatives 25
 Table 12: Estimated Capital Construction Cost 28

List of Appendices

Appendix A Record Drawings
 Appendix B Additional Water Quality Sampling
 Appendix C Water Quality Modeling (Blending Optimization) Calculations
 Appendix D Manufacturer Information
 Appendix E Rapid Small-Scale Column Test



1.0 Project Background

The City of Bay City operates five Water Treatment Plants (WTP) consisting of six groundwater wells serving the city's population. The largest well at the Bay City 6th Street & Avenue I WTP was found to have high levels of arsenic which exceeded the maximum contaminant level (MCL) set by the Texas Commission on Environmental Quality (TCEQ). Compliance with the arsenic Rule requires maintenance of arsenic levels below the MCL at all entry points to the distribution system on a running annual average basis. Arsenic levels can be controlled by blending source waters prior to the entry point, implementing arsenic removal processes at individual wells, or in a centralized treatment facility.

The Bay City 6th Street & Avenue I Well is currently not in production due to the arsenic MCL exceedance. During the previous arsenic exceedance, the City implemented a blending plan to blend water from the water plants prior to the entry point to the distribution system. Generally, blending is a preferred alternative to arsenic removal treatment. However, blending was not found to be effective during this latest violation due to the generally elevated arsenic concentrations occurring at other facilities (while still below the MCL), resulting in higher arsenic concentrations overall in the distribution system water.

Garver contracted with Bay City to perform an arsenic removal study in order to bring their largest well back in operation. Garver was scoped to investigate blending optimization from multiple well sites and several treatment technologies at individual well sites and a centralized treatment facility to reduce the arsenic levels to below the MCL.

2.0 Evaluation of Existing Water Plants

2.1 6th Street and Avenue I

The existing 6th Street & Avenue I WTP consists of one well and vertical turbine pump, chemical building, a 1 MG ground storage tank, booster pump station, and a backup generator (Figure 1). The well production capacity is 1,320 gpm (1.9 mgd). The chemical building stores polyphosphate, chlorine gas cylinders, and fluoride. The chlorine gas cylinders in the chemical building provide an average feed rate of 40 lb/day. There are three pumps in the booster pump station building: with a capacity of 500 gpm, 1,000 gpm, and 1,500 gpm respectively. Appendix A contains record drawings of the 6th Street and Avenue I WTP from the City.

As shown on Figure 1, the 6th Street & Avenue I WTP has limited space for new treatment units or equipment. Subsequently, tree removal and/or fence relocation may be necessary or additional land or easement may be necessary.




Figure 1: Bay City 6th St and Ave I WTP Existing Site Layout

2.2 6th Street and Katy Avenue

The existing 6th St and Katy Avenue WTP consists of one well and vertical turbine pump, chemical building, and a 450,000 gallon elevated storage tank (Figure 2). The well production capacity is 1,050 gpm (1.5 MGD). The well pumps directly into the distribution system and the elevated storage tank is filled from the distribution system. The 6th Street & Avenue I WTP and 6th St and Katy Avenue WTP are 0.9 miles apart from each other in downtown Bay City. As shown on Figure 2, it appears that anticipated individual treatment systems can fit appropriately on this site with adequate room for maintenance and future servicing.




Figure 2: Bay City 6th St and Katy Ave WTP Existing Site Layout

3.0 Additional Water Quality Sampling

Additional water quality testing was performed to characterize water quality parameters for these wells. This information was also provided to the vendors to allow them to suggest potential treatment system type and size. Water quality parameters analyzed included Arsenic III, Arsenic V, Phosphate, Vanadium, Silica, Alkalinity, and the pH from the Bay City 6th Street & Avenue I well. The water quality testing was performed by Eurofins South Central LLC located in Stafford, TX.

On August 11, 2022, 80 gallons of raw unchlorinated well water was collected from the Bay City 6th Street & Avenue I well for additional water quality testing using Rapid Small Scale Column Tests (RSSCTs). Five gallons of the raw well water was allocated for additional water quality testing while the remaining 75 gallons of the raw well water was allocated for the RSSCTs and used used for testing treatment performance..

Arsenic speciation test was performed using Hydride-Generation Cryo-Trapping Gas Chromatography-Atomic Absorption Spectrometry (GC-AAS) based on the United States Environmental Protection Agency (USEPA) Method 1632 to quantify Arsenic III, Arsenic V, and Inorganic Arsenic. Vanadium and Silica

concentrations were measured using Inductively Coupled Plasma (ICP) using USEPA Method 6010D. The test methods used are recommended in the USEPA publication: Test Methods for Evaluating Solid Waste: Physical/Chemical Methods, also known as SW-846. The Phosphates as Total Phosphorus was quantified using Colorimetry based on USEPA Methods 365.1, 365.2, and 365.3. Alkalinity was measured using titration based on Standard Methods (SM) for the Examination of Water and Wastewater 2320B.

The summarized results of the additional water quality sampling are shown in Table 1. The results were sent to manufacturers of various arsenic treatment technologies to select appropriate treatment technology and preliminary design and budgetary proposals. Complete water quality sampling testing procedures and results are provided in Appendix B.

Table 1: Water Quality Data

Analyte	Results	Unit
Arsenite, As(III)	1.15	ug/L
Arsenate, As(V)	9.55	ug/L
Inorganic Arsenic	10.7	ug/L
Vanadium	Non-Detectable	
SiO ₂	17.3	mg/L
Phosphates as Total Phosphorus	Non-Detectable	
pH	8.28	
Temperature	17.9	Degrees C
Alkalinity	213	mg/L

4.0 Water Quality Modeling (Blending Optimization)

Blending prior to entry points (EPs) to the distribution system can be used to bring arsenic levels below the Maximum Contaminant Level (MCL, 0.01 mg/L). Challenges to implementing blending or centralized treatment include the need to convey sufficient volumes of water with low arsenic levels to existing well sites or new treatment facilities for blending.

Blending targeted at one constituent can result in negative impacts to other water quality parameters and chemical stability of the water. Water quality modeling is used to assess the feasibility and water quality impacts of blending.

Garver used a spreadsheet-based blending model to determine if blending strategies could reliably produce finished water with arsenic levels below the MCL. The model was used to identify optimized blends of water from the wells at 4th Street & Avenue B (EP001) and Grace Street & Moore Avenue (EP005) wells, which have arsenic levels below the MCL, with water from the 6th Street & Katy (EP003),



Mockingbird Lane (EP002), and 6th Street & Avenue I (EP004) wells, which have arsenic levels approaching or above the MCL.

4.1 Blending Model Inputs

Inputs to the model include the rated capacities for the EPs, which are available on TCEQ’s Safe Drinking Water Information System (SDWIS) website and summarized in Table 2. Historical average day and maximum day demands for the overall system were given as 1,645 gpm and 2,268 gpm, respectively.

Table 2: Entry Point Capacities

Entry Point Number	Entry Point Location	Rated Flow (GPM)
EP001	4 th Street & Avenue B	1,360
EP002	Mockingbird Lane	1,010
EP003	6 th Street & Katy	1,050
EP004	6 th Street & Avenue I	1,250
EP005	Grace Street & Moore Avenue	1,300

Water quality data was collected from each EP as part of regulatory compliance monitoring, and data from 2019 through 2022 was used in this analysis. Generally, only one measurement was available per water quality parameter. Where multiple measurements were available for arsenic, the maximum value was used. The average was used for other parameters. City staff collected and provided one pH measurement per entry point in 2022. Measured and calculated water quality parameters are summarized in Table 3 with their MCLs or Texas Secondary Constituent Levels (SCLs).

Table 3: Entry Point Water Quality Data from 2019 to 2022

Parameter	EP001	EP002	EP003	EP004	EP005	MCL/SMCL	Units
Arsenic	0.005	0.008	0.009	0.013	0.005	0.01	mg/L
Calcium	30	18	16	14	21	--	mg/L
Chloride	40	72	67	47	106	300	mg/L
Iron	0.08	0.05	0.04	0.03	0.05	0.3	mg/L
Magnesium	12.2	7.9	6.6	5.5	8.6	--	mg/L
Manganese	0.02	0.01	0.01	0.00	0.00	0.05	mg/L
Sulfate	15	14	14	14	13	300	mg/L
Total Alkalinity	278	251	251	246	282	--	mg/L as CaCO ₃
Total Hardness	123	79	67	57	84	--	mg/L as CaCO ₃
Total Dissolved Solids (TDS)	325	377	372	330	440	1000	mg/L
pH	7.8	8.0	7.9	7.8	7.9	≥ 7.0	S.U.



These data were used as inputs to the Rothberg, Tamburini, and Winsor (RTW) model available from the American Waterworks Association (AWWA), which was used to calculate calcium carbonate stability indices including the Langelier Saturation Index (LSI), Ryznar Index (RI), Aggressiveness Index (AI), and calcium carbonate precipitation potential (CCPP) for each water. Additionally, the chloride to sulfate mass ratio (CSMR), which is related to the potential for galvanic corrosion and lead release, was calculated for each well. Results are summarized in Table 4. Based on TCEQ's classification system (Table 5), the water from each entry point would be classified as non-corrosive to slightly corrosive.

Table 4: Chemical Stability Indices for Entry Points

Parameter	EP001	EP002	EP003	EP004	EP005	Units
CSMR*	2.7	5.1	4.8	3.4	8.2	--
LSI	0.3	0.3	0.1	-0.1	0.3	--
RI	7.1	7.5	7.7	7.9	7.4	--
AI	12.1	12.1	11.9	11.7	12.1	--
CCPP	12.7	6.1	2.6	-1.3	7.8	mg/L as CaCO ₃

*CSMR - Chloride to Sulfate Mass Ratio

LSI - Langelier Saturation Index

RI - Ryznar Index

AI - Aggressiveness Index

CCPP - Calcium Carbonate Precipitation Potential

Table 5: TCEQ Classification System

Index	Description	Classifications
Langelier Index (LSI)*	Indicator for the degree of calcium carbonate saturation in a water. Calculated using measured pH, alkalinity, calcium concentration, total dissolved solids, and water temperature. This index is not directly related to the corrosivity of a water as it relates to lead and copper, but it is an indicator of the likelihood for calcium carbonate scales to form or be dissolved. A low LSI could indicate the potential for dissolution of the cement in asbestos-cement piping. LSI can also be used to indicate a maximum pH for corrosion control that would not promote excessive calcium carbonate scaling.	Per TCEQ: <ul style="list-style-type: none"> LSI ≥ -0.25: Noncorrosive LSI < -0.25: Slightly corrosive LSI < -1.0: Corrosive
Ryznar Index (RI)*	Alternative to LSI for calculating calcium carbonate scaling potential. Calculated using measured pH, alkalinity, calcium concentration, total dissolved solids, and water temperature. This index is not directly related to the corrosivity of a water. Like LSI, RI can also be used to indicate a maximum pH for corrosion control that would not promote excessive scaling.	Per TCEQ: <ul style="list-style-type: none"> RI < 7.0: Noncorrosive 7.0 ≤ RI ≤ 8.5 Slightly corrosive RI > 8.5: Corrosive



Calcium Carbonate Precipitation Potential (CCPP)*	Calcium carbonate stability index that predicts whether a water is undersaturated or supersaturated with calcium carbonate as well as the quantity (mg/L) of calcium carbonate that would theoretically precipitate from or have to be dissolved into the water to reach equilibrium. This index is not directly related to the corrosivity of a water but can be used to indicate a maximum pH for corrosion control that would not promote excessive scaling.	Per TCEQ: <ul style="list-style-type: none"> • CCPP > 0: Noncorrosive • -3.0 < CCPP < 0: Slightly corrosive • CCPP < -3.0: Corrosive
Aggressiveness Index (AI)*	Simplified version of LSI that is intended to determine if asbestos-cement piping would be appropriate for a given system.	Per TCEQ <ul style="list-style-type: none"> • AI > 12: Noncorrosive • 10 ≤ AI ≤ 12: Slightly corrosive • AI < 10: Corrosive
Chloride:Sulfate Mass Ratio (CSMR)*	Indicator for potential lead release, particularly lead release due to galvanic corrosion. CSMR is calculated as the ratio of chloride to sulfate in milligrams per liter.	Per TCEQ: <ul style="list-style-type: none"> • CSMR < 0.2: Non-corrosive • 0.2 < CSMR < 0.5: Slightly Corrosive • CSMR > 0.5 & Total Alkalinity > 50 mg/L-CaCO₃: Slightly Corrosive • CSMR > 0.5 & Total Alkalinity < 50 mg/L-CaCO₃: Corrosive
*Parameter required by TCEQ for corrosivity engineering reports. Classification range terminology is per TCEQ guidance.		

4.2 Blend Development

Arsenic has exceeded the MCL at 6th Street and Avenue I and has reached 90% of the MCL at 6th Street and Katy Avenue, but it has remained below 80% of the MCL at the remaining entry points. EP001 and EP005 water can be used to bring blended water arsenic levels below the MCL, but given that EP002 has approached 80% of the MCL in the past, it has not been particularly beneficial for blending.

Blends were developed for multiple scenarios and evaluated based on:

- Blended water arsenic levels, with minimization of arsenic levels desired, but arsenic levels up to 80% of the MCL considered acceptable.
- Utilization of water sources.
- Optimization of overall water quality based on MCLs, SMCLs, and chemical stability indices.

Two-well, three-well, four-well, and five-well blends were developed using EP water quality data. Table 6 shows blends that use all available water from each contributing well site based on the rated capacities of



the existing entry points. Blends 2a and 2c produce blended water with the lowest arsenic levels and would provide sufficient flow to serve the system during historical maximum day demand conditions, but these blends could not be produced at the same time. Rather, Blend 2d or EP005 and EP002 could serve the system at the same time as Blend 2a, and Blend 2b or EP001 and EP002 could serve the system at the same time as Blend 2c.

If three-well blends were used, the system could also receive water directly from EP002, as well as EP005 in the case of Blend 3a or EP001 in the case of Blend 3b. A significant portion of the system would receive water with arsenic at 80-90% of the MCL with the 3-well blends. Four- and five-well blends would be expected to produce water with arsenic at 80% of its MCL.

Table 6: Arsenic Levels for Blends Assuming Maximum Production at Entry Points' Rated Capacities

Blend	EP001 (%)	EP002 (%)	EP003 (%)	EP004 (%)	EP005 (%)	Blended Flow (gpm)	Arsenic (mg/L)
2a: EP001 & EP003	56	--	44	--	--	2,410	0.007
2b: EP001 & EP004	52	--	--	48	--	2,610	0.009
2c: EP005 & EP003	--	--	45	--	55	2,350	0.007
2d: EP005 & EP004	--	--	--	49	51	2,550	0.009
3a: EP001, EP003, & EP004	37	--	29	34	--	3,660	0.009
3b: EP003, EP004, & EP005	--	--	29	35	36	3,600	0.009
4: EP001, EP003, EP004, & EP005	27	--	21	25	26	4,960	0.008
5: EP001, EP002, EP003, EP004, & EP005	23	17	18	21	22	5,970	0.008

The blends could be further optimized to bring arsenic levels to 70% of the MCL (e.g., to 0.007 mg/L As) using only a portion of the water available from each existing EP, as shown in Table 7.

Table 7: Optimized Blends with 0.007 mg/L Arsenic

Blend	EP001 (%)	EP002 (%)	EP003 (%)	EP004 (%)	EP005 (%)	Blended Flow (gpm)	% of Available Flow
2a _o : EP001 & EP003	56	--	44	--	--	2,410	100
2b _o : EP001 & EP004	70	--	--	30	--	1,943	74
2c _o : EP005 & EP003	--	--	45	--	55	2,350	100



2d_o: EP005 & EP004	--	--	--	33	67	1,940	76
3a_o: EP001, EP003, & EP004	63	--	18	19	--	2,159	59
3b_o: EP003, EP004, & EP005	--	--	21	19	60	2,167	60
4_o: EP001, EP003, EP004, & EP005	31	--	21	18	30	4,333	87
5_o: EP001, EP002, EP003, EP004, & EP005	27	19	13	13	28	4,643	78

Of the blends evaluated, use of Blends 2a_o + 2d_o, Blend 4_o, or Blend 5_o provide the ability to produce the most water with arsenic levels of 0.007 mg/L. Based on water quality parameters measured at the individual EPs (shown in Table 3), no MCLs or SCLs aside from arsenic are exceeded by any EP. However, there is some variation in CSMR and calcium carbonate stability indices, so these values were calculated for blends 2a_o, 2d_o, 4_o, and 5_o at 20°C. RTW Model inputs and blending results are shown in Table 8. All blends would be considered noncorrosive or slightly corrosive based on TCEQ’s classification system. Blend 2d_o is somewhat less desirable than other blends due to its higher TDS and CSMR. The spreadsheet used to calculate the optimized blending is located in Appendix C.

Table 8: Chemical Stability Indices for Optimized Blends

Parameter	2a_o	2d_o	4_o	5_o
pH	7.8	7.9	7.9	7.9
Alkalinity	266	270	266	266
TDS	345	404	369	374
Calcium	60	46	53	53
LSI	0.2	0.2	0.3	0.3
RI	7.4	7.5	7.4	7.4
AI	12.0	12.0	12.1	12.1
CCPP	7.1	5.3	7.4	7.4
CSMR	3.6	6.5	4.8	4.9

4.3 Blending Recommendations

If blending is the selected alternative for arsenic management in the Bay City System, blending infrastructure could be installed in phases, starting with that required for Blend 2a_o. Infrastructure for Blend 4_o could be installed to allow the City to utilize water from existing 6th Street & Avenue I (EP004), and infrastructure for Blend 5 could be installed if arsenic levels approach the MCL at Mockingbird Lane (EP002).



4.4 Treatment Evaluation/Findings

Garver used the blending model to determine the degree of treatment that would be required at 6th Street & Katy (EP003) and 6th Street & Avenue I (EP004) to bring arsenic levels to 70% of the MCL without blending with water from other EPs. It was assumed that treatment would consist of adsorption using iron oxide media and treated water would be blended with untreated water. Based on the results of Rapid Small-Scale Column Tests (RSSCTs), treated water arsenic would be at or below 0.001 mg/L, and there would be no impact on pH. Untreated water from each site would have the same water quality as shown in Table 3.

Based on the aforementioned assumptions to meet 70% of the maximum contaminant level, the following treatment findings are presented (Table 9):

EP003 (6th Street and Katy Avenue) → Minimum 31% of the water requires treatment

EP004 (6th Street and Avenue I) → Minimum 50% of the water requires treatment

Table 9: Summary of Blended Treated and Untreated Water for 6th St & Avenue I and 6th St & Katy Avenue

EP	Percent Treated	Percent Untreated	Blended Water As (mg/L)
EP003	31%	69%	0.00652
EP004	50%	50%	0.00675

5.0 Alternatives Evaluation

Garver was scoped to analyze three permanent arsenic treatment system alternatives comprising:

1. Adsorption
2. Ion exchange
3. Reverse osmosis.

The treatment alternatives were evaluated for location at individual water treatment plant sites. Based on discussion with several vendors, Garver assessed that coagulation-assisted microfiltration could also be a treatment consideration for the affected water plant sites. Consequently, Garver added coagulation-assisted microfiltration as a fourth arsenic treatment system alternative. **The full vendor proposals for each arsenic treatment alternative are included in Appendix D.**



5.1 Adsorption

Garver studied adsorption as a viable arsenic removal treatment system utilizing iron oxide adsorptive media. A typical adsorption vessel system would include two carbon steel pressure vessels on a skid, with each vessel handling half of the required treatment flow. A proposed adsorption system plan layout is shown on Figure 3. Garver solicited proposals for installing individual adsorption treatment systems at the 6th St & Avenue I WTP and one at the 6th St & Katy Avenue WTP. The projected design and operating criteria for an adsorption vessel with iron oxide based media for each WTP site are provided in Table 10.

The system will be designed such that each adsorption vessel can handle half of the proposed treatment flow. During media replacement, this would allow the treatment unit to remain online and still provide half capacity. It should be noted that the adsorptive media is typically proprietary which may cause difficulty sourcing the same media if it becomes discontinued in the future.

Table 10: Projected Design and Operating Criteria for Adsorption System at Each WTP Site

Design/Operating Criteria	6th Street & Avenue I	6th Street & Katy Avenue
Proposed Treatment Flow Rates (gpm)	660	330
Head Loss (psi)	3 (clean bed) 10 (initiate BW)	3 (clean bed) 10 (initiate BW)
Media Life Est. (months)	21	18
Media Replacement Duration (hrs)	4	4
Backwash Frequency (days)	45	45
Backwash Flow Rates (gpm)	455	215
Backwash Duration (min)	15	15
Backwash Volume (gal)	6,825 (each) 13,650 (total)	3,225 (each) 6,450 (total)

The adsorption media system will require backwashing approximately every 45 days to remove particulates and redistribute the bed material. The backwash source can be raw water or treated water. Backwash waste stream will have no arsenic and can be discharged to sewer.

As shown on Figures 4 and 5, while it appears an adsorption vessel treatment system will fit on the 6th Street and Avenue I site, access will likely be constrained to perform routine operations and maintenance, and in particular to remove and replace media. The proposed adsorption system for the 6th Street and Katy Avenue site is smaller than at Avenue I and there is more available land area. As shown on Figure 6, it appears that an adsorption vessel treatment system can fit appropriately on the 6th Street and Katy Avenue site with adequate room for maintenance and future servicing.






Figure 3: Plan View of Proposed Iron Adsorption Media System




Figure 4: 6th Street and Avenue I WTP Proposed Adsorption Treatment System Site Layout Alternative 1




Figure 5: 6th Street and Avenue I WTP
Proposed Adsorption Treatment System Site Layout Alternative 2




Figure 6 : 6th Street & Katy Ave. WTP
Proposed Adsorption Treatment System Layout

5.1.1 Rapid Small Scale Column Test

Garver contracted Arizona State University (ASU) to perform Rapid Small Scale Column Tests (RSSCTs) on the raw groundwater samples to assess arsenic removal using two types of iron adsorption media: Bayoxide E33 and Dry Granular Ferric Hydroxide (GFH). The purpose of the RSSCTs was to project arsenic breakthrough for both types of iron adsorption media and determine if there was any notable advantage to one media over the other.

ASU conducted one RSSCT run for each type of media. The raw well water samples were chlorinated by ASU staff with liquid chlorine at a dose of 2 mg/L. ASU performed the RSSCTs at ambient pH after samples were filtered and acidified to 2% trace-metal grade nitric acid. During the RSSCTs, ASU collected effluent samples and analyzed them for arsenic at various points along the breakthrough curve.

The results of the RSSCT concluded that there was negligible difference in the arsenic breakthrough curves between the Bayoxide E33 and Dry GFH media columns. This suggests the capacity, lifetime, and media replacement frequency (based upon arsenic removal under the conditions tested) would be nearly identical.

As shown in Figure 7 7, both adsorbents achieved between 10,000 to 14,000 bed volumes treated before exceeding the 1 ug/L detection limit for arsenic. Approximately 80% of arsenic breakthrough (target value) occurred around 100,000 bed volumes treated. The full results of the Rapid Small Scale Column Tests performed by Arizona State University is provided in Appendix E.




Figure 7: Arsenic Breakthrough Curve using Bayoxide E33 and Dry GFH

5.2 Ion Exchange

Garver evaluated ion exchange as a viable arsenic removal treatment. Ion exchange systems typically are used in the form of columns that can contain a variety of resins. During a service cycle, a flow stream is directed into the ion exchange column where it reacts with the resin. Ion exchange resin is used as a physical medium to facilitate ion exchange reactions. Over the course of one or more service cycles, an ion exchange resin will become exhausted, meaning that it can no longer facilitate ion exchange reactions. Regeneration is a process where functional groups are restored to the spent resin matrix. This is accomplished through the application of a chemical regenerant solution.

A proposed ion exchange system for the Bay City water plants would include two carbon steel pressure vessels on a skid, with each vessel handling half of the required treatment flow. Figure 8 depicts a schematic of a proposed ion exchange system. The proposed resin media is FerrIX A33E, a highly porous hybrid anion resin infused with iron oxide, which will need to be regenerated every five to six months. While ion exchange systems are easy to install and connect to existing infrastructure, a key disadvantage is having to utilize a recommended brine solution to regenerate the resin on-site, which is an added cost and generates saline waste which needs to be discharged to a nearby sewer. Additionally, the location of the ion exchange system within the water plant needs careful consideration so the resins

do not get exposed to oxidants which can result in irreversible damage to the resins. Ion exchange resins are also prone to organic fouling.

As provided in Table 12, since Ion Exchange is notably more expensive than adsorption and has saline waste considerations along with the complexity of on-site resin regeneration and capacity for silica interference, it is not a recommended alternative.




Figure 8: Schematic of Proposed Ion Exchange System

5.3 Reverse Osmosis

Garver considered Reverse Osmosis (RO) as an arsenic treatment alternative because RO is shown to be effective at removing arsenic besides other constituents from water, including organic carbon, salts, dissolved minerals, and color. shows the general configuration of a reverse osmosis system which consists of membranes, pressure vessels, cleaning in place (CIP) skid, acid-dosing skids, and a flushing system.

Based on discussion with several vendors for the Bay City water plant sites, RO will produce high amounts of wasted water from the reject stream, projected at 40% of the RO feed water. This consistent reject stream or brine will need to be properly disposed of likely to sewer.

Given that Bay City does not need to invest capital to treat the affected well sites to very low arsenic levels to reach MCL compliance (or have other treatment objectives), and considering the high energy costs and high waste volumes projected for this given application, the use of reverse osmosis technology does not seem warranted for this particular application.




Figure 8: Plan View Proposed Reverse Osmosis System



5.4 Coagulation/Microfiltration

Garver considered Coagulation-Enhanced Microfiltration as an additional treatment alternative due to recommendations from several vendors after presenting additional water quality data. A coagulation-enhanced microfiltration system consists of a feed tank, a reverse filtration tank, feed pumps, membrane modules, a cleaning in place (CIP) system, a neutralization system, and chemical storage (Figure 8).

A coagulant such as Ferric Chloride and a pH adjuster such as citric acid are added to the water followed by direct microfiltration without flocculation. Microfiltration uses a filter membrane that must be backwashed frequently, projected at 1-2 times each week. The coagulation/microfiltration process produces backwash water as a liquid waste. The backwash water waste may be disposed by discharging to a nearby sewer. Since chemicals such as coagulants, pH adjustment, and caustic will need to be added to the system, notable additional chemical storage will be needed onsite. This is cumbersome for the 6th Street and Avenue I WTP given the site is constrained in terms of available land. Based on the vendor proposals, the coagulation-microfiltration system had the highest capital cost.




Figure 8: Plan View of Proposed Microfiltration System

5.5 Summary of Alternatives

Garver evaluated four arsenic treatment alternatives based on the scope and subsequent vendor engagement. Table 11 summarizes the advantages and disadvantages of each arsenic treatment alternative.

Table 11: Advantages and Disadvantages of Arsenic Treatment Alternatives

Treatment Alternative	Advantage	Disadvantage
Adsorption	<ul style="list-style-type: none"> • Lowest capital cost • Easy installation and media replacement • Convenient disposal of media waste to municipal landfill 	<ul style="list-style-type: none"> • Monthly backwash required • Proprietary media
Ion Exchange	<ul style="list-style-type: none"> • Backwash not required • Media is reusable • Easy installation • Smallest footprint 	<ul style="list-style-type: none"> • Silica interference • Prone to fouling • Brine solution required • Onerous on-site regeneration
Reverse Osmosis	<ul style="list-style-type: none"> • Backwash not required • Membrane is regenerable • Automatic flushing 	<ul style="list-style-type: none"> • High waste volume • Complex operations • Brine disposal
Coagulation/Microfiltration	<ul style="list-style-type: none"> • Many applications nationwide and in Texas • Coagulation direct injection to piping 	<ul style="list-style-type: none"> • Weekly backwash required • Highest capital cost • Additional chemical storage and cost • Largest footprint

Garver received proposals from multiple vendors for four different treatment technologies all using the same treatment criteria. We subsequently prepared a high-level capital cost estimation of each treatment alternative based on vendor, site/civil work, process piping, structural, and electrical costs and found that Adsorption (using granular iron oxide media) would be the least expensive capital cost alternative. Coagulation enhanced microfiltration was estimated to be the most expensive treatment alternative considered. Table 12 provides a capital cost summary for each of the arsenic treatment alternatives.

Table 12: Summary of Estimated Capital Costs of Arsenic Treatment Alternatives

Treatment Alternative	6th St and Ave I	6th St and Katy Ave
Adsorption	\$ 2,550,000	\$ 1,980,000
Ion Exchange	\$ 3,610,000	\$ 2,610,000
Reverse Osmosis	\$ 4,260,000	\$ 3,110,000
Coagulation-Microfiltration	\$ 4,790,000	\$ 3,560,000



5.6 Centralized Treatment System

One treatment alternative was to consider implementation of a centralized treatment system if treatment at individual sites was not deemed an optimal long-term solution. Garver considered two options for a centralized treatment system in order to treat the inflows from multiple well sites. One alternative was consideration for a new overall centralized treatment system which will have inflows from all five existing facilities [Reference Table 2] and anticipated to be located at a new parcel of land without existing facilities which would be somewhat equidistant to all WTP sites. The other option was to construct a combined treatment system which will treat combined inflows from 6th Street & Avenue I WTP and 6th Street & Katy Avenue WTP at the existing 6th Street & Avenue I WTP site, taking advantage of existing facilities.

5.6.1 Overall Centralized Treatment System

The overall centralized treatment system would include flow from all five sites and ideally would be at a neutral location which is equidistant to all the well sites because the existing WTP sites are not only size constrained, but do not have the capacity to store and handle the combined flows of all the WTPs. Garver did not identify an exact city-owned property for the site of the centralized treatment system. However, for preliminary cost estimating and comparison purposes, the site location was assumed to be somewhat equidistant to all existing WTP sites for the purposes of estimating distribution system modification costs.

An overall centralized treatment system creates known, tangible challenges to the City to construct. A new overall centralized treatment facility would necessitate extensive distribution system piping modifications with disruption of City streets, traffic flow, and pedestrian access. Additionally, a new centralized treatment system would expectedly involve construction of new larger facilities (with existing reliable facilities that are already useful to the City) and also likely warrant modifications of standard operating procedures.

Conversely, a centralized treatment system could bring advantages should water quality notably degrade at the other City wells besides 6th Street and Avenue I and 6th Street and Katy Ave. However, with additional storage and pumping facilities for an overall centralized treatment system, the anticipated construction cost of a new overall centralized treatment facility is projected to be six times the cost of the combined individual treatment systems located at 6th Street and Avenue I and 6th Street and Katy Ave., this is provided in Table 13. Additionally, as a result of the modeling performed and treatment recommendations provide in Section 4.4, only modest amounts of water need to be treated at the impacted well sites. The individual treatment systems also offer flexibility to modify and treat higher flows to meet MCL requirements if the raw water quality changes over time; acknowledging that increasing treated flows would shorten the media life.

Given the estimated capital construction cost of an individual treatment system, this allows the City to install a similar individual treatment system at each of other well sites before ever encroaching the projected cost of a centralized treatment system; with notably less public and operational impacts.

Treatment at individual well sites do seem a viable and economic alternative for Bay City and can be deemed as an optimal long-term solution. Consequently, the consideration of an overall centralized treatment system to accommodate flow from all five sites does not seem warranted for Bay City given the aforementioned findings and is not being considered further as a justifiable alternative for design.

5.6.2 Combined Treatment System (6th St & Avenue I and 6th St & Katy Avenue)

Another treatment option considered was a combined treatment facility located at 6th Street & Avenue WTP to treat inflows from 6th Street & Avenue I WTP and 6th Street and Katy Avenue WTP. The 6th Street and Avenue I WTP site was considered even though it is more spatially constrained than the 6th Street and Katy Avenue WTP site because the well pump at 6th Street and Katy Avenue pumps directly into the distribution system without the use of booster pumps. Additionally, the ground storage tank at 6th Street & Avenue I has a large enough volume to store the combined treated flows before being pumped into the distribution system by the existing booster pump station.

The combined treatment system cost was **based on a proposal received for an iron adsorption media vessel**, the least expensive alternative. The combined treatment system at 6th Street & Avenue I would allow for the utilization of the existing facilities onsite with marginal operating impacts. As shown in Table 13, the combined treatment system cost is \$350,000 more than the individual treatment systems at each site. However, with the larger combined system, the media life would be expected to be about two months longer and the City would only have to maintain and operate one system in lieu of two. Notwithstanding, for cost comparison purposes, we assumed the City would need to install a new dedicated water line from 6th Street and Katy Ave. to the 6th Street and Avenue I location.

5.7 Estimated Capital Construction Cost Comparison

Garver considered costs from vendors, site and civil work, backwashing piping, process piping and valves, electrical, instrumentation and controls, and concrete to estimate the capital construction costs of **iron adsorption media vessels** at individual well sites and at the centralized treatment system locations (described in Sections 5.6.1, 5.6.2). A comparison of the estimated capital construction costs between the treatment alternatives are shown in .

Table 13: Estimated Capital Cost Comparison of Individual Treatment Units and Centralized Treatment Systems

Adsorption System	6 th St & Avenue I	6 th St & Katy	Combined (Katy & Ave I)	Overall Centralized
Cost	\$ 2,550,000	\$ 1,980,000	\$ 4,940,000	\$ 14,400,000

Note: Table 13 Capital Construction Costs do not include cost for additional land or easement if deemed necessary



6.0 Recommendation

Garver evaluated four permanent arsenic removal systems for the 6th Street and Ave I and 6th St and Katy Ave Water Treatment Plants. The existing conditions and operations were assessed to determine alternatives to reduce arsenic levels to below the MCL and maintain TCEQ compliance.

Based on the capital cost, treatment reliability, technology footprint, operations and maintenance complexity, operations and maintenance cost, and requisite city staff engagement, **we recommend the City of Bay City implement Alternative No.1: Iron Adsorption Media Vessel at each well site.** This alternative will require a slab on grade system containing two carbon steel vessels and adsorptive media at each water plant site.


Garver assessed the need of adding an in-line booster pump at both treatment plant sites. For **6th Street and Avenue I**, given the treatment system maximum head loss of 10 psi, and the known differential between the well pump and ground storage tank, the addition of a new booster pump station is not anticipated and is not included in the capital construction cost. At the **6th Street and Katy Ave** site, the well pumps directly into the distribution system. With a similar treatment system head loss of 10 psi, this operational impact may need to be discussed further with the City. At this time we have not included an inline booster pump in the capital cost estimate for 6th Street and Katy Ave.

Based on the blending optimization model, only 50% of the water from the 6th St & Avenue I WTP will need to be treated and only 31% of the water from the 6th St & Katy Avenue WTP will need to be treated to reach 70% of the MCL and maintain compliance with TCEQ. Additionally, the amount of treated water can be easily and readily changed should raw water quality change in the future.

Garver considered two vendors for the installation of an adsorptive system, AdEdge (Chart Industries) and Applied Process Equipment. AdEdge provided a more competitive proposal with a smaller footprint. Our treatment team also has experience with multiple successful installations by AdEdge that exhibit operational reliability. Subsequently, herein, **we recommend the City of Bay City implement Iron Adsorption Media Vessels by AdEdge at each plant site, 6th Street & Avenue I and 6th Street & Katy Avenue.**

We would note that since the combined treatment system capital cost estimate is less than 10% more than the mutual individual treatment units, this may be an option to the recommended alternative that we can explore more closely during Detailed Design should the City have interest.

Appendix A: Record Drawings



N. I. C.
GENERAL NOTES

1. Contractor shall protect all trees designated by constructing a barrier around each tree trunk.
2. Existing Pool Filter and Associated Piping Above Ground and Underground shall be removed and salvaged as directed by Bay City officials.
3. Contractor shall field verify the location of any existing abandoned underground piping that may interfere with construction of new facilities.

NOTE:

DEMOLITION OF EXISTING STRUCTURES AND FILL OF EXISTING SWIMMING POOL PER THIS SHEET WILL HAVE BEEN ACCOMPLISHED BY THE CITY OF BAY CITY PRIOR TO THIS CONTRACT. THIS SHEET IS INCLUDED HEREIN FOR CONTRACTOR'S REFERENCE ONLY.

N. I. C.
LEGEND

- +41.67 Existing Spot Elevations
- Large Shade Trees To Be Protected as Per Note #1
- Concrete to be demolished & removed (may be used as fill in area indicated) to a Min depth of 18" below grade or to Elev. indicated
- Interior of Existing Swimming Pool To Be Filled With Compacted Select Sandy Clay To Finished Grade Elev 51.50, After Breaking Up " Bottom of Pool " To Allow Ground Water Drainage.
- Interior of Existing Swimming Pool To Be Filled With Rubble and Debris, above Elevation +7.00, as shown on Sht 3 of 3


CITY OF BAY CITY, TEXAS

DEMOLITION PLAN


Langford Engineering Inc. consulting engineers
450 West 5th North, Suite 108 - Houston, Texas - 77043

DESIGN	B.R.H.	DATE	023-24	COMT NO	2
DRAWN	C.W. & D.W.	DATE	SEPTEMBER 1982		
CHECKED	G.W.B.	SCALE	VERT 1" = 10'	HORIZ	
APPROVED	D.E.M.	SHEET NO	1	OF	3


9-20-82




NOTES:
 1. Bench Mark - "MM" IN TENNESSEE ON FLANGE OF
 PIPE 11023.017 @ NORTHWEST CORNER
 7th STREET & AVE I. ELEVATION 33.91



TEE SUPPORTS DETAILS
 N.T.S.




PIPE SUPPORT DETAIL
 N.T.S. (5 Read)




ENLARGED PLAN
 Scale: 1/4" = 1'-0"


CITY OF BAY CITY, TEXAS			
1.0 M.G. GROUND STORAGE TANK SITE LAYOUT			
450 West 8th North Suite 208 Houston, Texas 77003			
DESIGN	BRH	JOB NO.	023-24
DRAWN	D.B.W., G.W.B.	DATE	SEPTEMBER 1982
CHECKED	G.W.B.	SCALE	1" = 10'
APPROVED	D.E.M.	SHEET NO.	2 OF 3




TANK DRAIN DETAIL
N.T.S.



ACCESS HATCH DETAILS
Scale: 1/2" = 1'-0"




PLAN VIEW




ELEVATION

TANK INLET A & B DETAILS
(See Sheet 2 of 3 For Inlet Location and Designation)
N.T.S. (2 Req'd)




PLAN VIEW




ELEVATION

TANK OUTLET DETAILS
N.T.S.




PLAN VIEW




ELEVATION

MANHOLE DETAILS
(2 Required) See Sheet 2 of 3 For Location
N.T.S.



ACCESS LADDER DETAILS
N.T.S.



TANK VENT DETAIL
N.T.S.

General Note:
For Contractors Information only. Existing concrete of Pool, adjacent structures & walkways, shown on sheet 1 of 3, have been removed completely or to a min. depth of 18" below grade. In specified areas to an elevation of 46.00/47.00 to allow for construction of "Proposed Tank". Remains of concrete has been thoroughly ruptured. Excavations have been backfilled & compacted to Std. Proctor Density as shown below.

Finish Grade of Select Backfill Compacted to 95% Std. Proctor Density
F.O. Elev 51.50

Limits of Area Backfilled with Approved Debris From Demolished Structures, with Select Backfill Compacted to 90% Proctor.

Existing Select Backfill Compacted to 95% Std. Proctor Density.

Bottom of Pool has been thoroughly ruptured by mechanical means to allow for adequate groundwater drainage.

Existing Select Backfill Compacted to 90% Std. Proctor.

SECTION
N.T.S. (A) (13)

CITY OF BAY CITY, TEXAS		
I.O.M.G. GROUND STORAGE TANK MISCELLANEOUS DETAILS		
Langford Engineering, Inc. consulting engineers 1201 West Park North, Suite 100, Houston, Texas 77043		
DESIGN: B.R.H.	JOB NO: 023-24	CONT. NO: 2
DRAWN: G.W.B., P.J.S.	DATE: SEPTEMBER 1982	
CHECKED: G.W.B.	SCALE: VERT. AS SHOWN	HORIZ.
APPROVED: D.E.M.	SHEET NO. 3 OF 3	

CITY OF BAY CITY, TEXAS

CONSTRUCTION OF 1.0 M.G. GROUND STORAGE TANK

JOB NO. 023-24

CONTRACT NO. 2

INDEX OF DRAWINGS

SHT. NO.	SHEET TITLE
023-24*2	COVER SHEET
1 of 3	DEMOLITION PLAN
2 of 3	1.0 M.G. GROUND STORAGE TANK SITE LAYOUT
3 of 3	1.0 M.G. GROUND STORAGE TANK MISCELLANEOUS DETAILS

MAYOR

Glen White

CITY COUNCIL

C.B. Keener

Frank Henderson


Georgia Herreth

Pasqual Martinez

Meyer Denn

DIRECTOR OF UTILITIES

Clark Young



LANGFORD ENGINEERING INC.

CONSULTING ENGINEERS

1450 West Belt Drive North · Suite 108

Houston, Texas · 77043

Sept., 1982

IN ACCORDANCE WITH THE AGREEMENT DATED 12/10/82 1982,
BETWEEN THE CITY OF BAY CITY, TEXAS, OWNER, AND TANK BUILDERS, INC.,
CONTRACTOR, FOR CONSTRUCTION OF 1.0 M.G. GROUND STORAGE TANK, JOB
NO. 023-24, CONTRACT NO. 2, THE CONTRACT DRAWINGS LISTED IN THE
DRAWING INDEXY AND BOUND HEREWITH ARE CERTIFIED AND IDENTIFIED AS
PART OF THE AGREEMENT.

TANK BUILDERS, INC.
CONTRACTOR

BY: *Bruce Kromer*

TITLE: BRUCE KROMER, VICE-PRES.


DATE: 12/10/82

CITY OF BAY CITY



BY: *Glen White*

TITLE: *Mayor*

DATE: 12-10-82



- NOTES:**
1. Remove as soon as practicable, accumulated Rubbish and Open Block 15' public use. Where Section of Concrete pavement has been removed and it is desirable not to replace the pavement the same day, the Contractor will be required to provide, install, and maintain steel plating suitable to carry Public Traffic safely over the opened area. Include the cost of steel plating and all work required in other items of the project.
 2. All excess excavation and unsuitable soil for waste material, including vegetation, roots, concrete, and debris shall be disposed of by the Contractor as approved by the City of Bay City. Include haul in other items of the project.
 3. BEUCH MARK "MUN" in Tennessee on Flange of the Hydrant @ Northeast corner 7th Street & Avenue I. Elevation 53.91.
 4. Field Verify Location and Type of Material Prior to Connecting the New 6" Sanitary Sewer to the Existing 6" Sanitary Line. The Connection Will Require The Installation of 1" 6"x 6" A.I. Wye, M.J., D.I. And 1-4" 45° Bend M.J., D.I. With Associated Adapters to Connect the Wye into the Existing 6" Line.




CITY OF BAY CITY, TEXAS


BOOSTER PUMP STATION AND YARD PIPING SITE LAYOUT

Eangford
Engineering, Inc.
consulting engineers
490 West Bell North, Suite 108, Houston, Texas - 77063


DESIGN	B.R.H.	JOB NO.	023-24	CONT. NO.	3
DRAWN	G.W.B.	DATE	SEPTEMBER 1982		
CHECKED	D.E.M.	SCALE	1" = 10'	VERT.	HORIZ.
APPROVED	D.E.M.	SHEET NO.	1	OF	9




SOUTH ELEVATION
SCALE: 1/4"=1'-0"




NORTH ELEVATION
SCALE: 1/4"=1'-0"




EAST ELEVATION
SCALE: 1/4"=1'-0"




WEST ELEVATION
SCALE: 1/4"=1'-0"



TYPICAL INTERIOR JAMB DETAIL FOR PERSONNEL DOOR
NTS



TYPICAL EXTERIOR WINDOW DETAIL
NTS



TYPICAL INTERIOR DOOR DETAIL
NTS

EXTERIOR DOOR DETAIL
NTS

DOOR SCHEDULE		
SYMBOL	SIZE	DESCRIPTION
1	3' x 7'	Republic Steel Door, Series DM20, Type 4L, 5 3/4\"/>
2	3' x 7'	Republic Steel Door, Series DM20, Type 6L, 5 3/4\"/>
3	3' x 7'	Republic Steel Door, Series DM20, Type 8, 5 3/4\"/>
4	4' x 7'-10"	Republic Steel Door, Series DM20, Type 8, Double Swing Right Hand Active, 5 3/4\"/>
5	2' x 7'-0"	Republic Steel Door, Series DM20, Type 5, 5 3/4\"/>

WINDOW SCHEDULE		
SYMBOL	SIZE	DESCRIPTION
Δ	4'-0\"/>	







- EQUIPMENT DOOR NOTES**
1. Furnish & install (1) KENNELAR Model SPD-20 or APD01 Type ATM or Approved Equal.
 2. Door curtain shall be composed of interlocking slats (Hot Dip Galv.) w/ a phenolic coating for paint adhesion. Both ends of alternate slats shall be provided w/ end-locking also every 6th slat shall withstand a windload of 80 lbs./sq. ft.
 3. Doors shall come complete w/
 - A. Brackets - fabricated from min 3/8\"/>
 - B. Head - shall be 20 ga (Hot Dip Galv.) sheet metal.
 - C. Guides - fabricated of min 3/16\"/>
 4. Doors shall be operated by an electric operator motor shall be 1/2 hp, 115 v, 1 ph complete w/ worm gear reducer & an emergency hand chain hoist and a 24 volt control system. "Open - Close - Stop." The "Close" control button shall be of the constant - pressure type (motor to be wall mounted).
 5. All ferrous surfaces and work parts shall receive one factory applied coat of rust inhibitive metal primer.
 6. The equipment doors shall cover a 10'-0\"/>

CITY OF BAY CITY, TEXAS.

BOOSTER PUMP STATION ARCHITECTURAL PLAN ELEVATIONS AND DETAILS

Langford engineering inc. consulting engineers
1450 West Bell North, Suite 108 - Houston, Texas - 77043

DESIGN: B.R.H.	JOB NO: 023-24	CONT NO: 03
DRAWN: N.D.	DATE: SEPTEMBER 1982	
CHECKED: D.E.M.	SCALE: VERT AS SHOWN	HORIZ.
APPROVED: D.E.M.	SHEET NO: 3	OF 9











FITTING & VALVE SCHEDULE

Item No.	Description	No. Req'd
1	16" X 16" Tee, D.I., M.J.	1
2	16" X 10" Tee, D.I., M.J.	1
3	16" X 8" Tee, D.I., M.J.	1
4	16" X 12" Conc. Red., D.I., Large End M.J.	1
5	16" X 10" Conc. Red., D.I., Small End M.J.	1
6	18" X 12" Tee, D.I., Fig'd	1
7	18" X 12" Conc. Red., D.I., Fig'd	2
8	McDONNELL F57-V Flow Switches	2
9	12" X 8" Tee, D.I., Fig'd	7
10	12" X 8" Tee, D.I., Fig'd	2
11	12" X 10" Eccent. Red., D.I., Fig'd	1
12	12" X 8" Tee, D.I., Fig'd	7
13	12" X 10" Eccent. Red., D.I., Fig'd	1
14	12" X 3" Tee, 1/2" Ig Wall Pipe, D.I., M.J., Fig'd	1
15	12" Dresser Flange Adapter Style 177	1
16	10" X 45" Bend, D.I., Fig'd	2

CONTINUED

17	10" X 8" Eccent. Red., D.I., Fig'd	1
18	10" X 8" Conc. Red., D.I., Fig'd	1
19	10" Dresser Flange Adapter Style 177	3
20	10" X 2 1/2" Ig Wall Pipe, D.I., M.J., Fig'd	1
21	8" X 45" Bend, D.I., Fig'd	2
22	8" X 6" Tee, D.I., M.J.	1
23	8" X 6" Tee, D.I., M.J.	1
24	8" X 6" Conc. Red., D.I., Fig'd	1
25	8" X 4" Conc. Red., D.I., Fig'd	1
26	8" X 2 1/2" Ig Wall Pipe, D.I., M.J., Fig'd	1
27	18" Dresser Flange Adapter, Style 177	1
A	10" W-5500DR Rockwell Turbo-meter And 10" Strainer	2
B	12" Butterfly Valve	1
C	10" Butterfly Valve	2
D	8" Butterfly Valve	6
E	10" Check Valve	1
F	8" Check Valve	2



GENERAL NOTES













- SUMP PUMP - Furnish & install (1) "MCCO" Fiberglass Grating Type "CD" 15" x 15" x 3/8" x 1/4", Furnish Each ft of (2) 3" x 1/2" x 3" x 1/2" sections for easy removal; cut openings for pipe in necessary (cut edges shall be finished smooth).
- Dimensions @ Booster Pump Bases & Concrete Base Box Dimensions May Vary From Those Shown On Plan Refer To Approved Manufacturer Shop Drawings for Verification (Contractor shall verify Pump Suction & Discharge Centerline locations as shown on Plans).
- 4" Drain Line Base Drain Line Outlet location & Sealing to Piping May Vary w/ C.I. Base
- INSTALL - Furnish & install (1) "MCCO" Low Lead room Type Galvaloy # 902100 10' Dia. Capacity w/ Chain Containment # 902191.

CITY OF BAY CITY, TEXAS

BOOSTER PUMP STATION MECHANICAL PLAN, SECTION AND DETAILS

Langford Engineering Inc. consulting engineers
1920 West Bell North - Suite 108 - Houston, Texas - 77063

DESIGN: BRH	JOB NO: 023-24	CONT NO: 03
DRAWN: BRH	DATE: SEPTEMBER 1982	
CHECKED: DEM	SCALE: AS SHOWN	HOURS:
APPROVED: DEM	SHEET NO: 4	OF 9



PLUMBING FIXTURE SCHEDULE	
SYMBOL	DESCRIPTION
	WATER CLOSET: American Standard No. 2502.011, "Glenco" Toilet, Siphon Jet, Vitreous China, with Church No. 5320.072 Moltex heavy duty Plastic Elongated bowl, open front, Flush Valve Sloan Royal No. 112.YY. or as Manufactured by Briggs or Approved equal.
	LAVATORY: American Standard "Comrade" Wall Hung, 20" x 18" Vitreous China, with concealed arm hangers, No. 2103.729 Trim 1/4" Pop-up Drain, 1/4" Tail piece No. 4420.030 wdg. cast brass, C.P., "P" trap with cleanout No. 2306.017, Supplies & stop or as Manufactured by Briggs or other Approved equal.
	FLOOR DRAIN: Zurn Type 2-470, Cast Iron, with Nickel Bronze Strainer, Drum Trap, & Backwater Valve, or as Manufactured by Wade or other Approved equal.

PLUMBING SPECIFICATIONS:

- Provide 4 ea lead flashing at all plumbing Vents. Turn flashing down into vent 2" Min.
- Test Sanitary Lines & Vent piping by plugging all openings & filling the system the heights of all tests. inspect all joints, repair all leaks found & retest until piping is demonstrated to be free of leaks.


CITY OF BAY CITY, TEXAS

MISCELLANEOUS DETAILS



Engford
engineering, inc. consulting engineers

DESIGN	G.W.B.	JOB NO.	023-24	CONT. NO.	3
DRAWN	G.W.B.	DATE	SEPTEMBER 1982		
CHECKED	D.E.M.	SCALE	AS SHOWN	VERT	HORIZ
APPROVED	D.E.M.	SHEET NO.	5	OF	9


NOTE: All Electrical Conduits Shall Have A Min. Cover of 2 Feet. Conduits Shall Clear All Water And Sewer Lines By 2 Feet In Both The Horizontal And Vertical. Contractor Shall Minimize The Number of Conduit Bends Required. All Flow Switches Shall Have A Min of 2 Feet Flex. Conduit Connecting Flow Switch With Rigid Conduit.



POWER PLAN SCALE: 1/4" = 1'-0"




ONE LINE DIAGRAM N.T.S.




TANK SUPPORT N.T.S.


ANCHOR BOLT DETAIL N.T.S.



GENERATOR SET - EAST ELEVATION



GENERATOR SET - SOUTH ELEVATION




ELEVATION "A-A" SCALE: 3/4" = 1'-0"


	A	B	C
CONTROLS	1		2
CONTROLS	3		4
CONTROLS	5		6
CONTROLS	7		8
SUMP PUMP	9		10
CONTROL ROOM	30A		12
A/C UNIT	13		14
3 RECEPTACLES	15		16
3 RECEPTACLES	17		18
3" x 2", 2" D" FIXTURES	19		20
2" x 2", 2" B", 1 1/2" VFR	21		22
SPARES	23		24
	25		26
	27		28
	29		30

PANEL "LPA"

All Breakers 20 Amps, Unless Noted 3 PH, 4W - 100 Ampere MIO. Surface Mount 120/208 Volts



AUX. ENGINE SUPPLY SCHEMATIC - TYPICAL N.T.S.



SCHEMATIC DIAGRAM HIGH AND LOW PRESSURE SWITCHES

- NOTES
1. Tank Size - 500 Gal.
 2. For Orientation & Details See This Sheet & Detail 1/2" x 9"
 3. All Fuel Oil Lines To Be Supported At Tank Support & Engine Foundation With Galv. Clamps.

CITY OF BAY CITY, TEXAS

ELECTRICAL PLAN, DIAGRAMS AND DETAILS


Langford Engineering Inc. consulting engineers
1480 West Bell North - Suite 108 - Houston, Texas - 77043

DESIGN: D.E.M.	JOB NO: 023-24	CONT NO: 03
DRAWN: N.J.D.	DATE: SEPTEMBER 1982	
CHECKED: G.D.W.	SCALE: VERT AS SHOWN	HORIZ
APPROVED: G.D.W.	SHEET NO: 6	OF 9




Air Conditioner: General Electric
Zone Line, Packaged Terminal A.C.
#A 2.B.7.7B w/ RAF/BA Room
Cabinet or Approved Equal.

FIXTURE SCHEDULE (See Mounting Details)

Mk	Mfr. & Model	Mounting	Lamps	Remarks
A	HOLOPHANE 412-000 w/ Guard (120V)	Surf.	100W Inc.	Exterior
B	CRUISE-HINDS VBP	Surf.	100W Inc.	Chlorine Room
C	NUTONE 066Z	Ceiling	100W Inc.	Restroom
D	WIDELITE BH-250-A-120/240-S-P	Surf.	175W Inc.	Exterior
E	WESTINGHOUSE SF-3552227010	Ceiling	F40T12SHD	Control Room
F	WESTINGHOUSE 2E62200EP	Suspend	F40T12SHD	Pump Room 10' Above F.F.
G	WESTINGHOUSE 2V330 w/ PHOTO CELL	POLE	175W Merc.	Existing
H	FEDERAL 371	PIPE	1-200W	Alarm Light (Red)




"H" FIXTURE MOUNTING DETAIL
(1 Req'd on 1,300,000 Gal Tank)




Time Delay Relay Settings (all timers reset on de-energization)

Switch	Energized Before Timing	Relay Effect During Timing	Effect On Switch After Timing	Delay Range	Function
TD-1	Closed	Open	Closed	1-30 Min.	Refuse immed. restart of Well #9
TD-2	Open	Open	Closed*	1-60 Sec.	Shutdown Well #9 if no flow
TD-3	Closed	Open	Closed	1-30 Min.	Refuse immed. restart of Well #4 Deleted
TD-4	Open	Open	Closed*	1-60 Sec.	Shutdown Well #4 if no flow Deleted
TD-5	Open	Open	Closed*	1-60 Sec.	Shutdown BP #1 if no flow
TD-6	Open	Open	Closed*	1-60 Sec.	Shutdown BP #2 if no flow
TD-7	Open	Open	Closed*	1-60 Sec.	Shutdown BP #3 if no flow
Other's	Open	Open	Closed	1-60 Sec.	Delay action of




Pressure Switch Settings


Switch	Open	Close	Function
PS-1	24'	21'	Stop Well #9
PS-2	24'	21'	Start Well #9 Deleted
PS-3	24'	23'	Stop Well #4 Deleted
PS-4	24'	23'	Start Well #4 Deleted
PS-5	67 psi	61 psi	Start B.P. #1 - Condition A
PS-6	67 psi	61 psi	Stop B.P. #1 - Condition B
PS-7	67 psi	61 psi	Start B.P. #2 - Condition A
PS-8	67 psi	61 psi	Stop B.P. #2 - Condition B
PS-9	67 psi	61 psi	Start B.P. #3 - Condition A
PS-10	67 psi	61 psi	Stop B.P. #3 - Condition B
PS-11	60 psi	54 psi	Start B.P. #1
PS-12	60 psi	54 psi	Stop B.P. #1
PS-13	60 psi	54 psi	Start B.P. #2
PS-14	60 psi	54 psi	Stop B.P. #2
PS-15	60 psi	54 psi	Start B.P. #3
PS-16	60 psi	54 psi	Stop B.P. #3



LIGHTING PLAN
SCALE: 1/4" = 1'-0"



"A" FIXTURE MOUNTING DETAIL
3 Required



"B" FIXTURE MOUNTING DETAIL
2 Required

LEGEND

- Crankcase Heater
- Pressure Switch Normally Open or Closed As Indicated
- Flow Indicating Switch Normally Opened or Closed As Indicated
- Time Delay Relay Switch Normally Opened or Closed As Indicated
- Control Relay
- Time Delay Relay Coil
- Amber - Power On
- White - Required
- Green - Run
- Red - Fail
- Elapsed Time Meter
- Normally Open Contact
- Normally Closed Contact
- Hand-Off-Auto Selector Switch
- Alarm Bell
- Booster Pump Motor
- Solenoid Valve
- Motor - No. Indicates Size
- Motor Starter - Holding Coil Number & Indicates Well Pump Number

Flow Switch Number	Pipe Diameter	Min Flow In GPM
FS-1	8"	125
FS-2	8"	125
FS-3	8"	125
FS-4	10"	270
FS-5	12"	515


NO.	DESCRIPTION OF REVISION	DATE	BY
1	SIMPLIFY CONTROL SYSTEM BY DELETING PS-5, PS-6, PS-10 and PS-15 and CHANGING SETTINGS ON PS-3, PS-7, PS-12 and PS-14	1/2/88	G.J.M.

CITY OF BAY CITY, TEXAS

ELECTRICAL PLAN, DIAGRAMS AND DETAILS







Langford Engineering Inc.
consulting engineers
450 West Bell North, Suite 105 • Houston, Texas • 77043

DESIGN: D.E.M.	JOB NO: 023-24	CONT. NO: 03
DRAWN: G.W.B.	DATE: SEPTEMBER 1982	
CHECKED: G.D.W.	SCALE: VERT AS SHOWN	HORIZ.
APPROVED: G.D.W.	SHEET NO: 7 OF 9	



CONSTRUCTION NOTES

- Bench mark-"BM" in "Tennessee" on flange of fire hydrant at North East corner of 7th street and Ave. I. Elevation 53.91.
- Proposed 12" water line:
The alignment and location of the proposed 12" water line and its connections, hydrants, risers, etc. were determined from surveys excavation probing and from said information supplied by owner. Since exact locations and sizes of said utilities may be in doubt (due to a lack of records and inability to determine exactly on the ground), the owner reserves the right to make changes in line and location (due to unforeseeable obstructions) without additional compensation to contractor.
- Connection into existing 8" water line system and tie in to existing 4" water line:
Contractor shall not commence until the proposed 12" water line is installed, pressure tested, chlorinated and an acceptable sample has been approved by the Texas Department of Health.
- List of known utilities and owners representative:
City of Bay City-Dir. of Utilities-
Mr. C. Young-245-2322
City of Bay City-Water/Sewer Supt.-
Mr. Brinkman-245-9183
Bay City Gas Co.-Supervisor-
Mr. J. Deleon, Jr.-245-2327
Southwestern Bell Tel. Co. Supervisor-
Mr. Bruno-245-5703
Central Power and Light Co.-
245-8371
A.T. and S.F. Railroad-



LEGEND

RAILROAD CABLE	SIGNAL JUNCTION BOX
WATER METER	WATER METER
GAS LINE	GAS METER
SANITARY SEWER	SAN. SEWER MANHOLE
STORM SEWER	GRATE INLET
POWER POLE	BUILDING OR HOUSE
GUY WIRE	TREE
FENCE	BUSH
SIDEWALK	HEDGE
CONCRETE	STUMP
ASPHALT	WATER VALVE
SHELL, GRAVEL or DIRT	FIRE HYDRANT


CITY OF BAY CITY, TEXAS

12" WATERLINE
6th STREET FROM AVE. I
TO AVE. K


Langford engineering inc. consulting engineers

DESIGN	JOB NO. 023-24	CONT. NO. 3
DRAWN	DATE SEPTEMBER 1982	
CHECKED	SCALE	VERT. HORIZ.
APPROVED	SCALE 1"=2'-0"	1"=20'


SHEET NO. 8 OF 9



TYPICAL SERVICE RECONSTRUCTIONS
N.T.S.




TYPICAL 2\"/>




TAP DETAIL DETAIL "A"
N.T.S.

CURB STOP DETAIL DETAIL "B"
N.T.S.


DETAIL "C"
N.T.S.



RESIDENTIAL SERVICE RECONNECTION
N.T.S.




SECTION SHOWING METHOD OF CUTTING




SECTION SHOWING METHOD OF REPAIR


CUTTING AND REPAIRING CONCRETE AND ASPHALT PAVEMENT DETAIL




GATE VALVE INSTALLATION DETAIL
N.T.S.




PLAN



ELEVATION STANDARD FIRE HYDRANT DETAILS
N.T.S.



FITTING ASSEMBLY & THRUST BLOCK DETAILS
N.T.S.



TYPICAL DITCH AND BACKFILL
N.T.S.

Table of Slab Depths & Reinf.

Min. Depth of Slab	Width of Trench	Bar of Reinf.	Spacing of Bar	Length of Bar
8"	18"	4	9"	40"
8"	24"	4	8"	42"
8"	30"	4	7"	52"
8"	36"	4	6"	58"
10"	42"	4	8 1/2"	64"
10"	48"	4	7 1/2"	70"
10"	54"	4	7"	76"
10"	60"	4	6 1/2"	82"
10"	66"	5	9"	88"
10"	72"	6	8 1/2"	94"
10"	78"	6	8"	100"
10"	84"	6	7 1/2"	106"

CITY OF BAY CITY, TEXAS

STANDARD CONSTRUCTION DETAILS

Langford Engineering Inc. consulting engineers

DESIGN: L.W.B. JOB NO: 023 24 COMT NO: 3

DRAWN: N.J.D. DATE: SEPTEMBER 1982

CHECKED: G.J.M. SCALE: N.T.S.

APPROVED: SHEET NO 9 OF 9

CITY OF BAY CITY, TEXAS

CONSTRUCTION OF WATER PUMP STATION

AT AVE I & SIXTH STREET

JOB NO. 023-24 CONTRACT NO. 3

MAYOR

Glen White

CITY COUNCIL

C. B. Keener

Frank Henderson


Georgia Herreth

Pasqual Martinez

Meyer Denn

DIRECTOR OF UTILITIES

Clark Young



LANGFORD ENGINEERING INC.
CONSULTING ENGINEERS
 1450 West Belt Drive North · Suite 108
 Houston, Texas · 77043
 Sept., 1982

INDEX OF DRAWINGS

SHEET NO.	SHEET TITLE
023-24 3	COVER SHEET
1 OF 9	BOOSTER PUMP STATION AND YARD PIPING SITE LAYOUT
2 OF 9	BOOSTER PUMP STATION STRUCTURAL FOUNDATION PLAN AND STRUCTURAL ROOF PLAN AND DETAILS
3 OF 9	BOOSTER PUMP STATION ARCHITECTURAL PLAN, ELEVATION AND DETAILS
4 OF 9	BOOSTER PUMP STATION MECHANICAL, PLAN, SECTION AND DETAILS
5 OF 9	MISCELLANEOUS DETAILS
6 OF 9	ELECTRICAL PLAN, DIAGRAMS, AND DETAILS
7 OF 9	ELECTRICAL PLAN, DIAGRAMS, AND DETAILS
8 OF 9	12" WATERLINE - 6TH STREET FROM AVE. I TO AVE. K
9 OF 9	STANDARD CONSTRUCTION DETAILS

IN ACCORDANCE WITH THE AGREEMENT DATED 12/13/82 1982,
 BETWEEN THE CITY OF BAY CITY, TEXAS, OWNER, AND MERCER CONSTRUCTION
 COMPANY, CONTRACTOR, FOR CONSTRUCTION OF WATER PUMP STATION AT
 AVENUE I AND SIXTH STREET, JOB NO. 023-24, CONTRACT NO. 3, THE
 CONTRACT DRAWINGS LISTED IN THE DRAWING INDEX AND BOUND HEREWITH ARE
 CERTIFIED AND IDENTIFIED AS PART OF THE AGREEMENT.

MERCER CONSTRUCTION CO.
 CONTRACTOR

BY: W. M. Mercer

TITLE: pres

DATE: 12/13/82

CITY OF BAY CITY
 OWNER

BY: Glen White

TITLE: Mayor

DATE: 12-13-82

Appendix B: Additional Water Quality Sampling

ANALYTICAL REPORT

Eurofins Houston
4145 Greenbriar Dr
Stafford, TX 77477
Tel: (281)240-4200


Laboratory Job ID: 860-32031-1

Client Project/Site: Bay City Raw Water Wells

For:

Garver LLC
12141 Wickchester Lane
Suite 200
Houston, Texas 77079

Attn: Sabin K Jacob



Authorized for release by:
9/9/2022 5:51:08 PM

Travis Richter, Project Manager
(281)794-7216

Travis.Richter@et.eurofinsus.com

LINKS

Review your project
results through



Have a Question?



Visit us at:

www.eurofinsus.com/Env

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Table of Contents

Cover Page	1
Table of Contents	2
Definitions/Glossary	3
Case Narrative	4
Detection Summary	5
Client Sample Results	6
QC Sample Results	7
QC Association Summary	10
Lab Chronicle	12
Certification Summary	13
Method Summary	14
Sample Summary	15
Chain of Custody	16
Receipt Checklists	18

Definitions/Glossary

ITEM #2.

Client: Garver LLC
Project/Site: Bay City Raw Water Wells

Job ID: 800-02051-1

Qualifiers

Metals

Qualifier	Qualifier Description
U	Indicates the analyte was analyzed for but not detected.

General Chemistry

Qualifier	Qualifier Description
HF	Field parameter with a holding time of 15 minutes. Test performed by laboratory at client's request.
U	Indicates the analyte was analyzed for but not detected.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
▫	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: Garver LLC
Project/Site: Bay City Raw Water Wells

Job ID: 860-32031-1

ITEM #2.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Job ID: 860-32031-1

Laboratory: Eurofins Houston

Narrative

Job Narrative 860-32031-1

Comments

No additional comments.

Receipt

The sample was received on 8/24/2022 1:00 PM. Unless otherwise noted below, the sample arrived in good condition, and where required, properly preserved and on ice. The temperature of the cooler at receipt was 4.2° C.

Receipt Exceptions

The Chain-of-Custody (COC) was incomplete as received and/or improperly completed. COC is totally empty, no information at all.

Metals

Method 1632 As III: The matrix spike / matrix spike duplicate (MS/MSD) recoveries for analytical batch 580-402991 were outside control limits. Sample matrix interference and/or non-homogeneity are suspected because the associated laboratory control sample (LCS) recovery was within acceptance limits.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

General Chemistry

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Detection Summary

ITEM #2.

Client: Garver LLC
 Project/Site: Bay City Raw Water Wells

Job ID: 860-32031-1

Client Sample ID: Sample1

Lab Sample ID: 860-32031-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Arsenite	1.15		0.500	0.255	ug/L	10		1632 As III	Total/NA
Arsenate	9.55		1.00	0.690	ug/L	1		1632 As V	Total/NA
Inorganic Arsenic	10.7		1.00	0.690	ug/L	20		1632	Total/NA
SiO2	17.3		1.07	0.446	mg/L	1		6010D	Total/NA
pH	8.28	HF			SU	1		9040C	Total/NA
Temperature	17.9	HF			Degrees C	1		9040C	Total/NA
Corrosivity	8.28	HF			SU	1		9040C	Total/NA
Alkalinity	213		4.00	4.00	mg/L	1		SM 2320B	Total/NA

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

This Detection Summary does not include radiochemical test results.

Client Sample Results

Client: Garver LLC
 Project/Site: Bay City Raw Water Wells

Job ID: 860-32031-1
ITEM #2.

Client Sample ID: Sample1
 Date Collected: 08/24/22 00:00
 Date Received: 08/24/22 13:00

Lab Sample ID: 860-32031-1
 Matrix: Water

Method: 1632 As III - Arsenic Speciation by Hydride- Generation Cryo-Trapping GC-AAS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenite	1.15		0.500	0.255	ug/L			09/02/22 19:00	10

Method: 1632 As V - Arsenic Speciation by Hydride- Generation Cryo-Trapping GC-AAS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenate	9.55		1.00	0.690	ug/L			09/06/22 12:58	1

Method: 1632 - Arsenic Speciation by Hydride- Generation Cryo-Trapping GC-AAS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Inorganic Arsenic	10.7		1.00	0.690	ug/L			09/08/22 13:19	20

Method: 6010D - Metals (ICP)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Vanadium	<0.00518	U	0.0200	0.00518	mg/L		08/31/22 09:30	08/31/22 17:39	1
SiO2	17.3		1.07	0.446	mg/L		08/31/22 09:30	08/31/22 17:39	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Phosphate as P	<0.00959	U	0.0200	0.00959	mg/L		09/02/22 17:21	09/03/22 12:58	1
pH	8.28	HF			SU			09/01/22 13:44	1
Temperature	17.9	HF			Degrees C			09/01/22 13:44	1
Corrosivity	8.28	HF			SU			09/01/22 13:44	1
Alkalinity	213		4.00	4.00	mg/L			08/27/22 15:27	1

QC Sample Results

ITEM #2.

Client: Garver LLC
 Project/Site: Bay City Raw Water Wells

Job ID: 860-32031-1

Method: 1632 - Arsenic Speciation by Hydride- Generation Cryo-Trapping GC-AAS

Lab Sample ID: MB 580-403385/10
Matrix: Water
Analysis Batch: 403385

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Inorganic Arsenic	<0.345	U	0.500	0.345	ug/L			09/08/22 12:43	10

Lab Sample ID: LCS 580-403385/11
Matrix: Water
Analysis Batch: 403385

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Inorganic Arsenic	2.47	2.747		ug/L		111	50 - 150

Lab Sample ID: LCSD 580-403385/12
Matrix: Water
Analysis Batch: 403385

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Inorganic Arsenic	2.47	2.578		ug/L		104	50 - 150	6	35

Lab Sample ID: 860-32031-1 MS
Matrix: Water
Analysis Batch: 403385

Client Sample ID: Sample1
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Inorganic Arsenic	10.7		4.95	15.07		ug/L		89	50 - 150

Lab Sample ID: 860-32031-1 MSD
Matrix: Water
Analysis Batch: 403385

Client Sample ID: Sample1
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Inorganic Arsenic	10.7		4.95	16.12		ug/L		110	50 - 150	7	35

Method: 1632 As III - Arsenic Speciation by Hydride- Generation Cryo-Trapping GC-AAS

Lab Sample ID: MB 580-402991/41
Matrix: Water
Analysis Batch: 402991

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenite	<0.0255	U	0.0500	0.0255	ug/L			09/02/22 18:40	1

Lab Sample ID: MB 580-402991/9
Matrix: Water
Analysis Batch: 402991

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenite	<0.255	U	0.500	0.255	ug/L			09/02/22 14:26	10

QC Sample Results

ITEM #2.

Client: Garver LLC
 Project/Site: Bay City Raw Water Wells

Job ID: 860-02051-1

Method: 1632 As III - Arsenic Speciation by Hydride- Generation Cryo-Trapping GC-AAS (Continued)

Lab Sample ID: LCS 580-402991/10
Matrix: Water
Analysis Batch: 402991

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Arsenite	2.50	1.685		ug/L		67	30 - 170

Lab Sample ID: LCSD 580-402991/11
Matrix: Water
Analysis Batch: 402991

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Arsenite	2.50	2.232		ug/L		89	30 - 170	28	35

Method: 6010D - Metals (ICP)

Lab Sample ID: MB 860-67310/1-A
Matrix: Water
Analysis Batch: 67553

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 67310

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Vanadium	<0.00518	U	0.0200	0.00518	mg/L		08/31/22 09:30	08/31/22 16:51	1
SiO2	<0.446	U	1.07	0.446	mg/L		08/31/22 09:30	08/31/22 16:51	1

Lab Sample ID: LCS 860-67310/2-A
Matrix: Water
Analysis Batch: 67553

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 67310

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Silicon	10.0	10.40		mg/L		104	80 - 120
Vanadium	1.00	1.030		mg/L		103	80 - 120

Lab Sample ID: LCSD 860-67310/3-A
Matrix: Water
Analysis Batch: 67553

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 67310

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Silicon	10.0	10.30		mg/L		103	80 - 120	1	20
Vanadium	1.00	1.030		mg/L		103	80 - 120	0	20

Method: 365.1 - Phosphorus, Total

Lab Sample ID: MB 860-67785/4-A
Matrix: Water
Analysis Batch: 67832

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 67785

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Phosphate as P	<0.00959	U	0.0200	0.00959	mg/L		09/02/22 17:21	09/03/22 12:52	1

QC Sample Results

ITEM #2.

Client: Garver LLC
 Project/Site: Bay City Raw Water Wells

Job ID: 860-32031-1

Method: 365.1 - Phosphorus, Total (Continued)

Lab Sample ID: LCS 860-67785/5-A
 Matrix: Water
 Analysis Batch: 67832

Client Sample ID: Lab Control Sample
 Prep Type: Total/NA
 Prep Batch: 67785

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Total Phosphate as P	0.250	0.2565		mg/L		103	90 - 110

Lab Sample ID: LCSD 860-67785/6-A
 Matrix: Water
 Analysis Batch: 67832

Client Sample ID: Lab Control Sample Dup
 Prep Type: Total/NA
 Prep Batch: 67785

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Total Phosphate as P	0.250	0.2548		mg/L		102	90 - 110	1	20

Method: 9040C - pH

Lab Sample ID: 860-32031-1 DU
 Matrix: Water
 Analysis Batch: 67561

Client Sample ID: Sample1
 Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
pH	8.28	HF	8.310		SU		0.4	20
Temperature	17.9	HF	17.80		Degrees C		0.6	20
Corrosivity	8.28	HF	8.310		SU		0.4	

Method: SM 2320B - Alkalinity

Lab Sample ID: MB 860-66975/4
 Matrix: Water
 Analysis Batch: 66975

Client Sample ID: Method Blank
 Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Alkalinity	<4.00	U	4.00	4.00	mg/L			08/27/22 13:24	1

Lab Sample ID: LCS 860-66975/5
 Matrix: Water
 Analysis Batch: 66975

Client Sample ID: Lab Control Sample
 Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Alkalinity	250	249.5		mg/L		100	85 - 115

Lab Sample ID: LCSD 860-66975/6
 Matrix: Water
 Analysis Batch: 66975

Client Sample ID: Lab Control Sample Dup
 Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Alkalinity	250	253.6		mg/L		101	85 - 115	2	20

QC Association Summary

ITEM #2.

Client: Garver LLC
 Project/Site: Bay City Raw Water Wells

Job ID: 860-32031-1

Metals

Prep Batch: 67310

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-32031-1	Sample1	Total/NA	Water	3010A	
MB 860-67310/1-A	Method Blank	Total/NA	Water	3010A	
LCS 860-67310/2-A	Lab Control Sample	Total/NA	Water	3010A	
LCSD 860-67310/3-A	Lab Control Sample Dup	Total/NA	Water	3010A	

Analysis Batch: 67553

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-32031-1	Sample1	Total/NA	Water	6010D	67310
MB 860-67310/1-A	Method Blank	Total/NA	Water	6010D	67310
LCS 860-67310/2-A	Lab Control Sample	Total/NA	Water	6010D	67310
LCSD 860-67310/3-A	Lab Control Sample Dup	Total/NA	Water	6010D	67310

Analysis Batch: 402991

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-32031-1	Sample1	Total/NA	Water	1632 As III	
MB 580-402991/41	Method Blank	Total/NA	Water	1632 As III	
MB 580-402991/9	Method Blank	Total/NA	Water	1632 As III	
LCS 580-402991/10	Lab Control Sample	Total/NA	Water	1632 As III	
LCSD 580-402991/11	Lab Control Sample Dup	Total/NA	Water	1632 As III	

Analysis Batch: 403027

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-32031-1	Sample1	Total/NA	Water	1632 As V	

Analysis Batch: 403385

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-32031-1	Sample1	Total/NA	Water	1632	
MB 580-403385/10	Method Blank	Total/NA	Water	1632	
LCS 580-403385/11	Lab Control Sample	Total/NA	Water	1632	
LCSD 580-403385/12	Lab Control Sample Dup	Total/NA	Water	1632	
860-32031-1 MS	Sample1	Total/NA	Water	1632	
860-32031-1 MSD	Sample1	Total/NA	Water	1632	

General Chemistry

Analysis Batch: 66975

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-32031-1	Sample1	Total/NA	Water	SM 2320B	
MB 860-66975/4	Method Blank	Total/NA	Water	SM 2320B	
LCS 860-66975/5	Lab Control Sample	Total/NA	Water	SM 2320B	
LCSD 860-66975/6	Lab Control Sample Dup	Total/NA	Water	SM 2320B	

Analysis Batch: 67561

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-32031-1	Sample1	Total/NA	Water	9040C	
860-32031-1 DU	Sample1	Total/NA	Water	9040C	

Prep Batch: 67785

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-32031-1	Sample1	Total/NA	Water	365.2/365.3/365	
MB 860-67785/4-A	Method Blank	Total/NA	Water	365.2/365.3/365	

QC Association Summary

Client: Garver LLC
Project/Site: Bay City Raw Water Wells

Job ID: 860-32031-1

ITEM #2.

General Chemistry (Continued)

Prep Batch: 67785 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LCS 860-67785/5-A	Lab Control Sample	Total/NA	Water	365.2/365.3/365	
LCSD 860-67785/6-A	Lab Control Sample Dup	Total/NA	Water	365.2/365.3/365	

Analysis Batch: 67832

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
860-32031-1	Sample1	Total/NA	Water	365.1	67785
MB 860-67785/4-A	Method Blank	Total/NA	Water	365.1	67785
LCS 860-67785/5-A	Lab Control Sample	Total/NA	Water	365.1	67785
LCSD 860-67785/6-A	Lab Control Sample Dup	Total/NA	Water	365.1	67785

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Lab Chronicle

ITEM #2.

Client: Garver LLC
 Project/Site: Bay City Raw Water Wells

Job ID: 860-32031-1

Client Sample ID: Sample1
Date Collected: 08/24/22 00:00
Date Received: 08/24/22 13:00

Lab Sample ID: 860-32031-1
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Analysis	1632		20			403385	09/08/22 13:19	D1C	EET SEA
Total/NA	Analysis	1632 As III		10			402991	09/02/22 19:00	D1C	EET SEA
Total/NA	Analysis	1632 As V		1			403027	09/06/22 12:58	AJR	EET SEA
Total/NA	Prep	3010A			50 mL	50 mL	67310	08/31/22 09:30	MD	EET HOU
Total/NA	Analysis	6010D		1			67553	08/31/22 17:39	DP	EET HOU
Total/NA	Prep	365.2/365.3/365			10 mL	10 mL	67785	09/02/22 17:21	ALL	EET HOU
Total/NA	Analysis	365.1		1			67832	09/03/22 12:58	ALL	EET HOU
Total/NA	Analysis	9040C		1			67561	09/01/22 13:44	TL	EET HOU
Total/NA	Analysis	SM 2320B		1			66975	08/27/22 15:27	TL	EET HOU

Laboratory References:

EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200
 EET SEA = Eurofins Seattle, 5755 8th Street East, Tacoma, WA 98424, TEL (253)922-2310



Accreditation/Certification Summary

ITEM #2.

Client: Garver LLC
 Project/Site: Bay City Raw Water Wells

Job ID: 866-92051-1

Laboratory: Eurofins Houston

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date																
Texas	NELAP	T104704215-22-47	06-30-23																
<p>The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Analysis Method</th> <th style="text-align: left;">Prep Method</th> <th style="text-align: left;">Matrix</th> <th style="text-align: left;">Analyte</th> </tr> </thead> <tbody> <tr> <td>6010D</td> <td>3010A</td> <td>Water</td> <td>SiO2</td> </tr> <tr> <td>9040C</td> <td></td> <td>Water</td> <td>Corrosivity</td> </tr> <tr> <td>9040C</td> <td></td> <td>Water</td> <td>Temperature</td> </tr> </tbody> </table>				Analysis Method	Prep Method	Matrix	Analyte	6010D	3010A	Water	SiO2	9040C		Water	Corrosivity	9040C		Water	Temperature
Analysis Method	Prep Method	Matrix	Analyte																
6010D	3010A	Water	SiO2																
9040C		Water	Corrosivity																
9040C		Water	Temperature																

Laboratory: Eurofins Seattle

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Alaska (UST)	State	20-004	02-19-25
ANAB	Dept. of Defense ELAP	L2236	01-19-25
ANAB	Dept. of Energy	L2236	01-19-25
ANAB	ISO/IEC 17025	L2236	01-19-25
Arkansas DEQ	State	8801526	05-23-23
California	State	2954	07-07-22 *
Florida	NELAP	E87575	06-30-23
Louisiana	NELAP	03073	06-30-23
Maine	State	WA01273	05-02-24
Montana (UST)	State	NA	04-14-27
New Jersey	NELAP	WA014	06-30-23
New York	NELAP	11662	04-01-23
Oregon	NELAP	4167	07-08-23
US Fish & Wildlife	US Federal Programs	A20571	06-30-23
USDA	US Federal Programs	P330-20-00031	02-10-23
Washington	State	C788	07-13-23
Wisconsin	State	399133460	08-31-22 *

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

ITEM #2.

Client: Garver LLC
 Project/Site: Bay City Raw Water Wells

Job ID: 866-92051-1

Method	Method Description	Protocol	Laboratory
1632	Arsenic Speciation by Hydride- Generation Cryo-Trapping GC-AAS	EPA	EET SEA
1632 As III	Arsenic Speciation by Hydride- Generation Cryo-Trapping GC-AAS	EPA	EET SEA
1632 As V	Arsenic Speciation by Hydride- Generation Cryo-Trapping GC-AAS	EPA	EET SEA
6010D	Metals (ICP)	SW846	EET HOU
365.1	Phosphorus, Total	EPA	EET HOU
9040C	pH	SW846	EET HOU
SM 2320B	Alkalinity	SM	EET HOU
3010A	Preparation, Total Metals	SW846	EET HOU
365.2/365.3/365	Phosphorus, Total	MCAWW	EET HOU

Protocol References:

- EPA = US Environmental Protection Agency
- MCAWW = "Methods For Chemical Analysis Of Water And Wastes", EPA-600/4-79-020, March 1983 And Subsequent Revisions.
- SM = "Standard Methods For The Examination Of Water And Wastewater"
- SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

- EET HOU = Eurofins Houston, 4145 Greenbriar Dr, Stafford, TX 77477, TEL (281)240-4200
- EET SEA = Eurofins Seattle, 5755 8th Street East, Tacoma, WA 98424, TEL (253)922-2310



Sample Summary

Client: Garver LLC
Project/Site: Bay City Raw Water Wells


Job ID: 860-32031-1

ITEM #2.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
860-32031-1	Sample1	Water	08/24/22 00:00	08/24/22 13:00

Chain of Custody Record

Client Information		Lab PM: Richter Travis W		Carrier Tracking No(s): 880-11857-4135.1	
Client Contact: Sabin Jacob		E-Mail: Travis.Richter@et.eurofins.com		State of Origin:	
Company: Garver		pwsID:		Page: Page 1 of 1	
Address: 12141 Wickchester Lane Suite 200		Due Date Requested:		Job #:	
City: Houston		TAT Requested (days):		Preservation Codes:	
State, Zip: TX, 77079		Compliance Project: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		A HCL B NaOH C Zn Acetate D Nitric Acid E NaHSO4 F MeOH G Amchlor H Ascorbic Acid I Ice J DI Water K EDTA L EDA Other	
Phone: 713-491-8333(Tel)		Purchase Order Requested		M Hexane N None O AsNaO2 P Na2OAS Q Na2SO3 R Na2S2O3 S H2SO4 T TSP Dodecahydrate U Acetone V MCAA W pH 4-5 Y Trizma Z other (specify)	
Email: SKJacob@GarverUSA.com		WO #:		Total Number of Containers: <input checked="" type="checkbox"/>	
Project Name: Bay City Raw Water Wells		Project #: 86003663		Special Instructions/Note:	
Site:		SSOW#:		Field Filled Sample (Yes or No) <input checked="" type="checkbox"/>	
<div style="text-align: center;">  860-32031 Chain of Custody </div>		Sample Date		S D N A	
		Sample Time		60100 SI and V by ICP 2308, 9040C 1632, 1632 As, III	
Sample Type (G=comp, G=grab)		Sample Time		365, Total Phosphorus as P	
Preservation Code:		Matrix (Water, Seawater, Oncozestrol, etc.)		Temp: 30 IR ID:HOU-344 C/F: +1.2 Corrected Temp: 4.2	
Water		Water		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)	
Water		Water		<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months	
Water		Water		Special Instructions/QC Requirements:	
Water		Water		Possible Hazard Identification	
Water		Water		<input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological	
Water		Water		Deliverable Requested: I II III IV Other (specify)	
Water		Water		Empty Kit Relinquished by:	
Water		Water		Date/Time: _____ Date: _____	
Water		Water		Relinquished by: _____ Company: _____	
Water		Water		Relinquished by: _____ Date/Time: _____ Company: _____	
Water		Water		Relinquished by: _____ Date/Time: _____ Company: _____	
Water		Water		Custody Seal Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Water		Water		Custody Seal No. _____	
Water		Water		Cooler Temperature(s) °C and Other Remarks:	

ITEM #2.

Ver 01/16/2019


Date/Time: 8/24/22 1300
 Date/Time: _____
 Date/Time: _____

Received by: *[Signature]* Company: _____
 Received by: _____ Company: _____
 Received by: _____ Company: _____

Eurofins Houston

4145 Greenbriar Dr
Stafford, TX 77477
Phone: 281-240-4200

Chain of Custody Record



Environment Testing
America

ITEM #2.

Client Information (Sub Contract Lab)		Sampler:		Lab PM:		Carrier Tracking No(s):		COC No:			
Client Contact: Shipping/Receiving		Phone:		E-Mail:		State of Origin:		Page:			
Company: Eurofins Environment Testing Northwest,		Due Date Requested: 8/31/2022		Accreditations Required (See note): NELAP - Texas		Job #:		860-32031-1			
Address: 5755 8th Street East,		TAT Requested (days):		Analysis Requested						Preservation Codes: A - HCL M - Hexane B - NaOH N - None C - Zn Acetate O - AsNaO2 D - Nitric Acid P - Na2O4S E - NaHSO4 Q - Na2SO3 F - MeOH R - Na2S2O3 G - Amchlor S - H2SO4 H - Ascorbic Acid T - TSP Dodecahydrate I - Ice U - Acetone J - DI Water V - MCAA K - EDTA W - pH 4-5 L - EDA Y - Trizma Z - other (specify): Other:	
City: Tacoma		PO #:									
State, Zip: WA, 98424		WO #:									
Phone: 253-922-2310(Tel)		Project #: 86003663									
Email:		SSOW#:									
Project Name: Bay City Raw Water Wells		Site:		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Total Number of Containers			
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=Water, S=solid, O=wastewater, BT=Tissue, A=Air)			
Sample1 (860-32031-1)		8/24/22		Central		Water		2			

Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing South Central, LLC places the ownership of method, analyte & accreditation compliance upon out subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing South Central, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing South Central, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing South Central, LLC.

Possible Hazard Identification				Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)			
Unconfirmed				<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months			
Deliverable Requested: I, II, III, IV, Other (specify)		Primary Deliverable Rank: 2		Special Instructions/QC Requirements: 777 6734 9351			
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:	
Relinquished by: <i>[Signature]</i>		Date/Time: 8/29/22 1900		Company: Ex		Received by: <i>[Signature]</i>	
Relinquished by:		Date/Time:		Company:		Date/Time: 8/29/22 9:21	
Relinquished by:		Date/Time:		Company:		Date/Time:	
Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.: NA		Cooler Temperature(s) °C and Other Remarks: 0.5 D12 2001			

Login Sample Receipt Checklist

Client: Garver LLC

Job Number: 860-32031-1

Login Number: 32031

List Source: Eurofins Houston

List Number: 1

Creator: Palmar, Pedro

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	False	No information at all.
COC is filled out with all pertinent information.	False	No information at all.
Is the Field Sampler's name present on COC?	False	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	False	No date or time on COC or sample containers
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	N/A	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	

Login Sample Receipt Checklist

Client: Garver LLC

Job Number: 860-32031-1

Login Number: 32031

List Number: 2

Creator: Miller, Darren R

List Source: Eurofins Seattle

List Creation: 08/26/22 12:30 PM

Question	Answer	Comment
Radioactivity wasn't checked or is <=/ background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
Multiphasic samples are not present.	N/A	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

Appendix C: Water Quality Modeling (Blending Optimization) Calculations

Water Quality Data from Drinking Water Watch and City Staff

Parameter	EP001	EP003	EP002	EP004	EP005	Column1	MCL/SMCL	Units
Arsenic	0.0053	0.0090	0.0077	0.0125	0.005			0.01 mg/L
Calcium	30.3	16.2	18.4	13.7	20.8		--	mg/L
Chloride	40	67	72	47	106			300 mg/L
Fluoride	0.37	0.47	0.38	0.42	0.61			2 mg/L
Iron	0.075	0.044	0.047	0.028	0.053			0.3 mg/L
Magnesium	12.2	6.55	7.92	5.53	8.57		--	mg/L
Manganese	0.017	0.0087	0.011	0.0081	0.0118			0.05 mg/L
Selenium	0.003	0.0051	0.0066	0.0034	0.003			0.05 mg/L
Sodium	71.7	107	107	98.2	140.5		--	mg/L
Sulfate	15	14	14	14	13			300 mg/L
Total Alkalinity	278	251	251	246	282		--	mg/L as CaCO ₃
Total Hardness	123	67.4	78.6	57	84.4		--	mg/L as CaCO ₃
Total Dissolved Solids	325	372	377	330	440			1000 mg/L
CSMR	2.7	4.8	5.1	3.4	8.2			
pH	7.8	7.9	8	7.8	7.9		≥ 7.0	S.U.
DI C	571	512	509	506	575		--	mg/L as CaCO ₃

Capacity and Flow Data from Drinking Water Watch

Entry Point	Rated Flow (GPM)
EP001	1360
EP003	1050
EP002	1010
EP004	1250
EP005	1300

Condition	MGD	GPM	With 25% Safety Factor
Max Day Demand	3.266	2268	2835
Average Day	2.369	1645	2056

Blend Types

Type	Description	Max Flow (gpm)
1	Single Well (no blending)	
2a	Two Wells - EP001 + EP003	2410
2b	Two Wells - EP001 + EP004	2610
2c	Two Wells - EP005 + EP003	2350
2d	Two Wells - EP005 + EP004	2550
3a	Three Wells - EP001 + EP003 + EP004	3660
3b	Three Wells - EP003 + EP004 + EP005	3600
3c	Three Wells - EP005 + EP003 + EP002	3360
3d	Three Wells - EP005 + EP002 + EP004	3560
4	Four Wells - EP001 + EP003 + EP004 + EP005	4960
5	Five Wells - All Entry Points	5970

Blending calculations for conservative parameters are provided in the table below. Blends are filtered based on the "Used" column (far right).

Blends

Blend Type	Blend	EP001	EP003	EP002	EP004	EP005	Check	Arsenic	Calcium
2a	16	56%	44%	0%	0%	0%	100%	0.007	24
2b	38	70%	0%	0%	30%	0%	100%	0.007	25
2c	54	0%	45%	0%	0%	55%	100%	0.007	19
2d	68	0%	0%	0%	33%	67%	100%	0.007	18
3a	89	63%	18%	0%	19%	0%	100%	0.007	25
3b	109	0%	21%	0%	19%	60%	100%	0.007	18
4	141	31%	21%	0%	18%	30%	100%	0.007	21
5	159	27%	13%	19%	13%	28%	100%	0.007	21

Blend Type2	Chloride	Fluoride	Iron	Magnesium	Manganese	Selenium	Sodium	Sulfate
2a	52	0.4	0.061	10	0.013	0.004	87	15
2b	42	0.4	0.061	10	0.014	0.003	80	15
2c	89	0.5	0.049	8	0.010	0.004	126	13
2d	87	0.5	0.045	8	0.011	0.003	127	13
3a	46	0.4	0.060	10	0.014	0.003	83	15
3b	87	0.5	0.046	8	0.010	0.004	125	13
4	67	0.5	0.053	9	0.012	0.003	104	14
5	69	0.5	0.053	9	0.012	0.004	106	14

Blend Type3	Total Alkalinity	Total Hardness	Dissolved Inorganic Carbon	Total Dissolved Solids	CSMR
2a	266	99	545	345	3.6
2b	268	103	552	327	2.9
2c	268	77	547	410	6.6
2d	270	75	552	404	6.5
3a	267	100	548	334	3.2
3b	269	76	549	405	6.5
4	266	87	545	369	4.8
5	266	88	544	374	4.9

Blend Type4	EP001 Flow	EP003 Flow	EP002 Flow	EP004 Flow	EP005 Flow	Total Blended Flow	Total Flow	Used
2a	1360	1050	0	0	0	2410	4720	Y
2b	1360	0	0	583	0	1943	4253	Y
2c	0	1050	0	0	1300	2350	4720	Y
2d	0	0	0	640	1300	1940	4310	Y
3a	1360	389	0	410	0	2159	4469	Y
3b	0	455	0	412	1300	2167	4537	Y
4	1322	910	0	780	1300	4333	5382	Y
5	1254	604	882	604	1300	4643	4877	Y

Source Water Quality Data

Parameter	EP001	EP003	EP002	EP004	EP005	MCL/SMCL	Units
Arsenic	0.0053	0.009	0.0077	0.0125	0.005		0.01 mg/L
Calcium	30.3	16.2	18.4	13.7	20.8	--	mg/L
Chloride	40	67	72	47	106		300 mg/L
Fluoride	0.37	0.47	0.38	0.42	0.61		2 mg/L
Iron	0.075	0.044	0.047	0.028	0.053		0.3 mg/L
Magnesium	12.2	6.55	7.92	5.53	8.57	--	mg/L
Manganese	0.017	0.0087	0.011	0.0081	0.0118		0.05 mg/L
Selenium	0.003	0.0051	0.0066	0.0034	0.003		0.05 mg/L
Sodium	71.7	107	107	98.2	140.5	--	mg/L
Sulfate	15	14	14	14	13		300 mg/L
Total Alkalinity	278	251	251	246	282	--	mg/L as CaCO3
Total Hardness	123	67.4	78.6	57	84.4	--	mg/L as CaCO3
Total Dissolve	325	372	377	330	440		1000 mg/L
CSMR	2.7	4.8	5.1	3.4	8.2		0
pH	7.8	7.9	8	7.8	7.9	≥ 7.0	S.U.
DI C	571	512	509	506	575	--	mg/L as CaCO3

Treatment Needed to Achieve 0.007 mg/L As

EP	Percent Treated	Percent Untreated	Blended Water As (m
EP003	31%	69%	0.00652
EP004	50%	50%	0.00675

Equilibrium Calculations

Chemical Species	Start	
H2O	1 mM	
[H+]	1.13243E-08 mM	7.945989
[OH-]	mM	3.16228E-09
[CO32-]	mM	
[Na+]	0 mM	
Kw	1E-14 mM	
Ka1	5.01187E-07 mM	
Ka2	5.01187E-11 mM	

Used solver to perform iterations to adjust [H+] so that the Alk = column matches the formula column

Equil			
[OH-] = Kw/[H+]	α_0	$[H+]^2/([H+]^2+[H+][Ka1+Ka1Ka2])$	
[H2CO3*]=[H+][HCO3-]/Ka1	α_1	$[H+][Ka1]/([H+]^2+[H+][Ka1+Ka1Ka2])$	
[CO32-]=Ka2[HCO3-]/[H+]	α_2	$Ka1Ka2/([H+]^2+[H+][Ka1+Ka1Ka2])$	
MB			
Ct = [H2CO3*]+[HCO3-]+[CO32-]	α_0		0.022
	α_1		0.974
CB			
[H+]+[Na+]=[OH-]+[HCO3-]+2[CO32-]	α_2		0.004

Iteration for [H+]

PC	
[H+]=[OH-]+[HCO3-]+2[CO32-]	
Get species in terms of [H+]	
[OH-]	8.83057E-07
Solve for [H+]	0 8.71733E-07
pH	7.945988661

Blend	Alk =	($\alpha_1+2\alpha_2$)CT + [OH-]-[H+]
2a	5.32	5.36
2b	5.25	5.30
2b	5.37	5.42
2c	5.36	5.37
2d	5.40	5.42
2d	5.29	5.32
3a	5.34	5.38
3a	5.19	5.22
3b	5.37	5.39
3b	5.21	5.23
3c	5.26	5.26
4	5.33	5.36
4	5.31	5.34
5	5.33	5.35
5	5.26	5.28

Results recorded here

Results from RTW Model recorded here

Calcium (mg/L)

Blend Type	Blend	Dissolved Inorganic Carbon (mg/L as CaCO ₃)		Total Alkalinity meq/L	DIC (mM)	pH	Dissolved Solids				LSI	RI	AI	CCPP (mg/L as CaCO ₃)	
		Total Alkalinity (mg/L as CaCO ₃)	Carbon (mg/L as CaCO ₃)				Calcium (mg/L as CaCO ₃)	Solids (mg/L)	Chloride (mg/L)	Sulfate (mg/L)					
24	2a	16	266	545	5.32	5.45	7.8	60	345	52	15	0.34	7.2	12.1	10.3
22	2b	34	263	540	5.25	5.40	7.8	56	327	43	15	0.18	7.4	12.0	5.7
25	2b	38	268	552	5.37	5.52	7.8	63	327	42	15	0.25	7.3	12.0	8.3
19	2c	54	268	547	5.36	5.47	7.9	47	410	89	13	0.32	7.4	12.1	8.2
18	2d	68	270	552	5.40	5.52	7.9	46	404	87	13	0.20	7.5	12.0	5.3
17	2d	82	264	541	5.29	5.41	7.9	43	386	77	13	0.17	7.6	12.0	4.2
25	3a	89	267	548	5.34	5.48	7.8	62	334	46	15	0.44	7.1	12.2	12.4
21	3a	102	259	532	5.19	5.32	7.8	51	340	50	14	0.25	7.4	12.0	7.0
18	3b	109	269	549	5.37	5.49	7.9	46	405	87	13	0.21	7.5	12.0	5.6
17	3b	114	260	533	5.21	5.33	7.9	42	382	74	14	0.17	7.6	12.0	4.2
19	3c	128	263	535	5.26	5.35	7.9	47	400	84	14	#REF!	#REF!	#REF!	#REF!
21	4	141	266	545	5.33	5.45	7.9	53	369	67	14	0.27	7.4	12.1	7.7
21	4	154	265	543	5.31	5.43	7.9	52	366	65	14	0.26	7.4	12.0	7.2
21	5	159	266	544	5.33	5.44	7.9	53	374	69	14	0.26	7.4	12.1	7.3
20	5	162	263	537	5.26	5.37	7.9	51	368	66	14	0.23	7.4	12.0	6.4

RTW Model

4th Street & Avenue B (EP001)

The RTW Model Ver. 4.0 ID: EP001

STEP 1: Enter initial water characteristics.

Measured TDS	325	mg/L
Measured temperature	20	deg C
Measured pH	7.8	
Measured alk, as CaCO3	278	mg/L
Measured Ca, as CaCO3	75.75	mg/L
Measured Cl	40	mg/L
Measured SO4	15	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.8	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired	
Interim alkalinity	278	mg/L	> 40	mg/L	Interim pH	7.80
Interim Ca, as CaCO3	76	mg/L	> 40	mg/L	Precipitation potential	12.69
Alk/(Cl+SO4)	5.1		> 5.0		Langelier index	0.34
						>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	293	mg/L
Initial Ca sat, as CaCO3	35	mg/L
Initial DIC, as CaCO3	571	mg/L

Theoretical interim water characteristics

Interim acidity	293	mg/L
Interim Ca sat, as CaCO3	35	mg/L
Ryznar Index	7.12	
Interim DIC, as CaCO3	571	mg/L
Aggressiveness Index	12.12	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	265	mg/L
Final Ca	63	mg/L
Final acidity	293	mg/L
Final pH	7.56	
Final DIC, as CaCO3	559	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
(H+)	1.58E-08	1.58E-08													
[DIC]	5.71E-03	5.71E-03													
[HCO3-]	5.52E-03	5.52E-03													
[CO3-]	2.1E-05	2.1E-05	-40493.37	14	-0.34	7.46	75.75	278.00	5.71E-03	1.76E-04	2.10E-05	5.52E-03	5.11E-07	1.58E-08	7.8000
[H2CO3*]	0.000176	1.76E-04	-4052.13	13	0.52	7.79	40.26	242.51	5.36E-03	5.15E-04	5.52E-06	4.84E-03	1.53E-07	5.29E-08	7.2769
[Ca++] _s	3.47E-04	3.47E-04	-405.94	12	9.79	#####	0.00	171.73	4.65E-03	1.22E-03	1.18E-06	3.43E-03	4.59E-08	1.76E-07	6.7538
pHs alk		7.46	-22.32	11	10.61	#####	0.00	87.13	3.81E-03	2.06E-03	1.79E-07	1.74E-03	1.38E-08	5.88E-07	6.2308
			120.14	10	11.56	#####	0.00	32.88	3.26E-03	2.60E-03	2.03E-08	6.60E-04	4.13E-09	1.96E-06	5.7077
			248.29	9	12.57	#####	0.00	10.40	3.04E-03	2.82E-03	1.98E-09	2.15E-04	1.24E-09	6.54E-06	5.1846
			285.67	8	13.60	#####	0.00	2.20	2.96E-03	2.89E-03	1.82E-10	6.58E-05	3.71E-10	2.18E-05	4.6615
			389.50	7	14.65	#####	0.00	-2.65	2.91E-03	2.89E-03	1.64E-11	1.97E-05	1.11E-10	7.27E-05	4.1385
			1397.84	6	15.71	#####	0.00	-11.83	2.82E-03	2.81E-03	1.43E-12	5.76E-06	3.34E-11	2.42E-04	3.6154
			11496.10	5	16.80	#####	0.00	-40.35	2.53E-03	2.53E-03	1.16E-13	1.55E-06	1.00E-11	8.09E-04	3.0923
			114272.73	4	18.05	#####	0.00	-134.80	1.59E-03	1.59E-03	6.54E-15	2.92E-07	3.00E-12	2.70E-03	2.5692
			1321474.57	3	#####	#####	0.00	-293.46	1.81E-06	1.81E-06	6.71E-109	1.00E-100	9.01E-13	8.99E-03	2.0462
			31337047.74	2	#####	#####	0.00	-293.46	6.04E-96	6.04E-96	2.01E-109	1.00E-100	2.70E-13	3.00E-02	1.5231
			2125848253.25	1	#####	#####	0.00	-293.46	2.01E-95	2.01E-95	6.03E-110	1.00E-100	8.10E-14	1.00E-01	1.0000
			285.67	8	-0.34	7.46	75.75	278.00	5.71E-03	1.76E-04	2.10E-05	5.52E-03	5.11E-07	1.58E-08	7.8000
			289.26	7.9	-0.20	7.50	71.06	273.31	5.67E-03	2.18E-04	1.64E-05	5.43E-03	4.06E-07	2.00E-08	7.7000
			293.46	7.8	-0.06	7.54	65.56	267.81	5.61E-03	2.70E-04	1.28E-05	5.33E-03	3.22E-07	2.51E-08	7.6000
			298.50	7.7	0.09	7.59	59.07	261.32	5.55E-03	3.32E-04	9.93E-06	5.21E-03	2.56E-07	3.16E-08	7.5000
			304.63	7.6	0.27	7.67	51.44	253.69	5.47E-03	4.06E-04	7.67E-06	5.06E-03	2.03E-07	3.98E-08	7.4000
			312.19	7.5	0.46	7.76	42.52	244.77	5.38E-03	4.93E-04	5.88E-06	4.88E-03	1.62E-07	5.01E-08	7.3000
			321.58	7.4	0.70	7.90	32.20	234.45	5.28E-03	5.95E-04	4.48E-06	4.68E-03	1.28E-07	6.31E-08	7.2000
			333.30	7.3	1.02	8.12	20.42	222.67	5.16E-03	7.11E-04	3.38E-06	4.45E-03	1.02E-07	7.94E-08	7.1000
			347.98	7.2	1.60	8.60	7.20	209.45	5.03E-03	8.43E-04	2.52E-06	4.18E-03	8.10E-08	1.00E-07	7.0000
			366.38	7.1	9.59	#####	0.00	194.91	4.88E-03	9.87E-04	1.87E-06	3.89E-03	6.43E-08	1.26E-07	6.9000
			389.50	7	9.73	#####	0.00	179.25	4.73E-03	1.14E-03	1.36E-06	3.58E-03	5.11E-08	1.58E-07	6.8000
			293.46	7.8	-0.06	7.54	65.56	267.81	5.61E-03	2.70E-04	1.28E-05	5.33E-03	3.22E-07	2.51E-08	7.6000
			293.92	7.79	-0.05	7.54	64.96	267.21	5.61E-03	2.75E-04	1.25E-05	5.32E-03	3.15E-07	2.57E-08	7.5900
			294.39	7.78	-0.03	7.55	64.34	266.59	5.60E-03	2.81E-04	1.22E-05	5.31E-03	3.08E-07	2.63E-08	7.5800
			294.87	7.77	-0.02	7.55	63.72	265.97	5.59E-03	2.87E-04	1.19E-05	5.30E-03	3.01E-07	2.69E-08	7.5700
			295.36	7.76	0.00	7.56	63.09	265.34	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.75E-08	7.5600
			295.86	7.75	0.01	7.56	62.45	264.70	5.58E-03	2.99E-04	1.13E-05	5.27E-03	2.87E-07	2.82E-08	7.5500
			296.37	7.74	0.03	7.57	61.79	264.04	5.58E-03	3.05E-04	1.10E-05	5.26E-03	2.81E-07	2.88E-08	7.5400
			296.88	7.73	0.05	7.58	61.13	263.38	5.57E-03	3.12E-04	1.07E-05	5.25E-03	2.74E-07	2.95E-08	7.5300
			297.41	7.72	0.06	7.58	60.45	262.70	5.56E-03	3.18E-04	1.05E-05	5.23E-03	2.68E-07	3.02E-08	7.5200
			297.95	7.71	0.08	7.59	59.77	262.02	5.55E-03	3.25E-04	1.02E-05	5.22E-03	2.62E-07	3.09E-08	7.5100
			298.50	7.7	0.09	7.59	59.07	261.32	5.55E-03	3.32E-04	9.93E-06	5.21E-03	2.56E-07	3.16E-08	7.5000
					0.00	7.56	63.09	265.34	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.75E-08	7.5600
					0.00	7.56	63.03	265.28	5.59E-03	2.94E-04	1.15E-05	5.28E-03	2.93E-07	2.76E-08	7.5590
					0.00	7.56	62.96	265.21	5.59E-03	2.94E-04	1.15E-05	5.28E-03	2.93E-07	2.77E-08	7.5580
					0.00	7.56	62.90	265.15	5.59E-03	2.95E-04	1.15E-05	5.28E-03	2.92E-07	2.77E-08	7.5570
					0.01	7.56	62.83	265.08	5.59E-03	2.95E-04	1.15E-05	5.28E-03	2.91E-07	2.78E-08	7.5560
					0.01	7.56	62.77	265.02	5.58E-03	2.96E-04	1.14E-05	5.28E-03	2.91E-07	2.79E-08	7.5550
					0.01	7.56	62.71	264.96	5.58E-03	2.97E-04	1.14E-05	5.28E-03	2.90E-07	2.79E-08	7.5540
					0.01	7.56	62.64	264.89	5.58E-03	2.97E-04	1.14E-05	5.27E-03	2.89E-07	2.80E-08	7.5530
					0.01	7.56	62.58	264.83	5.58E-03	2.98E-04	1.13E-05	5.27E-03	2.89E-07	2.81E-08	7.5520
					0.01	7.56	62.51	264.76	5.58E-03	2.99E-04	1.13E-05	5.27E-03	2.88E-07	2.81E-08	7.5510
					0.01	7.56	62.45	264.70	5.58E-03	2.99E-04	1.13E-05	5.27E-03	2.87E-07	2.82E-08	7.5500
					0.00	7.56	63.09	265.34	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.75E-08	7.5600
					0.00	7.56	63.08	265.33	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.75E-08	7.5599
					0.00	7.56	63.08	265.33	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.76E-08	7.5598
					0.00	7.56	63.07	265.32	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.76E-08	7.5597
					0.00	7.56	63.06	265.31	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.76E-08	7.5596
					0.00	7.56	63.06	265.31	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.76E-08	7.5595
					0.00	7.56	63.05	265.30	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.76E-08	7.5594
					0.00	7.56	63.04	265.29	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.76E-08	7.5593
					0.00	7.56	63.04	265.29	5.59E-03	2.94E-04	1.16E-05	5.28E-03	2.93E-07	2.76E-08	7.5592
					0.00	7.56	63.03	265.28	5.59E-03	2.94E-04	1.15E-05	5.28E-03	2.93E-07	2.76E-08	7.5591
					0.00	7.56	63.03	265.28	5.59E-03	2.94E-04	1.15E-05	5.28E-03	2.93E-07	2.76E-08	7.5590
					0.00	7.56	63.06	265.31	5.59E-03	2.93E-04	1.16E-05	5.28E-03	2.94E-07	2.76E-08	7.5596

Tk 293
 I 0.008125
 E 80.094785
 A 0.5062483
 f(l) 0.0826856
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.9132255
 fd 0.6955241
 K1p 4.97E-07
 K2p 6.03E-11
 Kwp 8.10E-15
 Ksp 7.29E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
n	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Mockingbird Lane (EP002)

The RTW Model

Ver. 4.0

ID: EP002

STEP 1: Enter initial water characteristics.

Measured TDS	377	mg/L
Measured temperature	20	deg C
Measured pH	8	
Measured alk, as CaCO3	251	mg/L
Measured Ca, as CaCO3	45	mg/L
Measured Cl	72	mg/L
Measured SO4	14	mg/L

For CT and TTHM functions enter current:

Treated water pH	8	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics	Desired	Theoretical interim water characteristics	Desired		
Interim alkalinity	251 mg/L	> 40 mg/L	Interim pH	8.00	6.8-9.3
Interim Ca, as CaCO3	45 mg/L	> 40 mg/L	Precipitation potential	6.06 mg/L	4-10 mg/L
Alk/(Cl+SO4)	2.9	> 5.0	Langelier index	0.26	>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	258	mg/L
Initial Ca sat, as CaCO3	25	mg/L
Initial DIC, as CaCO3	509	mg/L

Theoretical interim water characteristics

Interim acidity	258	mg/L
Interim Ca sat, as CaCO3	25	mg/L
Ryznar index	7.48	
Interim DIC, as CaCO3	509	mg/L
Aggressiveness Index	12.05	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	245	mg/L
Final Ca	39	mg/L
Final acidity	258	mg/L
Final pH	7.82	
Final DIC, as CaCO3	503	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
{H+}	1.00E-08	1.00E-08													
[DIC]	5.09E-03	5.09E-03													
[HCO3-]	4.96E-03	4.96E-03													
[CO3-]	3.1E-05	3.1E-05	-40971.47	14	-0.26	7.74	45.00	251.00	5.09E-03	9.87E-05	3.06E-05	4.96E-03	8.19E-07	1.00E-08	8.0000
[H2CO3]	9.9E-05	9.87E-05	-4099.93	13	0.64	8.11	21.39	227.39	4.85E-03	3.12E-04	8.10E-06	4.53E-03	2.37E-07	3.46E-08	7.4615
[Ca++] _s	2.50E-04	2.50E-04	-410.96	12	9.63	#####	0.00	174.88	4.33E-03	8.30E-04	1.81E-06	3.49E-03	6.86E-08	1.19E-07	6.9231
pHs alk		7.74	-25.24	11	10.42	#####	0.00	97.55	3.55E-03	1.60E-03	2.92E-07	1.95E-03	1.99E-08	4.12E-07	6.3846
			106.39	10	11.36	#####	0.00	38.54	2.96E-03	2.19E-03	3.35E-08	7.72E-04	5.75E-09	1.43E-06	5.8462
			223.51	9	12.39	#####	0.00	12.25	2.70E-03	2.45E-03	3.14E-09	2.50E-04	1.66E-09	4.92E-06	5.3077
			257.72	8	13.45	#####	0.00	2.89	2.61E-03	2.53E-03	2.71E-10	7.48E-05	4.82E-10	1.70E-05	4.7692
			350.49	7	14.53	#####	0.00	-1.85	2.56E-03	2.54E-03	2.28E-11	2.17E-05	1.39E-10	5.88E-05	4.2308
			1250.30	6	15.61	#####	0.00	-9.85	2.48E-03	2.47E-03	1.86E-12	6.12E-06	4.03E-11	2.03E-04	3.6923
			10263.40	5	16.74	#####	0.00	-35.01	2.23E-03	2.23E-03	1.40E-13	1.59E-06	1.17E-11	7.02E-04	3.1538
			102167.47	4	18.03	#####	0.00	-121.21	1.37E-03	1.36E-03	7.21E-15	2.83E-07	3.38E-12	2.42E-03	2.6154
			1198549.56	3	#####	#####	0.00	-257.72	1.67E-96	1.67E-96	7.37E-109	1.00E-100	9.78E-13	8.38E-03	2.0769
			29896507.52	2	#####	#####	0.00	-257.72	5.76E-96	5.76E-96	2.13E-109	1.00E-100	2.83E-13	2.89E-02	1.5385
			2090289794.96	1	#####	#####	0.00	-257.72	1.99E-95	1.99E-95	6.18E-110	1.00E-100	8.19E-14	1.00E-01	1.0000
			257.72	8	-0.26	7.74	45.00	251.00	5.09E-03	9.87E-05	3.06E-05	4.96E-03	8.19E-07	1.00E-08	8.0000
			260.95	7.9	-0.12	7.78	41.90	247.90	5.06E-03	1.23E-04	2.41E-05	4.91E-03	6.51E-07	1.26E-08	7.9000
			264.72	7.8	0.02	7.82	38.37	244.37	5.02E-03	1.53E-04	1.89E-05	4.85E-03	5.17E-07	1.58E-08	7.8000
			269.23	7.7	0.18	7.88	34.28	240.28	4.98E-03	1.90E-04	1.48E-05	4.78E-03	4.11E-07	2.00E-08	7.7000
			274.71	7.6	0.35	7.95	29.48	235.48	4.93E-03	2.34E-04	1.15E-05	4.69E-03	3.26E-07	2.51E-08	7.6000
			281.47	7.5	0.55	8.05	23.82	229.82	4.88E-03	2.88E-04	8.94E-06	4.58E-03	2.59E-07	3.16E-08	7.5000
			289.86	7.4	0.81	8.21	17.17	223.17	4.81E-03	3.53E-04	6.90E-06	4.45E-03	2.06E-07	3.98E-08	7.4000
			300.32	7.3	1.19	8.49	9.40	215.40	4.73E-03	4.29E-04	5.30E-06	4.30E-03	1.63E-07	5.01E-08	7.3000
			313.42	7.2	2.68	9.88	0.40	206.40	4.64E-03	5.17E-04	4.03E-06	4.12E-03	1.30E-07	6.31E-08	7.2000
			329.85	7.1	9.40	#####	0.00	196.12	4.54E-03	6.19E-04	3.05E-06	3.92E-03	1.03E-07	7.94E-08	7.1000
			350.49	7	9.53	#####	0.00	184.57	4.42E-03	7.34E-04	2.28E-06	3.69E-03	8.19E-08	1.00E-07	7.0000
			257.72	8	-0.12	7.78	41.90	247.90	5.06E-03	1.23E-04	2.41E-05	4.91E-03	6.51E-07	1.26E-08	7.9000
			258.03	7.99	-0.11	7.78	41.56	247.56	5.05E-03	1.26E-04	2.35E-05	4.90E-03	6.36E-07	1.29E-08	7.8900
			258.34	7.98	-0.09	7.79	41.23	247.23	5.05E-03	1.29E-04	2.30E-05	4.90E-03	6.22E-07	1.32E-08	7.8800
			258.65	7.97	-0.08	7.79	40.89	246.89	5.05E-03	1.31E-04	2.24E-05	4.89E-03	6.07E-07	1.35E-08	7.8700
			258.96	7.96	-0.06	7.80	40.54	246.54	5.04E-03	1.34E-04	2.19E-05	4.89E-03	5.94E-07	1.38E-08	7.8600
			259.28	7.95	-0.05	7.80	40.19	246.19	5.04E-03	1.37E-04	2.13E-05	4.88E-03	5.80E-07	1.41E-08	7.8500
			259.61	7.94	-0.04	7.80	39.84	245.84	5.04E-03	1.40E-04	2.08E-05	4.87E-03	5.67E-07	1.45E-08	7.8400
			259.94	7.93	-0.02	7.81	39.48	245.48	5.03E-03	1.43E-04	2.03E-05	4.87E-03	5.54E-07	1.48E-08	7.8300
			260.27	7.92	-0.01	7.81	39.11	245.11	5.03E-03	1.46E-04	1.98E-05	4.86E-03	5.41E-07	1.51E-08	7.8200
			260.61	7.91	0.01	7.82	38.74	244.74	5.02E-03	1.50E-04	1.94E-05	4.86E-03	5.29E-07	1.55E-08	7.8100
			260.95	7.9	0.02	7.82	38.37	244.37	5.02E-03	1.53E-04	1.89E-05	4.85E-03	5.17E-07	1.58E-08	7.8000
					-0.01	7.81	39.11	245.11	5.03E-03	1.46E-04	1.98E-05	4.86E-03	5.41E-07	1.51E-08	7.8200
					-0.01	7.81	39.08	245.08	5.03E-03	1.47E-04	1.98E-05	4.86E-03	5.40E-07	1.52E-08	7.8190
					0.00	7.81	39.04	245.04	5.03E-03	1.47E-04	1.97E-05	4.86E-03	5.39E-07	1.52E-08	7.8180
					0.00	7.81	39.00	245.00	5.03E-03	1.47E-04	1.97E-05	4.86E-03	5.38E-07	1.52E-08	7.8170
					0.00	7.82	38.97	244.97	5.03E-03	1.48E-04	1.97E-05	4.86E-03	5.36E-07	1.53E-08	7.8160
					0.00	7.82	38.93	244.93	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.35E-07	1.53E-08	7.8150
					0.00	7.82	38.89	244.89	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.34E-07	1.53E-08	7.8140
					0.00	7.82	38.86	244.86	5.03E-03	1.49E-04	1.95E-05	4.86E-03	5.33E-07	1.54E-08	7.8130
					0.00	7.82	38.82	244.82	5.03E-03	1.49E-04	1.95E-05	4.86E-03	5.31E-07	1.54E-08	7.8120
					0.01	7.82	38.78	244.78	5.03E-03	1.49E-04	1.94E-05	4.86E-03	5.30E-07	1.55E-08	7.8110
					0.01	7.82	38.74	244.74	5.02E-03	1.50E-04	1.94E-05	4.86E-03	5.29E-07	1.55E-08	7.8100
					0.00	7.82	38.97	244.97	5.03E-03	1.48E-04	1.97E-05	4.86E-03	5.36E-07	1.53E-08	7.8160
					0.00	7.82	38.96	244.96	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.36E-07	1.53E-08	7.8159
					0.00	7.82	38.96	244.96	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.36E-07	1.53E-08	7.8158
					0.00	7.82	38.96	244.96	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.36E-07	1.53E-08	7.8157
					0.00	7.82	38.95	244.95	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.36E-07	1.53E-08	7.8156
					0.00	7.82	38.95	244.95	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.36E-07	1.53E-08	7.8155
					0.00	7.82	38.94	244.94	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.36E-07	1.53E-08	7.8154
					0.00	7.82	38.94	244.94	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.36E-07	1.53E-08	7.8153
					0.00	7.82	38.94	244.94	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.35E-07	1.53E-08	7.8152
					0.00	7.82	38.93	244.93	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.35E-07	1.53E-08	7.8151
					0.00	7.82	38.93	244.93	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.35E-07	1.53E-08	7.8150
					0.00	7.82	38.94	244.94	5.03E-03	1.48E-04	1.96E-05	4.86E-03	5.36E-07	1.53E-08	7.8154

Tk 293
 I 0.00943
 E 80.0948
 A 0.50625
 f(l) 0.08849
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.90788
 fd 0.67938
 K1p 5.02E-07
 K2p 6.18E-11
 Kwp 8.19E-15
 Ksp 7.64E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

6th Street & Katy (EP003)

The RTW Model Ver. 4.0 ID: EP003

STEP 1: Enter initial water characteristics.

Measured TDS	372	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	251	mg/L
Measured Ca, as CaCO3	40	mg/L
Measured Cl	67	mg/L
Measured SO4	14	mg/L

For CT and TTHM functions enter current:

Treated water pH	8	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired	
Interim alkalinity	251	mg/L	> 40	mg/L	Interim pH	7.90
Interim Ca, as CaCO3	40	mg/L	> 40	mg/L	Precipitation potential	2.60
Alk/(Cl+SO4)	3.1		> 5.0		Langelier index	0.11
						>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	261	mg/L
Initial Ca sat, as CaCO3	31	mg/L
Initial DIC, as CaCO3	512	mg/L

Theoretical interim water characteristics

Interim acidity	261	mg/L
Interim Ca sat, as CaCO3	31	mg/L
Ryznar Index	7.68	
Interim DIC, as CaCO3	512	mg/L
Aggressiveness Index	11.90	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	248	mg/L
Final Ca	37	mg/L
Final acidity	261	mg/L
Final pH	7.83	
Final DIC, as CaCO3	509	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

Tk 293
 I 0.0093
 E 80.094785
 A 0.5062483
 f(l) 0.0879545
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.9083709
 fd 0.6808521
 K1p 5.02E-07
 K2p 6.16E-11
 Kwp 8.18E-15
 Ksp 7.61E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

6th Street & Avenue I (EP004)

The RTW Model Ver. 4.0 ID: EP004

STEP 1: Enter initial water characteristics.

Measured TDS	330	mg/L
Measured temperature	20	deg C
Measured pH	7.8	
Measured alk, as CaCO3	246	mg/L
Measured Ca, as CaCO3	35	mg/L
Measured Cl	47	mg/L
Measured SO4	14	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.8	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics			Desired		
Interim alkalinity	246	mg/L	> 40	mg/L	
Interim Ca, as CaCO3	35	mg/L	> 40	mg/L	
Alk/(Cl+SO4)	4.0		> 5.0		
Theoretical interim water characteristics			Desired		
Interim pH	7.80		6.8-9.3		
Precipitation potential	-1.25	mg/L	4-10	mg/L	
Langelier index	-0.05		>0		

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	260	mg/L
Initial Ca sat, as CaCO3	39	mg/L
Initial DIC, as CaCO3	506	mg/L

Theoretical interim water characteristics

Interim acidity	260	mg/L
Interim Ca sat, as CaCO3	39	mg/L
Ryznar index	7.89	
Interim DIC, as CaCO3	506	mg/L
Aggressiveness Index	11.74	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	N/A	mg/L
Final Ca	N/A	mg/L
Final acidity	N/A	mg/L
Final pH	N/A	
Final DIC, as CaCO3	N/A	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Accd, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final {OH-}	Final {H+}	Final pH
{H+}	1.58E-08	1.58E-08													
[DIC]	5.06E-03	5.06E-03													
[HCO3-]	4.88E-03	4.88E-03													
[CO3-]	1.9E-05	1.9E-05	-40541.24	14	-15.52	-1.52	493614471.84	493614682.84	4.94E+03	1.64E-08	4.94E+03	8.16E-01	8.11E-01	1.00E-14	14.0000
[H2CO3]	0.00016	1.56E-04	-4056.94	13	-13.63	-0.10	55612358.05	55612569.05	5.56E+02	1.66E-08	5.56E+02	2.76E-01	2.70E-01	3.00E-14	13.5231
[Ca++]s	3.93E-04	3.93E-04	-406.69	12	-11.75	1.30	6423673.18	6423884.18	6.42E+01	1.72E-08	6.41E+01	9.54E-02	9.02E-02	8.99E-14	13.0462
pHs alk		7.85	-24.85	11	-9.93	2.64	794085.03	794296.03	7.95E+00	1.91E-08	7.91E+00	3.53E-02	3.01E-02	2.70E-13	12.5692
			105.48	10	-8.25	3.84	114917.06	115128.06	1.15E+00	2.48E-08	1.14E+00	1.52E-02	1.00E-02	8.09E-13	12.0923
			219.57	9	-6.80	4.82	21681.29	21892.29	2.22E-01	4.16E-08	2.13E-01	8.54E-03	3.34E-03	2.42E-12	11.6154
			252.76	8	-5.59	5.55	5408.35	5619.35	5.88E-02	9.22E-08	5.25E-02	6.31E-03	1.12E-03	7.27E-12	11.1385
			344.55	7	-4.54	6.13	1629.70	1840.70	2.10E-02	2.44E-07	1.54E-02	5.56E-03	3.72E-04	2.18E-11	10.6615
			1235.80	6	-3.57	6.62	552.83	763.83	1.02E-02	6.99E-07	4.92E-03	5.32E-03	1.24E-04	6.54E-11	10.1846
			10163.52	5	-2.67	7.03	213.97	424.97	6.85E-03	2.06E-06	1.61E-03	5.23E-03	4.14E-05	1.96E-10	9.7077
			101232.62	4	-1.88	7.36	102.87	313.87	5.74E-03	6.14E-06	5.35E-04	5.19E-03	1.38E-05	5.88E-10	9.2308
			1191147.35	3	-1.20	7.56	64.99	275.99	5.36E-03	1.83E-05	1.77E-04	5.16E-03	4.60E-06	1.76E-09	8.7538
			30012661.70	2	-0.59	7.68	49.22	260.22	5.20E-03	5.41E-05	5.82E-05	5.09E-03	1.53E-06	5.29E-09	8.2769
			2110464515.14	1	0.05	7.85	35.00	246.00	5.06E-03	1.56E-04	1.86E-05	4.88E-03	5.12E-07	1.58E-08	7.8000
			252.76	8	-0.59	7.68	49.22	260.22	5.20E-03	5.41E-05	5.82E-05	5.09E-03	1.53E-06	5.29E-09	8.2769
			255.93	7.9	-0.47	7.71	46.60	257.60	5.17E-03	6.77E-05	4.60E-05	5.06E-03	1.22E-06	6.65E-09	8.1769
			259.65	7.8	-0.34	7.74	43.91	254.91	5.15E-03	8.47E-05	3.63E-05	5.02E-03	9.68E-07	8.38E-09	8.0769
			264.10	7.7	-0.20	7.77	41.02	252.02	5.12E-03	1.06E-04	2.86E-05	4.98E-03	7.69E-07	1.05E-08	7.9769
			269.53	7.6	-0.06	7.81	37.79	248.79	5.08E-03	1.32E-04	2.25E-05	4.93E-03	6.11E-07	1.33E-08	7.8769
			276.21	7.5	0.09	7.86	34.10	245.10	5.05E-03	1.64E-04	1.76E-05	4.87E-03	4.85E-07	1.67E-08	7.7769
			284.52	7.4	0.25	7.93	29.80	240.80	5.00E-03	2.03E-04	1.38E-05	4.79E-03	3.85E-07	2.10E-08	7.6769
			294.88	7.3	0.44	8.02	24.74	235.74	4.95E-03	2.50E-04	1.07E-05	4.69E-03	3.06E-07	2.65E-08	7.5769
			307.85	7.2	0.67	8.15	18.79	229.79	4.89E-03	3.07E-04	8.31E-06	4.58E-03	2.43E-07	3.33E-08	7.4769
			324.11	7.1	0.99	8.36	11.79	222.79	4.82E-03	3.75E-04	6.40E-06	4.44E-03	1.93E-07	4.20E-08	7.3769
			344.55	7	1.62	8.89	3.62	214.62	4.74E-03	4.55E-04	4.90E-06	4.28E-03	1.53E-07	5.29E-08	7.2769
			259.65	7.8	-0.06	7.81	37.79	248.79	5.08E-03	1.32E-04	2.25E-05	4.93E-03	6.11E-07	1.33E-08	7.8769
			260.06	7.79	-0.05	7.82	37.45	248.45	5.08E-03	1.35E-04	2.19E-05	4.92E-03	5.97E-07	1.36E-08	7.8669
			260.48	7.78	-0.03	7.82	37.09	248.09	5.08E-03	1.38E-04	2.14E-05	4.92E-03	5.83E-07	1.39E-08	7.8569
			260.90	7.77	-0.02	7.83	36.74	247.74	5.07E-03	1.41E-04	2.09E-05	4.91E-03	5.70E-07	1.42E-08	7.8469
			261.33	7.76	-0.01	7.83	36.38	247.38	5.07E-03	1.44E-04	2.04E-05	4.91E-03	5.57E-07	1.46E-08	7.8369
			261.77	7.75	0.01	7.84	36.01	247.01	5.07E-03	1.47E-04	1.99E-05	4.90E-03	5.44E-07	1.49E-08	7.8269
			262.22	7.74	0.02	7.84	35.64	246.64	5.06E-03	1.50E-04	1.94E-05	4.89E-03	5.32E-07	1.52E-08	7.8169
			262.68	7.73	0.04	7.85	35.26	246.26	5.06E-03	1.53E-04	1.89E-05	4.89E-03	5.20E-07	1.56E-08	7.8069
			263.14	7.72	0.06	7.85	34.88	245.88	5.06E-03	1.57E-04	1.85E-05	4.88E-03	5.08E-07	1.60E-08	7.7969
			263.62	7.71	0.07	7.86	34.49	245.49	5.05E-03	1.60E-04	1.80E-05	4.87E-03	4.96E-07	1.63E-08	7.7869
			264.10	7.7	0.09	7.86	34.10	245.10	5.05E-03	1.64E-04	1.76E-05	4.87E-03	4.85E-07	1.67E-08	7.7769
					-0.01	7.83	36.38	247.38	5.07E-03	1.44E-04	2.04E-05	4.91E-03	5.57E-07	1.46E-08	7.8369
					0.00	7.83	36.34	247.34	5.07E-03	1.44E-04	2.03E-05	4.91E-03	5.56E-07	1.46E-08	7.8359
					0.00	7.83	36.31	247.31	5.07E-03	1.44E-04	2.03E-05	4.90E-03	5.54E-07	1.46E-08	7.8349
					0.00	7.83	36.27	247.27	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.53E-07	1.47E-08	7.8339
					0.00	7.83	36.23	247.23	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.52E-07	1.47E-08	7.8329
					0.00	7.83	36.20	247.20	5.07E-03	1.45E-04	2.01E-05	4.90E-03	5.51E-07	1.47E-08	7.8319
					0.00	7.83	36.16	247.16	5.07E-03	1.46E-04	2.01E-05	4.90E-03	5.49E-07	1.48E-08	7.8309
					0.01	7.84	36.12	247.12	5.07E-03	1.46E-04	2.00E-05	4.90E-03	5.48E-07	1.48E-08	7.8299
					0.01	7.84	36.09	247.09	5.07E-03	1.46E-04	2.00E-05	4.90E-03	5.47E-07	1.48E-08	7.8289
					0.01	7.84	36.05	247.05	5.07E-03	1.47E-04	1.99E-05	4.90E-03	5.46E-07	1.49E-08	7.8279
					0.01	7.84	36.01	247.01	5.07E-03	1.47E-04	1.99E-05	4.90E-03	5.44E-07	1.49E-08	7.8269
					0.00	7.83	36.27	247.27	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.53E-07	1.47E-08	7.8339
					0.00	7.83	36.27	247.27	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.53E-07	1.47E-08	7.8338
					0.00	7.83	36.26	247.26	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.53E-07	1.47E-08	7.8337
					0.00	7.83	36.26	247.26	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.53E-07	1.47E-08	7.8336
					0.00	7.83	36.25	247.25	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.53E-07	1.47E-08	7.8335
					0.00	7.83	36.25	247.25	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.52E-07	1.47E-08	7.8334
					0.00	7.83	36.25	247.25	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.52E-07	1.47E-08	7.8333
					0.00	7.83	36.24	247.24	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.52E-07	1.47E-08	7.8332
					0.00	7.83	36.24	247.24	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.52E-07	1.47E-08	7.8331
					0.00	7.83	36.24	247.24	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.52E-07	1.47E-08	7.8330
					0.00	7.83	36.23	247.23	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.52E-07	1.47E-08	7.8329
					0.00	7.83	36.25	247.25	5.07E-03	1.45E-04	2.02E-05	4.90E-03	5.52E-07	1.47E-08	7.8334

Tk 293
 I 0.00825
 E 80.0948
 A 0.50625
 f(l) 0.08327
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.91269
 fd 0.69388
 K1p 4.97E-07
 K2p 6.05E-11
 Kwp 8.11E-15
 Ksp 7.33E-09

		Forms of CaCO ₃ and their solubility product constants			
Form #	1	2	3	4	
Preferred	Calcite	Aragonite	Vaterite	General	
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09	

Coagulant	no. of waters of hydrations	
Aluminum Sulfate	14	Enter 14 or 18
Ferric sulfate	9	Enter 9,5,3 or 0
Ferric Chloride	0	Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Grace Street & Moore Avenue (EP005)

The RTW Model Ver. 4.0 ID: EP005

STEP 1: Enter initial water characteristics.

Measured TDS	440	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	282	mg/L
Measured Ca, as CaCO3	52.5	mg/L
Measured Cl	106	mg/L
Measured SO4	13	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired			
Interim alkalinity	282	mg/L	> 40	mg/L	Interim pH	7.90	6.8-9.3	
Interim Ca, as CaCO3	53	mg/L	> 40	mg/L	Precipitation potential	7.77	mg/L	4-10
Alk/(Cl+SO4)	2.4		> 5.0		Langelier index	0.27		>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	293	mg/L
Initial Ca sat, as CaCO3	29	mg/L
Initial DIC, as CaCO3	575	mg/L

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	274	mg/L
Final Ca	45	mg/L
Final acidity	293	mg/L
Final pH	7.72	
Final DIC, as CaCO3	567	mg/L

Theoretical interim water characteristics

Interim acidity	293	mg/L
Interim Ca sat, as CaCO3	29	mg/L
Ryznar Index	7.36	
Interim DIC, as CaCO3	575	mg/L
Aggressiveness Index	12.07	

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca	Final Alk	[DIC]	Final [H2CO3*]	Final [CO3-]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
							mg CaCO3/L	mg CaCO3/L							
(H+)	1.26E-08	1.26E-08													
[DIC]	5.75E-03	5.75E-03													
[HCO3-]	5.58E-03	5.58E-03													
[CO3-]	2.81E-05	2.81E-05	-41500.15	14	-0.26	7.64	52.50	282.00	5.75E-03	1.38E-04	2.81E-05	5.58E-03	6.59E-07	1.26E-08	7.9000
[H2CO3*]	0.000138	1.38E-04	-4152.74	13	0.69	8.06	22.07	251.57	5.45E-03	4.21E-04	7.44E-06	5.02E-03	1.94E-07	4.27E-08	7.3692
[Ca++] _s	2.86E-04	2.86E-04	-416.01	12	9.69	#####	0.00	186.73	4.80E-03	1.06E-03	1.63E-06	3.73E-03	5.72E-08	1.45E-07	6.8385
pHs alk		7.63	-23.91	11	10.50	#####	0.00	99.80	3.93E-03	1.93E-03	2.57E-07	2.00E-03	1.69E-08	4.92E-07	6.3077
			118.43	10	11.44	#####	0.00	38.61	3.32E-03	2.54E-03	2.93E-08	7.74E-04	4.97E-09	1.67E-06	5.7769
			250.47	9	12.46	#####	0.00	12.28	3.05E-03	2.80E-03	2.81E-09	2.51E-04	1.46E-09	5.67E-06	5.2462
			289.33	8	13.51	#####	0.00	2.84	2.96E-03	2.88E-03	2.51E-10	7.61E-05	4.31E-10	1.93E-05	4.7154
			392.33	7	14.57	#####	0.00	-2.15	2.91E-03	2.89E-03	2.18E-11	2.25E-05	1.27E-10	6.54E-05	4.1846
			1390.38	6	15.64	#####	0.00	-10.77	2.82E-03	2.82E-03	1.84E-12	6.46E-06	3.74E-11	2.22E-04	3.6538
			11385.12	5	16.74	#####	0.00	-37.57	2.55E-03	2.55E-03	1.45E-13	1.72E-06	1.10E-11	7.53E-04	3.1231
			113083.07	4	17.99	#####	0.00	-127.82	1.65E-03	1.65E-03	8.15E-15	3.29E-07	3.25E-12	2.56E-03	2.5923
			1305144.28	3	#####	#####	0.00	-292.94	1.71E-96	1.71E-96	7.30E-109	1.00E-100	9.56E-13	8.68E-03	2.0615
			30733939.27	2	#####	#####	0.00	-292.94	5.79E-96	5.79E-96	2.15E-109	1.00E-100	2.82E-13	2.95E-02	1.5308
			2075840174.18	1	#####	#####	0.00	-292.94	1.97E-95	1.97E-95	6.34E-110	1.00E-100	8.30E-14	1.00E-01	1.0000
			289.33	8	-0.26	7.64	52.50	282.00	5.75E-03	1.38E-04	2.81E-05	5.58E-03	6.59E-07	1.26E-08	7.9000
			292.94	7.9	-0.12	7.68	48.51	278.01	5.71E-03	1.72E-04	2.21E-05	5.52E-03	5.24E-07	1.58E-08	7.8000
			297.14	7.8	0.03	7.73	43.90	273.40	5.66E-03	2.13E-04	1.73E-05	5.43E-03	4.16E-07	2.00E-08	7.7000
			302.15	7.7	0.19	7.79	38.49	267.99	5.61E-03	2.63E-04	1.35E-05	5.33E-03	3.30E-07	2.51E-08	7.6000
			308.25	7.6	0.38	7.88	32.12	261.62	5.55E-03	3.24E-04	1.04E-05	5.21E-03	2.62E-07	3.16E-08	7.5000
			315.76	7.5	0.61	8.01	24.63	254.13	5.47E-03	3.96E-04	8.07E-06	5.07E-03	2.08E-07	3.98E-08	7.4000
			325.07	7.4	0.91	8.21	15.86	245.36	5.38E-03	4.82E-04	6.19E-06	4.89E-03	1.66E-07	5.01E-08	7.3000
			336.68	7.3	1.48	8.68	5.71	235.21	5.28E-03	5.82E-04	4.72E-06	4.69E-03	1.32E-07	6.31E-08	7.2000
			351.21	7.2	9.35	#####	0.00	223.60	5.17E-03	6.97E-04	3.56E-06	4.46E-03	1.04E-07	7.94E-08	7.1000
			369.44	7.1	9.48	#####	0.00	210.56	5.03E-03	8.26E-04	2.67E-06	4.21E-03	8.30E-08	1.00E-07	7.0000
			392.33	7	9.61	#####	0.00	196.17	4.89E-03	9.70E-04	1.97E-06	3.92E-03	6.59E-08	1.26E-07	6.9000
			292.94	7.9	-0.12	7.68	48.51	278.01	5.71E-03	1.72E-04	2.21E-05	5.52E-03	5.24E-07	1.58E-08	7.8000
			293.33	7.89	-0.11	7.68	48.08	277.58	5.71E-03	1.76E-04	2.15E-05	5.51E-03	5.12E-07	1.62E-08	7.7900
			293.72	7.88	-0.09	7.69	47.65	277.15	5.70E-03	1.79E-04	2.10E-05	5.50E-03	5.00E-07	1.66E-08	7.7800
			294.12	7.87	-0.08	7.69	47.20	276.70	5.70E-03	1.83E-04	2.05E-05	5.49E-03	4.89E-07	1.70E-08	7.7700
			294.53	7.86	-0.07	7.69	46.75	276.25	5.69E-03	1.87E-04	2.00E-05	5.48E-03	4.78E-07	1.74E-08	7.7600
			294.95	7.85	-0.05	7.70	46.30	275.80	5.69E-03	1.91E-04	1.95E-05	5.48E-03	4.67E-07	1.78E-08	7.7500
			295.37	7.84	-0.04	7.70	45.83	275.33	5.68E-03	1.96E-04	1.90E-05	5.47E-03	4.56E-07	1.82E-08	7.7400
			295.80	7.83	-0.02	7.71	45.36	274.86	5.68E-03	2.00E-04	1.86E-05	5.46E-03	4.46E-07	1.86E-08	7.7300
			296.24	7.82	-0.01	7.71	44.88	274.38	5.67E-03	2.04E-04	1.81E-05	5.45E-03	4.36E-07	1.91E-08	7.7200
			296.68	7.81	0.01	7.72	44.39	273.89	5.67E-03	2.09E-04	1.77E-05	5.44E-03	4.26E-07	1.95E-08	7.7100
			297.14	7.8	0.03	7.73	43.90	273.40	5.66E-03	2.13E-04	1.73E-05	5.43E-03	4.16E-07	2.00E-08	7.7000
					-0.01	7.71	44.88	274.38	5.67E-03	2.04E-04	1.81E-05	5.45E-03	4.36E-07	1.91E-08	7.7200
					0.00	7.72	44.83	274.33	5.67E-03	2.05E-04	1.81E-05	5.45E-03	4.35E-07	1.91E-08	7.7190
					0.00	7.72	44.78	274.28	5.67E-03	2.05E-04	1.80E-05	5.45E-03	4.34E-07	1.91E-08	7.7180
					0.00	7.72	44.74	274.24	5.67E-03	2.05E-04	1.80E-05	5.45E-03	4.33E-07	1.92E-08	7.7170
					0.00	7.72	44.69	274.19	5.67E-03	2.06E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7160
					0.00	7.72	44.64	274.14	5.67E-03	2.06E-04	1.79E-05	5.45E-03	4.31E-07	1.93E-08	7.7150
					0.00	7.72	44.59	274.09	5.67E-03	2.07E-04	1.79E-05	5.45E-03	4.30E-07	1.93E-08	7.7140
					0.01	7.72	44.54	274.04	5.67E-03	2.07E-04	1.78E-05	5.44E-03	4.29E-07	1.94E-08	7.7130
					0.01	7.72	44.49	273.99	5.67E-03	2.08E-04	1.78E-05	5.44E-03	4.28E-07	1.94E-08	7.7120
					0.01	7.72	44.44	273.94	5.67E-03	2.08E-04	1.77E-05	5.44E-03	4.27E-07	1.95E-08	7.7110
					0.01	7.72	44.39	273.89	5.67E-03	2.09E-04	1.77E-05	5.44E-03	4.26E-07	1.95E-08	7.7100
					0.00	7.72	44.74	274.24	5.67E-03	2.05E-04	1.80E-05	5.45E-03	4.33E-07	1.92E-08	7.7170
					0.00	7.72	44.73	274.23	5.67E-03	2.05E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7169
					0.00	7.72	44.73	274.23	5.67E-03	2.05E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7168
					0.00	7.72	44.72	274.22	5.67E-03	2.06E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7167
					0.00	7.72	44.72	274.22	5.67E-03	2.06E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7166
					0.00	7.72	44.71	274.21	5.67E-03	2.06E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7165
					0.00	7.72	44.71	274.21	5.67E-03	2.06E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7164
					0.00	7.72	44.70	274.20	5.67E-03	2.06E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7163
					0.00	7.72	44.70	274.20	5.67E-03	2.06E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7162
					0.00	7.72	44.69	274.19	5.67E-03	2.06E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7161
					0.00	7.72	44.69	274.19	5.67E-03	2.06E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7160
					0.00	7.72	44.73	274.23	5.67E-03	2.05E-04	1.80E-05	5.45E-03	4.32E-07	1.92E-08	7.7168

Tk 293
 I 0.011
 E 80.0948
 A 0.50625
 f(l) 0.09493
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.90208
 fd 0.66218
 K1p 5.09E-07
 K2p 6.34E-11
 Kwp 8.30E-15
 Ksp 8.04E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 2a: EP001 & EP003

The RTW Model Ver. 4.0 ID: **Blend 2a**

STEP 1: Enter initial water characteristics.

Measured TDS	347	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	266.49	mg/L
Measured Ca, as CaCO3	63.072	mg/L
Measured Cl	53.637	mg/L
Measured SO4	14.574	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired			
Interim alkalinity	266	mg/L	> 40	mg/L	Interim pH	7.90	6.8-9.3	
Interim Ca, as CaCO3	63	mg/L	> 40	mg/L	Precipitation potential	10.33	mg/L	4-10
Alk/(Cl+SO4)	3.9		> 5.0		Langelier index	0.34		>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	277	mg/L
Initial Ca sat, as CaCO3	29	mg/L
Initial DIC, as CaCO3	544	mg/L

Theoretical interim water characteristics

Interim acidity	277	mg/L
Interim Ca sat, as CaCO3	29	mg/L
Ryznar Index	7.22	
Interim DIC, as CaCO3	544	mg/L
Aggressiveness Index	12.13	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	256	mg/L
Final Ca	53	mg/L
Final acidity	277	mg/L
Final pH	7.66	
Final DIC, as CaCO3	533	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

Initial	Interim	Interim	Interim	Delta	Final	Final	Final	Final	Final	Final	Final	Final	Final	Final	Final
(H+)	1.26E-08	1.26E-08	Acid, mg/l	pH	pH	Ca	Alk	[DIC]	[H2CO3*]	[CO3--]	[HCO3-]	{OH-}	{H+}	pH	
[DIC]	5.44E-03	5.44E-03				mg CaCO3/L	mg CaCO3/L								
[HCO3-]	5.28E-03	5.28E-03													
[CO3-]	2.56E-05	2.56E-05	-40700.83	14	-0.34	7.56	63.07	266.49	5.44E-03	1.33E-04	2.56E-05	5.28E-03	6.47E-07	1.26E-08	7.9000
[H2CO3*]	0.000133	1.33E-04	-4072.87	13	0.51	7.88	33.93	237.35	5.15E-03	4.05E-04	6.75E-06	4.73E-03	1.90E-07	4.27E-08	7.3692
[Ca++] _s	2.91E-04	2.91E-04	-408.12	12	9.70	####	0.00	175.43	4.53E-03	1.02E-03	1.47E-06	3.51E-03	5.61E-08	1.45E-07	6.8385
pHs alk		7.56	-23.58	11	10.51	####	0.00	93.22	3.70E-03	1.84E-03	2.31E-07	1.86E-03	1.65E-08	4.92E-07	6.3077
			114.23	10	11.45	####	0.00	35.92	3.13E-03	2.41E-03	2.63E-08	7.20E-04	4.87E-09	1.67E-06	5.7769
			237.71	9	12.47	####	0.00	11.38	2.89E-03	2.65E-03	2.51E-09	2.33E-04	1.43E-09	5.67E-06	5.2462
			273.75	8	13.52	####	0.00	2.57	2.80E-03	2.73E-03	2.24E-10	7.07E-05	4.23E-10	1.93E-05	4.7154
			372.83	7	14.58	####	0.00	-2.23	2.75E-03	2.73E-03	1.94E-11	2.08E-05	1.25E-10	6.54E-05	4.1846
			1334.52	6	15.66	####	0.00	-10.80	2.66E-03	2.66E-03	1.64E-12	5.98E-06	3.67E-11	2.22E-04	3.6538
			10966.33	5	16.76	####	0.00	-37.58	2.40E-03	2.39E-03	1.28E-13	1.59E-06	1.08E-11	7.53E-04	3.1231
			109069.32	4	18.03	####	0.00	-127.82	1.49E-03	1.49E-03	6.95E-15	2.92E-07	3.18E-12	2.56E-03	2.5923
			1268619.97	3	#####	####	0.00	-277.19	1.74E-06	1.74E-06	7.02E-109	1.00E-100	9.38E-13	8.68E-03	2.0615
			30716205.21	2	#####	####	0.00	-277.19	5.90E-06	5.90E-06	2.07E-109	1.00E-100	2.76E-13	2.95E-02	1.5308
			2110399931.85	1	#####	####	0.00	-277.19	2.00E-095	2.00E-095	6.10E-110	1.00E-100	8.14E-14	1.00E-01	1.0000
			273.75	8	-0.34	7.56	63.07	266.49	5.44E-03	1.33E-04	2.56E-05	5.28E-03	6.47E-07	1.26E-08	7.9000
			277.19	7.9	-0.20	7.60	59.27	262.69	5.40E-03	1.66E-04	2.01E-05	5.21E-03	5.14E-07	1.58E-08	7.8000
			281.20	7.8	-0.06	7.64	54.85	258.27	5.35E-03	2.05E-04	1.57E-05	5.13E-03	4.08E-07	2.00E-08	7.7000
			286.01	7.7	0.09	7.69	49.67	253.09	5.30E-03	2.54E-04	1.22E-05	5.04E-03	3.24E-07	2.51E-08	7.6000
			291.87	7.6	0.26	7.76	43.56	246.98	5.24E-03	3.12E-04	9.49E-06	4.92E-03	2.57E-07	3.16E-08	7.5000
			299.09	7.5	0.45	7.85	36.38	239.80	5.17E-03	3.81E-04					
			308.05	7.4	0.68	7.98	27.98	231.40	5.09E-03	4.64E-04					
			319.23	7.3	0.98	8.18	18.26	221.68	4.99E-03	5.59E-04					
			333.22	7.2	1.51	8.61	7.16	210.59	4.88E-03	6.69E-04					
			350.78	7.1	9.49	####	0.00	198.13	4.75E-03	7.93E-04					
			372.83	7	9.62	####	0.00	184.42	4.62E-03	9.29E-04					
			277.19	7.9	-0.06	7.64	54.85	258.27	5.35E-03	2.05E-04					
			277.56	7.89	-0.05	7.64	54.37	257.79	5.35E-03	2.10E-04					
			277.94	7.88	-0.03	7.65	53.88	257.30	5.34E-03	2.14E-04					
			278.32	7.87	-0.02	7.65	53.38	256.81	5.34E-03	2.19E-04					
			278.71	7.86	0.00	7.66	52.88	256.30	5.33E-03	2.23E-04					
			279.11	7.85	0.01	7.66	52.36	255.79	5.33E-03	2.28E-04					
			279.51	7.84	0.03	7.67	51.84	255.26	5.32E-03	2.33E-04					
			279.93	7.83	0.04	7.67	51.31	254.73	5.32E-03	2.38E-04					
			280.34	7.82	0.06	7.68	50.77	254.20	5.31E-03	2.43E-04					
			280.77	7.81	0.07	7.68	50.22	253.65	5.31E-03	2.48E-04					
			281.20	7.8	0.09	7.69	49.67	253.09	5.30E-03	2.54E-04					
					0.00	7.66	52.88	256.30	5.33E-03	2.23E-04					
					0.00	7.66	52.83	256.25	5.33E-03	2.24E-04					
					0.00	7.66	52.78	256.20	5.33E-03	2.24E-04					
					0.00	7.66	52.72	256.15	5.33E-03	2.25E-04					
					0.00	7.66	52.67	256.10	5.33E-03	2.25E-04					
					0.00	7.66	52.62	256.04	5.33E-03	2.26E-04					
					0.01	7.66	52.57	255.99	5.33E-03	2.26E-04					
					0.01	7.66	52.52	255.94	5.33E-03	2.27E-04					
					0.01	7.66	52.47	255.89	5.33E-03	2.27E-04					
					0.01	7.66	52.42	255.84	5.33E-03	2.28E-04					
					0.01	7.66	52.36	255.79	5.33E-03	2.28E-04					
					0.00	7.66	52.78	256.20	5.33E-03	2.24E-04					
					0.00	7.66	52.77	256.19	5.33E-03	2.24E-04					
					0.00	7.66	52.77	256.19	5.33E-03	2.24E-04					
					0.00	7.66	52.76	256.18	5.33E-03	2.25E-04					
					0.00	7.66	52.76	256.18	5.33E-03	2.25E-04					
					0.00	7.66	52.75	256.17	5.33E-03	2.25E-04					
					0.00	7.66	52.75	256.17	5.33E-03	2.25E-04					
					0.00	7.66	52.74	256.16	5.33E-03	2.25E-04					
					0.00	7.66	52.74	256.16	5.33E-03	2.25E-04					
					0.00	7.66	52.73	256.15	5.33E-03	2.25E-04					
					0.00	7.66	52.72	256.15	5.33E-03	2.25E-04					
					0.00	7.66	52.75	256.17	5.33E-03	2.25E-04					

Tk 293
 I 0.008675
 E 80.094785
 A 0.5062483
 f(l) 0.0852038
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.9108948
 fd 0.6884507
 K1p 4.99E-07
 K2p 6.10E-11
 Kwp 8.14E-15
 Ksp 7.44E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 2b (1): EP001 & EP004

The RTW Model Ver. 4.0 ID: **Blend 2b (1)**

STEP 1: Enter initial water characteristics.

Measured TDS	327.4	mg/L
Measured temperature	20	deg C
Measured pH	7.8	
Measured alk, as CaCO3	262.64	mg/L
Measured Ca, as CaCO3	55.83	mg/L
Measured Cl	43.36	mg/L
Measured SO4	14.52	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.8	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired
Interim alkalinity	263	mg/L	> 40	mg/L	
Interim Ca, as CaCO3	56	mg/L	> 40	mg/L	
Alk/(Cl+SO4)	4.5		> 5.0		
			Interim pH	7.80	6.8-9.3
			Precipitation potential	5.69	mg/L
			Langelier index	0.18	>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	277	mg/L
Initial Ca sat, as CaCO3	37	mg/L
Initial DIC, as CaCO3	540	mg/L

Theoretical interim water characteristics

Interim acidity	277	mg/L
Interim Ca sat, as CaCO3	37	mg/L
Ryznar Index	7.43	
Interim DIC, as CaCO3	540	mg/L
Aggressiveness Index	11.97	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	257	mg/L
Final Ca	50	mg/L
Final acidity	277	mg/L
Final pH	7.67	
Final DIC, as CaCO3	534	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH	
[H+]	1.58E-08	1.58E-08													
[DIC]	5.40E-03	5.40E-03													
[HCO3-]	5.21E-03	5.21E-03													
[CO3-]	1.99E-05	1.99E-05	-40516.40	14	-0.18	7.62	55.83	262.64	5.40E-03	1.66E-04	1.99E-05	5.21E-03	5.11E-07	1.58E-08	7.8000
[H2CO3*]	0.000166	1.66E-04	-4054.44	13	0.80	8.07	22.32	229.13	5.06E-03	4.86E-04	5.23E-06	4.57E-03	1.53E-07	5.29E-08	7.2769
[Ca++] _s	3.68E-04	3.68E-04	-406.30	12	9.82	####	0.00	162.27	4.40E-03	1.15E-03	1.11E-06	3.24E-03	4.60E-08	1.76E-07	6.7538
pHs alk		7.62	-23.53	11	10.64	####	0.00	82.34	3.60E-03	1.95E-03	1.69E-07	1.65E-03	1.38E-08	5.88E-07	6.2308
			113.10	10	11.58	####	0.00	31.07	3.08E-03	2.46E-03	1.92E-08	6.23E-04	4.13E-09	1.96E-06	5.7077
			234.50	9	12.59	####	0.00	9.81	2.87E-03	2.67E-03	1.87E-09	2.03E-04	1.24E-09	6.54E-06	5.1846
			269.87	8	13.63	####	0.00	2.02	2.79E-03	2.73E-03	1.72E-10	6.22E-05	3.72E-10	2.18E-05	4.6615
			367.92	7	14.67	####	0.00	-2.70	2.75E-03	2.73E-03	1.55E-11	1.86E-05	1.11E-10	7.27E-05	4.1385
			1320.02	6	15.73	####	0.00	-11.85	2.65E-03	2.65E-03	1.35E-12	5.43E-06	3.34E-11	2.42E-04	3.6154
			10856.06	5	16.83	####	0.00	-40.35	2.37E-03	2.37E-03	1.09E-13	1.45E-06	1.00E-11	8.09E-04	3.0923
			108009.50	4	18.09	####	0.00	-134.80	1.42E-03	1.42E-03	5.88E-15	2.62E-07	3.01E-12	2.70E-03	2.5692
			1258877.41	3	####	####	0.00	-277.23	1.81E-96	1.81E-96	6.72E-109	1.00E-100	9.01E-13	8.99E-03	2.0462
			30700911.04	2	####	####	0.00	-277.23	6.04E-96	6.04E-96	2.01E-109	1.00E-100	2.70E-13	3.00E-02	1.5231
			2118456704.18	1	####	####	0.00	-277.23	2.01E-95	2.01E-95	6.04E-110	1.00E-100	8.10E-14	1.00E-01	1.0000
			269.87	8	-0.18	7.62	55.83	262.64	5.40E-03	1.66E-04	1.99E-05	5.21E-03	5.11E-07	1.58E-08	7.8000
			273.26	7.9	-0.04	7.66	51.40	258.21	5.35E-03	2.06E-04	1.55E-05	5.13E-03	4.06E-07	2.00E-08	7.7000
			277.23	7.8	0.12	7.72	46.20	253.01	5.30E-03	2.55E-04	1.21E-05	5.04E-03	3.23E-07	2.51E-08	7.6000
			281.99	7.7	0.29	7.79	40.08	246.89	5.24E-03	3.13E-04	9.40E-06	4.92E-03	2.56E-07	3.16E-08	7.5000
			287.78	7.6	0.49	7.89	32.87	239.68	5.17E-03	3.83E-04	7.25E-06	4.78E-03	2.04E-07	3.98E-08	7.4000
			294.92	7.5	0.73	8.03	24.45	231.26	5.08E-03	4.65E-04	5.56E-06	4.61E-03	1.62E-07	5.01E-08	7.3000
			303.79	7.4	1.07	8.27	14.70	221.51	4.99E-03	5.62E-04	4.23E-06	4.42E-03	1.28E-07	6.31E-08	7.2000
			314.86	7.3	1.81	8.91	3.57	210.38	4.88E-03	6.72E-04	3.20E-06	4.20E-03	1.02E-07	7.94E-08	7.1000
			328.71	7.2	9.49	####	0.00	197.90	4.75E-03	7.96E-04	2.39E-06	3.95E-03	8.10E-08	1.00E-07	7.0000
			346.09	7.1	9.62	####	0.00	184.16	4.61E-03	9.32E-04	1.77E-06	3.68E-03	6.44E-08	1.26E-07	6.9000
			367.92	7	9.75	####	0.00	169.37	4.47E-03	1.08E-03	1.29E-06	3.38E-03	5.11E-08	1.58E-07	6.8000
			277.23	7.8	-0.04	7.66	51.40	258.21	5.35E-03	2.06E-04	1.55E-05	5.13E-03	4.06E-07	2.00E-08	7.7000
			277.67	7.79	-0.02	7.67	50.92	257.73	5.35E-03	2.11E-04	1.52E-05	5.12E-03	3.97E-07	2.04E-08	7.6900
			278.11	7.78	-0.01	7.67	50.43	257.24	5.34E-03	2.15E-04	1.48E-05	5.11E-03	3.88E-07	2.09E-08	7.6800
			278.56	7.77	0.01	7.68	49.93	256.74	5.34E-03	2.20E-04	1.44E-05	5.11E-03	3.79E-07	2.14E-08	7.6700
			279.03	7.76	0.02	7.68	49.42	256.23	5.33E-03	2.24E-04	1.41E-05	5.10E-03	3.70E-07	2.19E-08	7.6600
			279.50	7.75	0.04	7.69	48.91	255.72	5.33E-03	2.29E-04	1.37E-05	5.09E-03	3.62E-07	2.24E-08	7.6500
			279.98	7.74	0.05	7.69	48.38	255.19	5.32E-03	2.34E-04	1.34E-05	5.08E-03	3.54E-07	2.29E-08	7.6400
			280.46	7.73	0.07	7.70	47.85	254.66	5.32E-03	2.39E-04	1.31E-05	5.07E-03	3.46E-07	2.34E-08	7.6300
			280.96	7.72	0.08	7.70	47.31	254.12	5.31E-03	2.44E-04	1.27E-05	5.06E-03	3.38E-07	2.40E-08	7.6200
			281.47	7.71	0.10	7.71	46.76	253.57	5.31E-03	2.49E-04	1.24E-05	5.05E-03	3.30E-07	2.45E-08	7.6100
			281.99	7.7	0.12	7.72	46.20	253.01	5.30E-03	2.55E-04	1.21E-05	5.04E-03	3.23E-07	2.51E-08	7.6000
					-0.01	7.67	50.43	257.24	5.34E-03	2.15E-04	1.48E-05	5.11E-03	3.88E-07	2.09E-08	7.6800
					-0.01	7.67	50.38	257.19	5.34E-03	2.16E-04	1.48E-05	5.11E-03	3.87E-07	2.09E-08	7.6790
					-0.01	7.67	50.33	257.14	5.34E-03	2.16E-04	1.47E-05	5.11E-03	3.86E-07	2.10E-08	7.6780
					0.00	7.67	50.28	257.09	5.34E-03	2.16E-04	1.47E-05	5.11E-03	3.85E-07	2.10E-08	7.6770
					0.00	7.67	50.23	257.04	5.34E-03	2.17E-04	1.46E-05	5.11E-03	3.84E-07	2.11E-08	7.6760
					0.00	7.67	50.18	256.99	5.34E-03	2.17E-04	1.46E-05	5.11E-03	3.83E-07	2.11E-08	7.6750
					0.00	7.67	50.13	256.94	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.82E-07	2.12E-08	7.6740
					0.00	7.67	50.08	256.89	5.34E-03	2.18E-04	1.45E-05	5.11E-03	3.82E-07	2.12E-08	7.6730
					0.00	7.68	50.03	256.84	5.34E-03	2.19E-04	1.45E-05	5.11E-03	3.81E-07	2.13E-08	7.6720
					0.00	7.68	49.98	256.79	5.34E-03	2.19E-04	1.45E-05	5.11E-03	3.80E-07	2.13E-08	7.6710
					0.01	7.68	49.93	256.74	5.34E-03	2.20E-04	1.44E-05	5.11E-03	3.79E-07	2.14E-08	7.6700
					0.00	7.67	50.18	256.99	5.34E-03	2.17E-04	1.46E-05	5.11E-03	3.83E-07	2.11E-08	7.6750
					0.00	7.67	50.18	256.99	5.34E-03	2.17E-04	1.46E-05	5.11E-03	3.83E-07	2.11E-08	7.6749
					0.00	7.67	50.17	256.98	5.34E-03	2.17E-04	1.46E-05	5.11E-03	3.83E-07	2.11E-08	7.6748
					0.00	7.67	50.17	256.98	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.83E-07	2.11E-08	7.6747
					0.00	7.67	50.16	256.97	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.83E-07	2.12E-08	7.6746
					0.00	7.67	50.16	256.97	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.83E-07	2.12E-08	7.6745
					0.00	7.67	50.15	256.96	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.83E-07	2.12E-08	7.6744
					0.00	7.67	50.15	256.96	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.83E-07	2.12E-08	7.6743
					0.00	7.67	50.14	256.95	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.83E-07	2.12E-08	7.6742
					0.00	7.67	50.14	256.95	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.83E-07	2.12E-08	7.6741
					0.00	7.67	50.13	256.94	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.82E-07	2.12E-08	7.6740
					0.00	7.67	50.14	256.95	5.34E-03	2.18E-04	1.46E-05	5.11E-03	3.83E-07	2.12E-08	7.6742

Tk 293
 I 0.00819
 E 80.0948
 A 0.50625
 f(l) 0.08297
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.91297
 fd 0.69473
 K1p 4.97E-07
 K2p 6.04E-11
 Kwp 8.10E-15
 Ksp 7.31E-09

Forms of CaCO3 and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 2b (2): EP001 & EP004

The RTW Model Ver. 4.0 ID: **Blend 2b (2)**

STEP 1: Enter initial water characteristics.

Measured TDS	326.5	mg/L
Measured temperature	20	deg C
Measured pH	7.8	
Measured alk, as CaCO3	268.4	mg/L
Measured Ca, as CaCO3	63.3	mg/L
Measured Cl	42.1	mg/L
Measured SO4	14.7	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.8	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics	Desired	Theoretical interim water characteristics	Desired		
Interim alkalinity	268 mg/L	> 40 mg/L	Interim pH	7.80	6.8-9.3
Interim Ca, as CaCO3	63 mg/L	> 40 mg/L	Precipitation potential	8.26 mg/L	4-10 mg/L
Alk/(Cl+SO4)	4.7	> 5.0	Langelier index	0.25	>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	283	mg/L
Initial Ca sat, as CaCO3	36	mg/L
Initial DIC, as CaCO3	552	mg/L

Theoretical interim water characteristics

Interim acidity	283	mg/L
Interim Ca sat, as CaCO3	36	mg/L
Ryznar Index	7.30	
Interim DIC, as CaCO3	552	mg/L
Aggressiveness Index	12.03	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	260	mg/L
Final Ca	55	mg/L
Final acidity	283	mg/L
Final pH	7.63	
Final DIC, as CaCO3	543	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim	Interim	Delta	Final	Final	Final	Final	Final	Final	Final	Final	Final	Final	Final	
(H+)	1.58E-08	1.58E-08			pH	pH	Ca	Alk	[DIC]	[H2CO3*]	[CO3-]	[HCO3-]	{OH-}	{H+}		pH	
[DIC]	5.52E-03	5.52E-03					mg CaCO3/L	mg CaCO3/L									
[HCO3-]	5.33E-03	5.33E-03															
[CO3-]	2.03E-05	2.03E-05	-40507.78	14	-0.25	7.55	63.30	268.40	5.52E-03	1.70E-04	2.03E-05	5.33E-03	5.11E-07	1.58E-08	7.8000		
[H2CO3*]	0.00017	1.70E-04	-4053.57	13	0.67	7.95	29.05	234.15	5.17E-03	4.97E-04	5.34E-06	4.67E-03	1.53E-07	5.29E-08	7.2769		
[Ca++]s	3.60E-04	3.60E-04	-406.17	12	9.81	#####	0.00	165.82	4.49E-03	1.18E-03	1.14E-06	3.31E-03	4.60E-08	1.76E-07	6.7538		
pHs alk		7.55	-23.08	11	10.63	#####	0.00	84.13	3.67E-03	1.99E-03	1.73E-07	1.68E-03	1.38E-08	5.88E-07	6.2308		
			115.74	10	11.57	#####	0.00	31.75	3.15E-03	2.51E-03	1.96E-08	6.37E-04	4.13E-09	1.96E-06	5.7077		
			239.67	9	12.58	#####	0.00	10.03	2.93E-03	2.73E-03	1.91E-09	2.07E-04	1.24E-09	6.54E-06	5.1846		
			275.79	8	13.62	#####	0.00	2.09	2.85E-03	2.79E-03	1.76E-10	6.36E-05	3.72E-10	2.18E-05	4.6615		
			376.01	7	14.66	#####	0.00	-2.68	2.81E-03	2.79E-03	1.58E-11	1.90E-05	1.11E-10	7.27E-05	4.1385		
			1349.20	6	15.72	#####	0.00	-11.84	2.71E-03	2.71E-03	1.38E-12	5.55E-06	3.34E-11	2.42E-04	3.6154		
			11095.99	5	16.82	#####	0.00	-40.35	2.43E-03	2.43E-03	1.11E-13	1.49E-06	1.00E-11	8.09E-04	3.0923		
			110357.35	4	18.08	#####	0.00	-134.80	1.49E-03	1.48E-03	6.13E-15	2.74E-07	3.00E-12	2.70E-03	2.5692		
			1282342.63	3	#####	#####	0.00	-283.32	1.81E-96	1.81E-96	6.72E-109	1.00E-100	9.01E-13	8.99E-03	2.0462		
			30939368.58	2	#####	#####	0.00	-283.32	6.04E-96	6.04E-96	2.01E-109	1.00E-100	2.70E-13	3.00E-02	1.5231		
			2121226936.30	1	#####	#####	0.00	-283.32	2.01E-95	2.01E-95	6.04E-110	1.00E-100	8.10E-14	1.00E-01	1.0000		
			275.79	8	-0.25	7.55	63.30	268.40	5.52E-03	1.70E-04	2.03E-05	5.33E-03	5.11E-07	1.58E-08	7.8000		
			279.26	7.9	-0.11	7.59	58.77	263.87	5.47E-03	2.11E-04	1.59E-05	5.25E-03	4.06E-07	2.00E-08	7.7000		
			283.32	7.8	0.04	7.64	53.46	258.56	5.42E-03	2.60E-04	1.24E-05	5.15E-03	3.23E-07	2.51E-08	7.6000		
			288.18	7.7	0.21	7.71	47.20	252.30	5.36E-03	3.20E-04	9.60E-06	5.03E-03	2.56E-07	3.16E-08	7.5000		
			294.10	7.6	0.39	7.79	39.83	244.93	5.28E-03	3.91E-04	7.41E-06	4.88E-03	2.03E-07	3.98E-08	7.4000		
			301.40	7.5	0.61	7.91	31.22	236.32	5.20E-03	4.76E-04	5.68E-06	4.71E-03	1.62E-07	5.01E-08	7.3000		
			310.46	7.4	0.90	8.10	21.26	226.36	5.10E-03	5.74E-04	4.32E-06	4.52E-03	1.28E-07	6.31E-08	7.2000		
			321.77	7.3	1.35	8.45	9.89	214.99	4.98E-03	6.87E-04	3.26E-06	4.29E-03	1.02E-07	7.94E-08	7.1000		
			335.93	7.2	9.48	#####	0.00	202.23	4.86E-03	8.13E-04	2.44E-06	4.04E-03	8.10E-08	1.00E-07	7.0000		
			353.70	7.1	9.61	#####	0.00	188.19	4.72E-03	9.53E-04	1.80E-06	3.76E-03	6.43E-08	1.26E-07	6.9000		
			376.01	7	9.74	#####	0.00	173.08	4.56E-03	1.10E-03	1.32E-06	3.46E-03	5.11E-08	1.58E-07	6.8000		
			283.32	7.8	-0.11	7.59	58.77	263.87	5.47E-03	2.11E-04	1.59E-05	5.25E-03	4.06E-07	2.00E-08	7.7000		
			283.76	7.79	-0.09	7.60	58.28	263.38	5.47E-03	2.15E-04	1.55E-05	5.24E-03	3.97E-07	2.04E-08	7.6900		
			284.22	7.78	-0.08	7.60	57.78	262.88	5.46E-03	2.20E-04	1.51E-05	5.23E-03	3.88E-07	2.09E-08	7.6800		
			284.68	7.77	-0.06	7.61	57.27	262.37	5.46E-03	2.25E-04	1.47E-05	5.22E-03	3.79E-07	2.14E-08	7.6700		
			285.15	7.76	-0.05	7.61	56.75	261.85	5.45E-03	2.29E-04	1.44E-05	5.21E-03	3.70E-07	2.19E-08	7.6600		
			285.63	7.75	-0.03	7.62	56.23	261.33	5.45E-03	2.34E-04	1.40E-05	5.20E-03	3.62E-07	2.24E-08	7.6500		
			286.12	7.74	-0.02	7.62	55.69	260.79	5.44E-03	2.39E-04	1.37E-05	5.19E-03	3.54E-07	2.29E-08	7.6400		
			286.62	7.73	0.00	7.63	55.15	260.25	5.44E-03	2.44E-04	1.33E-05	5.18E-03	3.46E-07	2.34E-08	7.6300		
			287.13	7.72	0.01	7.63	54.59	259.69	5.43E-03	2.50E-04	1.30E-05	5.17E-03	3.38E-07	2.40E-08	7.6200		
			287.65	7.71	0.03	7.64	54.03	259.13	5.42E-03	2.55E-04	1.27E-05	5.16E-03	3.30E-07	2.45E-08	7.6100		
			288.18	7.7	0.04	7.64	53.46	258.56	5.42E-03	2.60E-04	1.24E-05	5.15E-03	3.23E-07	2.51E-08	7.6000		
					0.00	7.63	55.15	260.25	5.44E-03	2.44E-04	1.33E-05	5.18E-03	3.46E-07	2.34E-08	7.6300		
					0.00	7.63	55.09	260.19	5.44E-03	2.45E-04	1.33E-05	5.18E-03	3.45E-07	2.35E-08	7.6290		
					0.00	7.63	55.04	260.14	5.43E-03	2.45E-04	1.33E-05	5.18E-03	3.44E-07	2.36E-08	7.6280		
					0.00	7.63	54.98	260.08	5.43E-03	2.46E-04	1.32E-05	5.17E-03	3.43E-07	2.36E-08	7.6270		
					0.00	7.63	54.93	260.03	5.43E-03	2.46E-04	1.32E-05	5.17E-03	3.42E-07	2.37E-08	7.6260		
					0.00	7.63	54.87	259.97	5.43E-03	2.47E-04	1.32E-05	5.17E-03	3.42E-07	2.37E-08	7.6250		
					0.01	7.63	54.82	259.92	5.43E-03	2.47E-04	1.31E-05	5.17E-03	3.41E-07	2.38E-08	7.6240		
					0.01	7.63	54.76	259.86	5.43E-03	2.48E-04	1.31E-05	5.17E-03	3.40E-07	2.38E-08	7.6230		
					0.01	7.63	54.71	259.81	5.43E-03	2.49E-04	1.31E-05	5.17E-03	3.39E-07	2.39E-08	7.6220		
					0.01	7.63	54.65	259.75	5.43E-03	2.49E-04	1.30E-05	5.17E-03	3.38E-07	2.39E-08	7.6210		
					0.01	7.63	54.59	259.69	5.43E-03	2.50E-04	1.30E-05	5.17E-03	3.38E-07	2.40E-08	7.6200		
					0.00	7.63	55.04	260.14	5.43E-03	2.45E-04	1.33E-05	5.18E-03	3.44E-07	2.36E-08	7.6280		
					0.00	7.63	55.03	260.13	5.43E-03	2.45E-04	1.33E-05	5.18E-03	3.44E-07	2.36E-08	7.6279		
					0.00	7.63	55.02	260.13	5.43E-03	2.45E-04	1.33E-05	5.18E-03	3.44E-07	2.36E-08	7.6278		
					0.00	7.63	55.02	260.12	5.43E-03	2.46E-04	1.33E-05	5.18E-03	3.44E-07	2.36E-08	7.6277		
					0.00	7.63	55.02	260.12	5.43E-03	2.46E-04	1.33E-05	5.18E-03	3.44E-07	2.36E-08	7.6276		
					0.00	7.63	55.01	260.11	5.43E-03	2.46E-04	1.33E-05	5.18E-03	3.44E-07	2.36E-08	7.6275		
					0.00	7.63	55.00	260.10	5.43E-03	2.46E-04	1.33E-05	5.18E-03	3.44E-07	2.36E-08	7.6274		
					0.00	7.63	55.00	260.10	5.43E-03	2.46E-04	1.32E-05	5.18E-03	3.43E-07	2.36E-08	7.6273		
					0.00	7.63	54.99	260.09	5.43E-03	2.46E-04	1.32E-05	5.18E-03	3.43E-07	2.36E-08	7.6272		
					0.00	7.63	54.99	260.09	5.43E-03	2.46E-04	1.32E-05	5.17E-03	3.43E-07	2.36E-08	7.6271		
					0.00	7.63	54.98	260.08	5.43E-03	2.46E-04	1.32E-05	5.17E-03	3.43E-07	2.36E-08	7.6270		
					0.00	7.63	55.04	260.14	5.43E-03	2.45E-04	1.33E-05	5.18E-03	3.44E-07	2.36E-08	7.6280		

Tk 293
 I 0.00816
 E 80.0948
 A 0.50625
 f(l) 0.08286
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.91306
 fd 0.69503
 K1p 4.97E-07
 K2p 6.04E-11
 Kwp 8.10E-15
 Ksp 7.30E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 2c: EP005 & EP003

The RTW Model Ver. 4.0 ID: Blend 2c

STEP 1: Enter initial water characteristics.

Measured TDS	412.45	mg/L
Measured temperature	20	deg C
Measured pH	8	
Measured alk, as CaCO3	268.45	mg/L
Measured Ca, as CaCO3	49.377	mg/L
Measured Cl	91.134	mg/L
Measured SO4	13.437	mg/L

For CT and TTHM functions enter current:

Treated water pH	8	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics	Desired	Theoretical interim water characteristics	Desired		
Interim alkalinity	268 mg/L	> 40 mg/L	Interim pH	8.00	6.8-9.3
Interim Ca, as CaCO3	49 mg/L	> 40 mg/L	Precipitation potential	8.24 mg/L	4-10 mg/L
Alk/(Cl+SO4)	2.6	> 5.0	Langelier index	0.32	>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	276	mg/L
Initial Ca sat, as CaCO3	24	mg/L
Initial DIC, as CaCO3	544	mg/L

Theoretical interim water characteristics

Interim acidity	276	mg/L
Interim Ca sat, as CaCO3	24	mg/L
Ryznar Index	7.35	
Interim DIC, as CaCO3	544	mg/L
Aggressiveness Index	12.12	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	260	mg/L
Final Ca	41	mg/L
Final acidity	276	mg/L
Final pH	7.77	
Final DIC, as CaCO3	536	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca	Final Alk	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
							mg CaCO3/L	mg CaCO3/L							
(H+)	1.00E-08	1.00E-08													
[DIC]	5.44E-03	5.44E-03													
[HCO3-]	5.30E-03	5.30E-03													
[CO3-]	3.32E-05	3.32E-05	-41275.09	14	-0.32	7.68	49.38	268.45	5.44E-03	1.05E-04	3.32E-05	5.30E-03	8.25E-07	1.00E-08	8.0000
[H2CO3*]	0.000105	1.05E-04	-4130.26	13	0.57	8.03	24.25	243.32	5.19E-03	3.31E-04	8.80E-06	4.85E-03	2.39E-07	3.46E-08	7.4615
[Ca++] _s	2.37E-04	2.37E-04	-413.86	12	9.60	#####	0.00	187.40	4.63E-03	8.83E-04	1.97E-06	3.74E-03	6.91E-08	1.19E-07	6.9231
pHs alk		7.68	-24.49	11	10.39	#####	0.00	104.77	3.80E-03	1.71E-03	3.18E-07	2.10E-03	2.00E-08	4.12E-07	6.3846
			113.19	10	11.33	#####	0.00	41.47	3.17E-03	2.34E-03	3.65E-08	8.31E-04	5.79E-09	1.43E-06	5.8462
			238.70	9	12.36	#####	0.00	13.21	2.89E-03	2.62E-03	3.43E-09	2.69E-04	1.68E-09	4.92E-06	5.3077
			275.51	8	13.42	#####	0.00	3.18	2.79E-03	2.71E-03	2.97E-10	8.05E-05	4.85E-10	1.70E-05	4.7692
			374.05	7	14.50	#####	0.00	-1.77	2.74E-03	2.71E-03	2.49E-11	2.34E-05	1.40E-10	5.88E-05	4.2308
			1329.32	6	15.59	#####	0.00	-9.82	2.66E-03	2.65E-03	2.04E-12	6.61E-06	4.06E-11	2.03E-04	3.6923
			10896.54	5	16.71	#####	0.00	-35.00	2.41E-03	2.40E-03	1.55E-13	1.73E-06	1.18E-11	7.02E-04	3.1538
			108328.82	4	17.98	#####	0.00	-121.21	1.54E-03	1.54E-03	8.33E-15	3.22E-07	3.40E-12	2.42E-03	2.6154
			1258688.22	3	#####	#####	0.00	-275.51	1.66E-06	1.66E-06	7.48E-109	1.00E-100	9.85E-13	8.38E-03	2.0769
			30365949.08	2	#####	#####	0.00	-275.51	5.72E-96	5.72E-96	2.17E-109	1.00E-100	2.85E-13	2.89E-02	1.5385
			2081805242.65	1	#####	#####	0.00	-275.51	1.98E-95	1.98E-95	6.27E-110	1.00E-100	8.25E-14	1.00E-01	1.0000
			275.51	8	-0.32	7.68	49.38	268.45	5.44E-03	1.05E-04	3.32E-05	5.30E-03	8.25E-07	1.00E-08	8.0000
			278.96	7.9	-0.18	7.72	46.07	265.14	5.41E-03	1.31E-04	2.61E-05	5.25E-03	6.56E-07	1.26E-08	7.9000
			282.97	7.8	-0.04	7.76	42.31	261.38	5.37E-03	1.62E-04	2.05E-05	5.19E-03	5.21E-07	1.58E-08	7.8000
			287.76	7.7	0.11	7.81	37.95	257.02	5.33E-03	2.01E-04	1.61E-05	5.11E-03	4.14E-07	2.00E-08	7.7000
			293.59	7.6	0.28	7.88	32.85	251.92	5.27E-03	2.49E-04	1.25E-05	5.01E-03	3.29E-07	2.51E-08	7.6000
			300.77	7.5	0.48	7.98	26.84	245.90	5.21E-03	3.06E-04	9.71E-06	4.90E-03	2.61E-07	3.16E-08	7.5000
			309.68	7.4	0.73	8.13	19.76	238.83	5.14E-03	3.75E-04	7.50E-06	4.76E-03	2.07E-07	3.98E-08	7.4000
			320.79	7.3	1.08	8.38	11.49	230.56	5.06E-03	4.55E-04	5.75E-06	4.60E-03	1.65E-07	5.01E-08	7.3000
			334.70	7.2	1.97	9.17	1.91	220.98	4.96E-03	5.50E-04	4.38E-06	4.41E-03	1.31E-07	6.31E-08	7.2000
			352.15	7.1	9.38	#####	0.00	210.03	4.86E-03	6.58E-04	3.31E-06	4.19E-03	1.04E-07	7.94E-08	7.1000
			374.05	7	9.50	#####	0.00	197.73	4.73E-03	7.80E-04	2.48E-06	3.95E-03	8.25E-08	1.00E-07	7.0000
			275.51	8	-0.04	7.76	42.31	261.38	5.37E-03	1.62E-04	2.05E-05	5.19E-03	5.21E-07	1.58E-08	7.8000
			275.84	7.99	-0.03	7.76	41.90	260.97	5.36E-03	1.66E-04	2.00E-05	5.18E-03	5.09E-07	1.62E-08	7.7900
			276.17	7.98	-0.01	7.77	41.49	260.56	5.36E-03	1.70E-04	1.95E-05	5.17E-03	4.97E-07	1.66E-08	7.7800
			276.50	7.97	0.00	7.77	41.07	260.14	5.36E-03	1.73E-04	1.91E-05	5.16E-03	4.86E-07	1.70E-08	7.7700
			276.83	7.96	0.02	7.78	40.65	259.72	5.35E-03	1.77E-04	1.86E-05	5.16E-03	4.75E-07	1.74E-08	7.7600
			277.18	7.95	0.03	7.78	40.22	259.28	5.35E-03	1.81E-04	1.82E-05	5.15E-03	4.64E-07	1.78E-08	7.7500
			277.52	7.94	0.05	7.79	39.78	258.85	5.34E-03	1.85E-04	1.77E-05	5.14E-03	4.54E-07	1.82E-08	7.7400
			277.87	7.93	0.06	7.79	39.33	258.40	5.34E-03	1.89E-04	1.73E-05	5.13E-03	4.43E-07	1.86E-08	7.7300
			278.23	7.92	0.08	7.80	38.88	257.95	5.33E-03	1.93E-04	1.69E-05	5.12E-03	4.33E-07	1.91E-08	7.7200
			278.59	7.91	0.10	7.81	38.42	257.49	5.33E-03	1.97E-04	1.65E-05	5.12E-03	4.23E-07	1.95E-08	7.7100
			278.96	7.9	0.11	7.81	37.95	257.02	5.33E-03	2.01E-04	1.61E-05	5.11E-03	4.14E-07	2.00E-08	7.7000
					-0.01	7.77	41.49	260.56	5.36E-03	1.70E-04	1.95E-05	5.17E-03	4.97E-07	1.66E-08	7.7800
					-0.01	7.77	41.45	260.52	5.36E-03	1.70E-04	1.95E-05	5.17E-03	4.96E-07	1.66E-08	7.7790
					-0.01	7.77	41.41	260.48	5.36E-03	1.70E-04	1.94E-05	5.17E-03	4.95E-07	1.67E-08	7.7780
					-0.01	7.77	41.37	260.43	5.36E-03	1.71E-04	1.94E-05	5.17E-03	4.94E-07	1.67E-08	7.7770
					-0.01	7.77	41.32	260.39	5.36E-03	1.71E-04	1.93E-05	5.17E-03	4.93E-07	1.67E-08	7.7760
					-0.01	7.77	41.28	260.35	5.36E-03	1.71E-04	1.93E-05	5.17E-03	4.92E-07	1.68E-08	7.7750
					0.00	7.77	41.24	260.31	5.36E-03	1.72E-04	1.93E-05	5.17E-03	4.91E-07	1.68E-08	7.7740
					0.00	7.77	41.20	260.27	5.36E-03	1.72E-04	1.92E-05	5.17E-03	4.89E-07	1.69E-08	7.7730
					0.00	7.77	41.16	260.23	5.36E-03	1.73E-04	1.92E-05	5.17E-03	4.88E-07	1.69E-08	7.7720
					0.00	7.77	41.11	260.18	5.36E-03	1.73E-04	1.91E-05	5.16E-03	4.87E-07	1.69E-08	7.7710
					0.00	7.77	41.07	260.14	5.36E-03	1.73E-04	1.91E-05	5.16E-03	4.86E-07	1.70E-08	7.7700
					0.00	7.77	41.16	260.23	5.36E-03	1.73E-04	1.92E-05	5.17E-03	4.88E-07	1.69E-08	7.7720
					0.00	7.77	41.15	260.22	5.36E-03	1.73E-04	1.92E-05	5.17E-03	4.88E-07	1.69E-08	7.7719
					0.00	7.77	41.15	260.22	5.36E-03	1.73E-04	1.91E-05	5.17E-03	4.88E-07	1.69E-08	7.7718
					0.00	7.77	41.14	260.21	5.36E-03	1.73E-04	1.91E-05	5.17E-03	4.88E-07	1.69E-08	7.7717
					0.00	7.77	41.14	260.21	5.36E-03	1.73E-04	1.91E-05	5.17E-03	4.88E-07	1.69E-08	7.7716
					0.00	7.77	41.14	260.20	5.36E-03	1.73E-04	1.91E-05	5.17E-03	4.88E-07	1.69E-08	7.7715
					0.00	7.77	41.13	260.20	5.36E-03	1.73E-04	1.91E-05	5.17E-03	4.88E-07	1.69E-08	7.7714
					0.00	7.77	41.13	260.20	5.36E-03	1.73E-04	1.91E-05	5.17E-03	4.88E-07	1.69E-08	7.7713
					0.00	7.77	41.12	260.19	5.36E-03	1.73E-04	1.91E-05	5.17E-03	4.87E-07	1.69E-08	7.7712
					0.00	7.77	41.12	260.19	5.36E-03	1.73E-04	1.91E-05	5.17E-03	4.87E-07	1.69E-08	7.7711
					0.00	7.77	41.11	260.18	5.36E-03	1.73E-04	1.91E-05	5.16E-03	4.87E-07	1.69E-08	7.7710
					0.00	7.77	41.14	260.20	5.36E-03	1.73E-04	1.91E-05	5.17E-03	4.88E-07	1.69E-08	7.7715

Tk 293
 I 0.01031
 E 80.0948
 A 0.50625
 f(l) 0.09218
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.90454
 fd 0.66942
 K1p 5.06E-07
 K2p 6.27E-11
 Kwp 8.25E-15
 Ksp 7.87E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 2d (1): EP005 & EP004

STEP 1: Enter initial water characteristics.

Measured TDS	403.7	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	270.12	mg/L
Measured Ca, as CaCO3	46.143	mg/L
Measured Cl	86.53	mg/L
Measured SO4	13.33	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired
Interim alkalinity	270	mg/L	> 40	mg/L	
Interim Ca, as CaCO3	46	mg/L	> 40	mg/L	
Alk/(Cl+SO4)	2.7		> 5.0		
			Interim pH	7.90	6.8-9.3
			Precipitation potential	5.29	mg/L
			Langelier index	0.20	>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	281	mg/L
Initial Ca sat, as CaCO3	29	mg/L
Initial DIC, as CaCO3	551	mg/L

Theoretical interim water characteristics

Interim acidity	281	mg/L
Interim Ca sat, as CaCO3	29	mg/L
Ryznar Index	7.50	
Interim DIC, as CaCO3	551	mg/L
Aggressiveness Index	12.00	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	265	mg/L
Final Ca	41	mg/L
Final acidity	281	mg/L
Final pH	7.77	
Final DIC, as CaCO3	546	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

Initial	Interim	Interim	Interim	Delta	Final	Final	Final	Final	Final	Final	Final	Final	Final	Final	Final
(H+)	1.26E-08	1.26E-08	Acid, mg/l	pH	pH	Ca	Alk	[DIC]	[H2CO3*]	[CO3-]	[HCO3-]	{OH-}	{H+}	pH	
[DIC]	5.51E-03	5.51E-03				mg CaCO3/L	mg CaCO3/L								
[HCO3-]	5.35E-03	5.35E-03													
[CO3-]	2.65E-05	2.65E-05	-41201.64	14	-0.20	7.70	46.14	270.12	5.51E-03	1.33E-04	2.65E-05	5.35E-03	6.55E-07	1.26E-08	7.9000
[H2CO3*]	0.000133	1.33E-04	-4122.91	13	0.82	8.19	16.85	240.83	5.22E-03	4.06E-04	7.02E-06	4.80E-03	1.93E-07	4.27E-08	7.3692
[Ca++] _s	2.94E-04	2.94E-04	-413.11	12	9.71	#####	0.00	178.48	4.59E-03	1.02E-03	1.54E-06	3.57E-03	5.68E-08	1.45E-07	6.8385
pHs alk		7.70	-24.23	11	10.51	#####	0.00	95.18	3.76E-03	1.86E-03	2.42E-07	1.90E-03	1.67E-08	4.92E-07	6.3077
			114.18	10	11.45	#####	0.00	36.77	3.17E-03	2.44E-03	2.75E-08	7.37E-04	4.93E-09	1.67E-06	5.7769
			240.29	9	12.47	#####	0.00	11.67	2.92E-03	2.68E-03	2.63E-09	2.39E-04	1.45E-09	5.67E-06	5.2462
			277.26	8	13.52	#####	0.00	2.66	2.83E-03	2.76E-03	2.35E-10	7.24E-05	4.28E-10	1.93E-05	4.7154
			376.58	7	14.58	#####	0.00	-2.20	2.79E-03	2.76E-03	2.04E-11	2.14E-05	1.26E-10	6.54E-05	4.1846
			1339.51	6	15.66	#####	0.00	-10.79	2.70E-03	2.69E-03	1.73E-12	6.13E-06	3.71E-11	2.22E-04	3.6538
			10983.43	5	16.76	#####	0.00	-37.58	2.43E-03	2.43E-03	1.35E-13	1.63E-06	1.09E-11	7.53E-04	3.1231
			109185.84	4	18.02	#####	0.00	-127.82	1.53E-03	1.53E-03	7.38E-15	3.02E-07	3.22E-12	2.56E-03	2.5923
			1267560.36	3	#####	#####	0.00	-280.73	1.72E-96	1.72E-96	7.20E-109	1.00E-100	9.49E-13	8.68E-03	2.0615
			30486358.78	2	#####	#####	0.00	-280.73	5.83E-96	5.83E-96	2.12E-109	1.00E-100	2.80E-13	2.95E-02	1.5308
			2086179662.62	1	#####	#####	0.00	-280.73	1.98E-95	1.98E-95	6.25E-110	1.00E-100	8.24E-14	1.00E-01	1.0000
			277.26	8	-0.20	7.70	46.14	270.12	5.51E-03	1.33E-04	2.65E-05	5.35E-03	6.55E-07	1.26E-08	7.9000
			280.73	7.9	-0.05	7.75	42.31	266.29	5.47E-03	1.66E-04	2.08E-05	5.28E-03	5.20E-07	1.58E-08	7.8000
			284.77	7.8	0.10	7.80	37.87	261.85	5.43E-03	2.06E-04	1.63E-05	5.20E-03	4.13E-07	2.00E-08	7.7000
			289.60	7.7	0.28	7.88	32.66	256.64	5.37E-03	2.54E-04	1.27E-05	5.11E-03	3.28E-07	2.51E-08	7.6000
			295.48	7.6	0.48	7.98	26.53	250.50	5.31E-03	3.12E-04	9.86E-06	4.99E-03	2.61E-07	3.16E-08	7.5000
			302.71	7.5	0.73	8.13	19.31	243.29	5.24E-03	3.82E-04	7.61E-06	4.85E-03	2.07E-07	3.98E-08	7.4000
			311.69	7.4	1.09	8.39	10.87	234.85	5.16E-03	4.65E-04	5.84E-06	4.69E-03	1.64E-07	5.01E-08	7.3000
			322.89	7.3	2.20	9.40	1.10	225.08	5.06E-03	5.61E-04	4.45E-06	4.49E-03	1.31E-07	6.31E-08	7.2000
			336.91	7.2	9.37	#####	0.00	213.91	4.95E-03	6.72E-04	3.36E-06	4.27E-03	1.04E-07	7.94E-08	7.1000
			354.49	7.1	9.49	#####	0.00	201.37	4.82E-03	7.96E-04	2.51E-06	4.02E-03	8.24E-08	1.00E-07	7.0000
			376.58	7	9.62	#####	0.00	187.54	4.68E-03	9.34E-04	1.86E-06	3.75E-03	6.55E-08	1.26E-07	6.9000
			280.73	7.9	-0.05	7.75	42.31	266.29	5.47E-03	1.66E-04	2.08E-05	5.28E-03	5.20E-07	1.58E-08	7.8000
			281.10	7.89	-0.04	7.75	41.90	265.87	5.47E-03	1.69E-04	2.03E-05	5.28E-03	5.08E-07	1.62E-08	7.7900
			281.48	7.88	-0.02	7.76	41.48	265.45	5.46E-03	1.73E-04	1.98E-05	5.27E-03	4.96E-07	1.66E-08	7.7800
			281.87	7.87	-0.01	7.76	41.05	265.03	5.46E-03	1.77E-04	1.94E-05	5.26E-03	4.85E-07	1.70E-08	7.7700
			282.26	7.86	0.01	7.77	40.62	264.59	5.45E-03	1.81E-04	1.89E-05	5.25E-03	4.74E-07	1.74E-08	7.7600
			282.66	7.85	0.02	7.77	40.18	264.15	5.45E-03	1.85E-04	1.84E-05	5.25E-03	4.63E-07	1.78E-08	7.7500
			283.07	7.84	0.04	7.78	39.73	263.71	5.44E-03	1.89E-04	1.80E-05	5.24E-03	4.53E-07	1.82E-08	7.7400
			283.48	7.83	0.05	7.78	39.27	263.25	5.44E-03	1.93E-04	1.75E-05	5.23E-03	4.42E-07	1.86E-08	7.7300
			283.91	7.82	0.07	7.79	38.81	262.79	5.44E-03	1.97E-04	1.71E-05	5.22E-03	4.32E-07	1.91E-08	7.7200
			284.33	7.81	0.09	7.80	38.35	262.32	5.43E-03	2.01E-04	1.67E-05	5.21E-03	4.23E-07	1.95E-08	7.7100
			284.77	7.8	0.10	7.80	37.87	261.85	5.43E-03	2.06E-04	1.63E-05	5.20E-03	4.13E-07	2.00E-08	7.7000
					-0.01	7.76	41.05	265.03	5.46E-03	1.77E-04	1.94E-05	5.26E-03	4.85E-07	1.70E-08	7.7700
					-0.01	7.76	41.01	264.98	5.46E-03	1.77E-04	1.93E-05	5.26E-03	4.84E-07	1.70E-08	7.7690
					0.00	7.76	40.96	264.94	5.46E-03	1.78E-04	1.93E-05	5.26E-03	4.83E-07	1.71E-08	7.7680
					0.00	7.76	40.92	264.90	5.46E-03	1.78E-04	1.92E-05	5.26E-03	4.82E-07	1.71E-08	7.7670
					0.00	7.76	40.88	264.85	5.46E-03	1.78E-04	1.92E-05	5.26E-03	4.81E-07	1.71E-08	7.7660
					0.00	7.77	40.83	264.81	5.46E-03	1.79E-04	1.91E-05	5.26E-03	4.80E-07	1.72E-08	7.7650
					0.00	7.77	40.79	264.77	5.45E-03	1.79E-04	1.91E-05	5.26E-03	4.79E-07	1.72E-08	7.7640
					0.00	7.77	40.75	264.72	5.45E-03	1.80E-04	1.90E-05	5.26E-03	4.77E-07	1.73E-08	7.7630
					0.01	7.77	40.70	264.68	5.45E-03	1.80E-04	1.90E-05	5.26E-03	4.76E-07	1.73E-08	7.7620
					0.01	7.77	40.66	264.64	5.45E-03	1.80E-04	1.89E-05	5.25E-03	4.75E-07	1.73E-08	7.7610
					0.01	7.77	40.62	264.59	5.45E-03	1.81E-04	1.89E-05	5.25E-03	4.74E-07	1.74E-08	7.7600
					0.00	7.76	40.88	264.85	5.46E-03	1.78E-04	1.92E-05	5.26E-03	4.81E-07	1.71E-08	7.7660
					0.00	7.76	40.87	264.85	5.46E-03	1.78E-04	1.92E-05	5.26E-03	4.81E-07	1.71E-08	7.7659
					0.00	7.77	40.87	264.85	5.46E-03	1.78E-04	1.92E-05	5.26E-03	4.81E-07	1.71E-08	7.7658
					0.00	7.77	40.86	264.84	5.46E-03	1.78E-04	1.92E-05	5.26E-03	4.80E-07	1.72E-08	7.7657
					0.00	7.77	40.86	264.84	5.46E-03	1.79E-04	1.91E-05	5.26E-03	4.80E-07	1.72E-08	7.7656
					0.00	7.77	40.85	264.83	5.46E-03	1.79E-04	1.91E-05	5.26E-03	4.80E-07	1.72E-08	7.7655
					0.00	7.77	40.85	264.83	5.46E-03	1.79E-04	1.91E-05	5.26E-03	4.80E-07	1.72E-08	7.7654
					0.00	7.77	40.85	264.82	5.46E-03	1.79E-04	1.91E-05	5.26E-03	4.80E-07	1.72E-08	7.7653
					0.00	7.77	40.84	264.82	5.46E-03	1.79E-04	1.91E-05	5.26E-03	4.80E-07	1.72E-08	7.7652
					0.00	7.77	40.84	264.82	5.46E-03	1.79E-04	1.91E-05	5.26E-03	4.80E-07	1.72E-08	7.7651
					0.00	7.77	40.83	264.81	5.46E-03	1.79E-04	1.91E-05	5.26E-03	4.80E-07	1.72E-08	7.7650
					0.00	7.77	40.85	264.83	5.46E-03	1.79E-04	1.91E-05	5.26E-03	4.80E-07	1.72E-08	7.7654

Tk 293
 I 0.01009
 E 80.0948
 A 0.50625
 f(l) 0.09129
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.90534
 fd 0.67181
 K1p 5.05E-07
 K2p 6.25E-11
 Kwp 8.24E-15
 Ksp 7.82E-09

		Forms of CaCO3 and their solubility product consta			
Form #		1	2	3	4
Preferred		Calcite	Aragonite	Vaterite	General
1		3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 2d (2): EP005 & EP004

STEP 1: Enter initial water characteristics.

Measured TDS	386.08	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	264.35	mg/L
Measured Ca, as CaCO3	43.299	mg/L
Measured Cl	77.078	mg/L
Measured SO4	13.49	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired			
Interim alkalinity	264	mg/L	> 40	mg/L	Interim pH	7.90	6.8-9.3	
Interim Ca, as CaCO3	43	mg/L	> 40	mg/L	Precipitation potential	4.20	mg/L	4-10
Alk/(Cl+SO4)	2.9		> 5.0		Langelier index	0.17		>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	275	mg/L
Initial Ca sat, as CaCO3	30	mg/L
Initial DIC, as CaCO3	539	mg/L

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	260	mg/L
Final Ca	39	mg/L
Final acidity	275	mg/L
Final pH	7.79	
Final DIC, as CaCO3	535	mg/L

Theoretical interim water characteristics

Interim acidity	275	mg/L
Interim Ca sat, as CaCO3	30	mg/L
Ryznar Index	7.57	
Interim DIC, as CaCO3	539	mg/L
Aggressiveness Index	11.96	

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca	Final Alk	[DIC]	Final [H2CO3*]	Final [CO3-]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
							mg CaCO3/L	mg CaCO3/L							
(H+)	1.26E-08	1.26E-08													
[DIC]	5.39E-03	5.39E-03													
[HCO3-]	5.23E-03	5.23E-03													
[CO3-]	2.58E-05	2.58E-05	-41050.81	14	-0.16	7.74	43.30	264.35	5.39E-03	1.31E-04	2.58E-05	5.23E-03	6.52E-07	1.26E-08	7.9000
[H2CO3*]	0.000131	1.31E-04	-4107.85	13	0.89	8.26	14.56	235.61	5.10E-03	3.99E-04	6.82E-06	4.70E-03	1.92E-07	4.27E-08	7.3692
[Ca++] _s	2.99E-04	2.99E-04	-411.64	12	9.71	#####	0.00	174.47	4.49E-03	1.00E-03	1.49E-06	3.49E-03	5.66E-08	1.45E-07	6.8385
pHs alk		7.73	-24.39	11	10.52	#####	0.00	92.95	3.68E-03	1.82E-03	2.34E-07	1.86E-03	1.67E-08	4.92E-07	6.3077
			112.11	10	11.46	#####	0.00	35.88	3.11E-03	2.39E-03	2.67E-08	7.19E-04	4.91E-09	1.67E-06	5.7769
			235.34	9	12.48	#####	0.00	11.38	2.86E-03	2.63E-03	2.55E-09	2.33E-04	1.45E-09	5.67E-06	5.2462
			271.41	8	13.53	#####	0.00	2.57	2.77E-03	2.70E-03	2.28E-10	7.07E-05	4.26E-10	1.93E-05	4.7154
			368.93	7	14.59	#####	0.00	-2.23	2.73E-03	2.70E-03	1.98E-11	2.08E-05	1.26E-10	6.54E-05	4.1846
			1314.77	6	15.66	#####	0.00	-10.80	2.64E-03	2.63E-03	1.67E-12	5.98E-06	3.70E-11	2.22E-04	3.6538
			10787.91	5	16.77	#####	0.00	-37.58	2.37E-03	2.37E-03	1.30E-13	1.58E-06	1.09E-11	7.53E-04	3.1231
			107289.01	4	18.04	#####	0.00	-127.82	1.47E-03	1.47E-03	7.02E-15	2.89E-07	3.21E-12	2.56E-03	2.5923
			1249298.57	3	#####	#####	0.00	-274.80	1.72E-96	1.72E-96	7.15E-109	1.00E-100	9.46E-13	8.68E-03	2.0615
			30369252.96	2	#####	#####	0.00	-274.80	5.85E-96	5.85E-96	2.11E-109	1.00E-100	2.79E-13	2.95E-02	1.5308
			2091554671.41	1	#####	#####	0.00	-274.80	1.99E-95	1.99E-95	6.20E-110	1.00E-100	8.21E-14	1.00E-01	1.0000
			271.41	8	-0.16	7.74	43.30	264.35	5.39E-03	1.31E-04	2.58E-05	5.23E-03	6.52E-07	1.26E-08	7.9000
			274.80	7.9	-0.02	7.78	39.54	260.60	5.35E-03	1.63E-04	2.02E-05	5.17E-03	5.18E-07	1.58E-08	7.8000
			278.77	7.8	0.14	7.84	35.18	256.24	5.31E-03	2.02E-04	1.58E-05	5.09E-03	4.11E-07	2.00E-08	7.7000
			283.51	7.7	0.32	7.92	30.07	251.13	5.26E-03	2.49E-04	1.23E-05	5.00E-03	3.27E-07	2.51E-08	7.6000
			289.27	7.6	0.52	8.02	24.06	245.11	5.20E-03	3.07E-04	9.58E-06	4.88E-03	2.60E-07	3.16E-08	7.5000
			296.38	7.5	0.79	8.19	16.97	238.03	5.13E-03	3.75E-04	7.39E-06	4.75E-03	2.06E-07	3.98E-08	7.4000
			305.20	7.4	1.19	8.49	8.69	229.75	5.05E-03	4.56E-04	5.67E-06	4.58E-03	1.64E-07	5.01E-08	7.3000
			316.20	7.3	9.25	#####	0.00	220.16	4.95E-03	5.51E-04	4.32E-06	4.39E-03	1.30E-07	6.31E-08	7.2000
			329.97	7.2	9.37	#####	0.00	209.21	4.84E-03	6.59E-04	3.26E-06	4.18E-03	1.03E-07	7.94E-08	7.1000
			347.23	7.1	9.50	#####	0.00	196.91	4.72E-03	7.81E-04	2.44E-06	3.93E-03	8.21E-08	1.00E-07	7.0000
			368.93	7	9.63	#####	0.00	183.36	4.58E-03	9.16E-04	1.80E-06	3.66E-03	6.52E-08	1.26E-07	6.9000
			274.80	7.9	-0.02	7.78	39.54	260.60	5.35E-03	1.63E-04	2.02E-05	5.17E-03	5.18E-07	1.58E-08	7.8000
			275.17	7.89	0.00	7.79	39.14	260.19	5.35E-03	1.66E-04	1.97E-05	5.16E-03	5.06E-07	1.62E-08	7.7900
			275.54	7.88	0.01	7.79	38.72	259.78	5.35E-03	1.70E-04	1.93E-05	5.16E-03	4.95E-07	1.66E-08	7.7800
			275.92	7.87	0.03	7.80	38.30	259.36	5.34E-03	1.74E-04	1.88E-05	5.15E-03	4.83E-07	1.70E-08	7.7700
			276.31	7.86	0.04	7.80	37.88	258.93	5.34E-03	1.77E-04	1.83E-05	5.14E-03	4.72E-07	1.74E-08	7.7600
			276.70	7.85	0.06	7.81	37.45	258.50	5.33E-03	1.81E-04	1.79E-05	5.13E-03	4.62E-07	1.78E-08	7.7500
			277.10	7.84	0.08	7.82	37.01	258.06	5.33E-03	1.85E-04	1.75E-05	5.13E-03	4.51E-07	1.82E-08	7.7400
			277.50	7.83	0.09	7.82	36.56	257.62	5.32E-03	1.89E-04	1.70E-05	5.12E-03	4.41E-07	1.86E-08	7.7300
			277.92	7.82	0.11	7.83	36.11	257.17	5.32E-03	1.93E-04	1.66E-05	5.11E-03	4.31E-07	1.91E-08	7.7200
			278.34	7.81	0.12	7.83	35.65	256.71	5.32E-03	1.98E-04	1.62E-05	5.10E-03	4.21E-07	1.95E-08	7.7100
			278.77	7.8	0.14	7.84	35.18	256.24	5.31E-03	2.02E-04	1.58E-05	5.09E-03	4.11E-07	2.00E-08	7.7000
					0.00	7.79	39.14	260.19	5.35E-03	1.66E-04	1.97E-05	5.16E-03	5.06E-07	1.62E-08	7.7900
					0.00	7.79	39.09	260.15	5.35E-03	1.67E-04	1.97E-05	5.16E-03	5.05E-07	1.63E-08	7.7890
					0.00	7.79	39.05	260.11	5.35E-03	1.67E-04	1.96E-05	5.16E-03	5.04E-07	1.63E-08	7.7880
					0.00	7.79	39.01	260.07	5.35E-03	1.67E-04	1.96E-05	5.16E-03	5.03E-07	1.63E-08	7.7870
					0.00	7.79	38.97	260.02	5.35E-03	1.68E-04	1.96E-05	5.16E-03	5.02E-07	1.64E-08	7.7860
					0.01	7.79	38.93	259.98	5.35E-03	1.68E-04	1.95E-05	5.16E-03	5.00E-07	1.64E-08	7.7850
					0.01	7.79	38.89	259.94	5.35E-03	1.69E-04	1.95E-05	5.16E-03	4.99E-07	1.64E-08	7.7840
					0.01	7.79	38.85	259.90	5.35E-03	1.69E-04	1.94E-05	5.16E-03	4.98E-07	1.65E-08	7.7830
					0.01	7.79	38.81	259.86	5.35E-03	1.69E-04	1.94E-05	5.16E-03	4.97E-07	1.65E-08	7.7820
					0.01	7.79	38.76	259.82	5.35E-03	1.70E-04	1.93E-05	5.16E-03	4.96E-07	1.66E-08	7.7810
					0.01	7.79	38.72	259.78	5.35E-03	1.70E-04	1.93E-05	5.16E-03	4.95E-07	1.66E-08	7.7800
					0.00	7.79	39.14	260.19	5.35E-03	1.66E-04	1.97E-05	5.16E-03	5.06E-07	1.62E-08	7.7900
					0.00	7.79	39.13	260.18	5.35E-03	1.66E-04	1.97E-05	5.16E-03	5.06E-07	1.62E-08	7.7899
					0.00	7.79	39.13	260.18	5.35E-03	1.66E-04	1.97E-05	5.16E-03	5.06E-07	1.62E-08	7.7898
					0.00	7.79	39.12	260.18	5.35E-03	1.66E-04	1.97E-05	5.16E-03	5.06E-07	1.62E-08	7.7897
					0.00	7.79	39.12	260.17	5.35E-03	1.67E-04	1.97E-05	5.16E-03	5.06E-07	1.62E-08	7.7896
					0.00	7.79	39.11	260.17	5.35E-03	1.67E-04	1.97E-05	5.16E-03	5.06E-07	1.62E-08	7.7895
					0.00	7.79	39.11	260.16	5.35E-03	1.67E-04	1.97E-05	5.16E-03	5.05E-07	1.62E-08	7.7894
					0.00	7.79	39.11	260.16	5.35E-03	1.67E-04	1.97E-05	5.16E-03	5.05E-07	1.62E-08	7.7893
					0.00	7.79	39.10	260.16	5.35E-03	1.67E-04	1.97E-05	5.16E-03	5.05E-07	1.62E-08	7.7892
					0.00	7.79	39.10	260.15	5.35E-03	1.67E-04	1.97E-05	5.16E-03	5.05E-07	1.63E-08	7.7891
					0.00	7.79	39.09	260.15	5.35E-03	1.67E-04	1.97E-05	5.16E-03	5.05E-07	1.63E-08	7.7890
					0.00	7.79	39.10	260.15	5.35E-03	1.67E-04	1.97E-05	5.16E-03	5.05E-07	1.63E-08	7.7891

Tk 293
 I 0.00965
 E 80.0948
 A 0.50625
 f(l) 0.08946
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.907
 fd 0.67676
 K1p 5.03E-07
 K2p 6.20E-11
 Kwp 8.21E-15
 Ksp 7.70E-09

Forms of CaCO3 and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 3a (1): EP001, EP003, & EP004

The RTW Model

Ver. 4.0

ID: **Blend 3a (1)**

STEP 1: Enter initial water characteristics.

Measured TDS	335.31	mg/L
Measured temperature	20	deg C
Measured pH	8	
Measured alk, as CaCO3	267.06	mg/L
Measured Ca, as CaCO3	62.51	mg/L
Measured Cl	47.09	mg/L
Measured SO4	14.63	mg/L

For CT and TTHM functions enter current:

Treated water pH	8	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired			
Interim alkalinity	267	mg/L	> 40	mg/L	Interim pH	8.00	6.8-9.3	
Interim Ca, as CaCO3	63	mg/L	> 40	mg/L	Precipitation potential	12.41	mg/L	4-10
Alk/(Cl+SO4)	4.3		> 5.0		Langelier index	0.44		>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	274	mg/L
Initial Ca sat, as CaCO3	23	mg/L
Initial DIC, as CaCO3	541	mg/L

Theoretical interim water characteristics

Interim acidity	274	mg/L
Interim Ca sat, as CaCO3	23	mg/L
Ryznar Index	7.12	
Interim DIC, as CaCO3	541	mg/L
Aggressiveness Index	12.22	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	255	mg/L
Final Ca	50	mg/L
Final acidity	274	mg/L
Final pH	7.68	
Final DIC, as CaCO3	529	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
[H+]	1.00E-08	1.00E-08													
[DIC]	5.41E-03	5.41E-03													
[HCO3-]	5.28E-03	5.28E-03													
[CO3-]	3.2E-05	3.2E-05	-40591.60	14	-0.43	7.57	62.51	267.06	5.41E-03	1.06E-04	3.20E-05	5.28E-03	8.12E-07	1.00E-08	8.0000
[H2CO3]	0.000106	1.06E-04	-4061.95	13	0.37	7.83	37.25	241.80	5.16E-03	3.34E-04	8.46E-06	4.82E-03	2.35E-07	3.46E-08	7.4615
[Ca++] _s	2.30E-04	2.30E-04	-407.02	12	9.59	####	0.00	185.62	4.60E-03	8.89E-04	1.88E-06	3.71E-03	6.80E-08	1.19E-07	6.9231
pHs alk		7.56	-23.34	11	10.38	####	0.00	103.26	3.78E-03	1.71E-03	3.04E-07	2.06E-03	1.97E-08	4.12E-07	6.3846
			114.85	10	11.33	####	0.00	40.72	3.15E-03	2.34E-03	3.47E-08	8.16E-04	5.70E-09	1.43E-06	5.8462
			238.36	9	12.36	####	0.00	12.94	2.87E-03	2.61E-03	3.25E-09	2.64E-04	1.65E-09	4.92E-06	5.3077
			274.38	8	13.42	####	0.00	3.09	2.77E-03	2.70E-03	2.81E-10	7.89E-05	4.77E-10	1.70E-05	4.7692
			373.91	7	14.49	####	0.00	-1.79	2.73E-03	2.70E-03	2.36E-11	2.29E-05	1.38E-10	5.88E-05	4.2308
			1340.24	6	15.58	####	0.00	-9.83	2.65E-03	2.64E-03	1.93E-12	6.47E-06	4.00E-11	2.03E-04	3.6923
			11018.45	5	16.70	####	0.00	-35.00	2.39E-03	2.39E-03	1.47E-13	1.70E-06	1.16E-11	7.02E-04	3.1538
			109590.25	4	17.97	####	0.00	-121.21	1.53E-03	1.53E-03	7.86E-15	3.14E-07	3.35E-12	2.42E-03	2.6154
			1274309.47	3	####	####	0.00	-274.38	1.68E-96	1.68E-96	7.24E-109	1.00E-100	9.69E-13	8.38E-03	2.0769
			30821628.39	2	####	####	0.00	-274.38	5.81E-96	5.81E-96	2.10E-109	1.00E-100	2.80E-13	2.89E-02	1.5385
			2116307481.24	1	####	####	0.00	-274.38	2.01E-95	2.01E-95	6.06E-110	1.00E-100	8.12E-14	1.00E-01	1.0000
			274.38	8	-0.43	7.57	62.51	267.06	5.41E-03	1.06E-04	3.20E-05	5.28E-03	8.12E-07	1.00E-08	8.0000
			277.83	7.9	-0.31	7.59	59.20	263.75	5.38E-03	1.32E-04	2.52E-05	5.22E-03	6.45E-07	1.26E-08	7.9000
			281.86	7.8	-0.17	7.63	55.43	259.98	5.34E-03	1.64E-04	1.97E-05	5.16E-03	5.12E-07	1.58E-08	7.8000
			286.69	7.7	-0.03	7.67	51.05	255.60	5.30E-03	2.04E-04	1.54E-05	5.08E-03	4.07E-07	2.00E-08	7.7000
			292.57	7.6	0.12	7.72	45.91	250.46	5.25E-03	2.52E-04	1.20E-05	4.98E-03	3.23E-07	2.51E-08	7.6000
			299.82	7.5	0.30	7.80	39.85	244.40	5.19E-03	3.09E-04	9.34E-06	4.87E-03	2.57E-07	3.16E-08	7.5000
			308.82	7.4	0.49	7.89	32.73	237.28	5.12E-03	3.78E-04	7.21E-06	4.73E-03	2.04E-07	3.98E-08	7.4000
			320.05	7.3	0.74	8.04	24.40	228.95	5.03E-03	4.60E-04	5.53E-06	4.57E-03	1.62E-07	5.01E-08	7.3000
			334.11	7.2	1.07	8.27	14.77	219.32	4.94E-03	5.55E-04	4.21E-06	4.38E-03	1.29E-07	6.31E-08	7.2000
			351.76	7.1	1.79	8.89	3.77	208.32	4.83E-03	6.64E-04	3.18E-06	4.16E-03	1.02E-07	7.94E-08	7.1000
			373.91	7	9.49	####	0.00	195.97	4.70E-03	7.86E-04	2.37E-06	3.91E-03	8.12E-08	1.00E-07	7.0000
			274.38	8	-0.03	7.67	51.05	255.60	5.30E-03	2.04E-04	1.54E-05	5.08E-03	4.07E-07	2.00E-08	7.7000
			274.70	7.99	-0.01	7.68	50.57	255.12	5.30E-03	2.08E-04	1.51E-05	5.07E-03	3.98E-07	2.04E-08	7.6900
			275.03	7.98	0.00	7.68	50.09	254.64	5.29E-03	2.13E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6800
			275.36	7.97	0.02	7.69	49.59	254.14	5.29E-03	2.17E-04	1.43E-05	5.05E-03	3.80E-07	2.14E-08	7.6700
			275.70	7.96	0.03	7.69	49.09	253.64	5.28E-03	2.22E-04	1.40E-05	5.04E-03	3.71E-07	2.19E-08	7.6600
			276.04	7.95	0.05	7.70	48.58	253.13	5.28E-03	2.26E-04	1.36E-05	5.04E-03	3.63E-07	2.24E-08	7.6500
			276.39	7.94	0.06	7.70	48.07	252.62	5.27E-03	2.31E-04	1.33E-05	5.03E-03	3.54E-07	2.29E-08	7.6400
			276.74	7.93	0.08	7.71	47.54	252.09	5.26E-03	2.36E-04	1.30E-05	5.02E-03	3.46E-07	2.34E-08	7.6300
			277.10	7.92	0.09	7.71	47.00	251.55	5.26E-03	2.41E-04	1.27E-05	5.01E-03	3.38E-07	2.40E-08	7.6200
			277.46	7.91	0.11	7.72	46.46	251.01	5.25E-03	2.46E-04	1.23E-05	5.00E-03	3.31E-07	2.45E-08	7.6100
			277.83	7.9	0.12	7.72	45.91	250.46	5.25E-03	2.52E-04	1.20E-05	4.98E-03	3.23E-07	2.51E-08	7.6000
						7.68	50.57	255.12	5.30E-03	2.08E-04	1.51E-05	5.07E-03	3.98E-07	2.04E-08	7.6900
						7.68	50.52	255.07	5.29E-03	2.08E-04	1.50E-05	5.07E-03	3.97E-07	2.05E-08	7.6890
						7.68	50.47	255.02	5.29E-03	2.09E-04	1.50E-05	5.07E-03	3.96E-07	2.05E-08	7.6880
						7.68	50.43	254.98	5.29E-03	2.09E-04	1.50E-05	5.07E-03	3.95E-07	2.06E-08	7.6870
						7.68	50.38	254.93	5.29E-03	2.10E-04	1.49E-05	5.07E-03	3.94E-07	2.06E-08	7.6860
						7.68	50.33	254.88	5.29E-03	2.10E-04	1.49E-05	5.07E-03	3.93E-07	2.07E-08	7.6850
						7.68	50.28	254.83	5.29E-03	2.11E-04	1.48E-05	5.07E-03	3.92E-07	2.07E-08	7.6840
						7.68	50.23	254.78	5.29E-03	2.11E-04	1.48E-05	5.07E-03	3.91E-07	2.07E-08	7.6830
						7.68	50.18	254.73	5.29E-03	2.12E-04	1.48E-05	5.06E-03	3.90E-07	2.08E-08	7.6820
						7.68	50.13	254.68	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.08E-08	7.6810
						7.68	50.09	254.64	5.29E-03	2.13E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6800
						7.68	50.13	254.68	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.08E-08	7.6810
						7.68	50.13	254.68	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.08E-08	7.6809
						7.68	50.12	254.67	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6808
						7.68	50.12	254.67	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6807
						7.68	50.11	254.66	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6806
						7.68	50.11	254.66	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6805
						7.68	50.11	254.66	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6804
						7.68	50.10	254.65	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6803
						7.68	50.10	254.65	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6802
						7.68	50.09	254.64	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6801
						7.68	50.09	254.64	5.29E-03	2.13E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6800
						7.68	50.10	254.65	5.29E-03	2.12E-04	1.47E-05	5.06E-03	3.89E-07	2.09E-08	7.6802

Tk 293
 I 0.00838
 E 80.0948
 A 0.50625
 f(l) 0.08388
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.91212
 fd 0.69216
 K1p 4.98E-07
 K2p 6.06E-11
 Kwp 8.12E-15
 Ksp 7.36E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 3a (2): EP001, EP003, & EP004

The RTW Model Ver. 4.0 ID: **Blend 3a (2)**

STEP 1: Enter initial water characteristics.

Measured TDS	341.23	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	259.42	mg/L
Measured Ca, as CaCO3	53.119	mg/L
Measured Cl	51.345	mg/L
Measured SO4	14.376	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired			
Interim alkalinity	259	mg/L	> 40	mg/L	Interim pH	7.90	6.8-9.3	
Interim Ca, as CaCO3	53	mg/L	> 40	mg/L	Precipitation potential	7.02	mg/L	4-10
Alk/(Cl+SO4)	3.9		> 5.0		Langelier index	0.25		>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	270	mg/L
Initial Ca sat, as CaCO3	30	mg/L
Initial DIC, as CaCO3	529	mg/L

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	252	mg/L
Final Ca	46	mg/L
Final acidity	270	mg/L
Final pH	7.72	
Final DIC, as CaCO3	522	mg/L

Theoretical interim water characteristics

Interim acidity	270	mg/L
Interim Ca sat, as CaCO3	30	mg/L
Ryznar Index	7.39	
Interim DIC, as CaCO3	529	mg/L
Aggressiveness Index	12.04	

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim	Interim	Delta	Final	Final	Final		Final	Final	Final	Final	Final	Final	Final	
			Acid, mg/l	pH	pH	pH	Ca	Alk	[DIC]	[H2CO3*]	[CO3--]	[HCO3-]	{OH-}	{H+}		pH	
							mg CaCO3/L	mg CaCO3/L									
{H+}	1.26E-08	1.26E-08															
[DIC]	5.29E-03	5.29E-03															
[HCO3-]	5.14E-03	5.14E-03															
[CO3-]	2.48E-05	2.48E-05	-40647.24	14	-0.25	7.65	53.12	259.42	5.29E-03	1.30E-04	2.48E-05	5.14E-03	6.46E-07	1.26E-08		7.9000	
[H2CO3*]	0.00013	1.30E-04	-4067.52	13	0.66	8.03	24.72	231.02	5.01E-03	3.95E-04	6.56E-06	4.61E-03	1.90E-07	4.27E-08		7.3692	
{Ca++}s	2.98E-04	2.98E-04	-407.64	12	9.71	####	0.00	170.71	4.41E-03	9.93E-04	1.43E-06	3.41E-03	5.60E-08	1.45E-07		6.8385	
pHs alk		7.65	-24.02	11	10.52	####	0.00	90.67	3.61E-03	1.79E-03	2.24E-07	1.81E-03	1.65E-08	4.92E-07		6.3077	
			111.21	10	11.46	####	0.00	34.92	3.05E-03	2.35E-03	2.55E-08	7.00E-04	4.86E-09	1.67E-06		5.7769	
			231.45	9	12.48	####	0.00	11.06	2.81E-03	2.58E-03	2.43E-09	2.27E-04	1.43E-09	5.67E-06		5.2462	
			266.50	8	13.53	####	0.00	2.47	2.72E-03	2.65E-03	2.17E-10	6.87E-05	4.22E-10	1.93E-05		4.7154	
			363.07	7	14.59	####	0.00	-2.26	2.68E-03	2.66E-03	1.88E-11	2.02E-05	1.24E-10	6.54E-05		4.1846	
			1300.46	6	15.67	####	0.00	-10.80	2.59E-03	2.58E-03	1.59E-12	5.81E-06	3.86E-11	2.22E-04		3.6538	
			10689.42	5	16.78	####	0.00	-37.58	2.32E-03	2.32E-03	1.24E-13	1.54E-06	1.08E-11	7.53E-04		3.1231	
			106366.26	4	18.05	####	0.00	-127.82	1.42E-03	1.42E-03	6.58E-15	2.77E-07	3.18E-12	2.56E-03		2.5923	
			1241890.81	3	####	####	0.00	-269.85	1.74E-96	1.74E-96	7.01E-109	1.00E-100	9.37E-13	8.68E-03		2.0615	
			30472756.54	2	####	####	0.00	-269.85	5.91E-96	5.91E-96	2.06E-109	1.00E-100	2.76E-13	2.95E-02		1.5308	
			2110343433.70	1	####	####	0.00	-269.85	2.01E-95	2.01E-95	6.08E-110	1.00E-100	8.13E-14	1.00E-01		1.0000	
			266.50	8	-0.25	7.65	53.12	259.42	5.29E-03	1.30E-04	2.48E-05	5.14E-03	6.46E-07	1.26E-08		7.9000	
			269.85	7.9	-0.11	7.69	49.41	255.71	5.26E-03	1.61E-04	1.95E-05	5.07E-03	5.13E-07	1.58E-08		7.8000	
			273.76	7.8	0.03	7.73	45.11	251.41	5.21E-03	2.00E-04	1.52E-05	5.00E-03	4.07E-07	2.00E-08		7.7000	
			278.45	7.7	0.19	7.79	40.06	246.36	5.16E-03	2.47E-04	1.19E-05	4.90E-03	3.24E-07	2.51E-08		7.6000	
			284.16	7.6	0.37	7.87	34.11	240.41	5.10E-03	3.04E-04	9.21E-06	4.79E-03	2.57E-07	3.16E-08		7.5000	
			291.19	7.5	0.58	7.98	27.11	233.41	5.03E-03	3.72E-04	7.11E-06	4.65E-03	2.04E-07	3.98E-08		7.4000	
			299.92	7.4	0.86	8.16	18.93	225.22	4.95E-03	4.52E-04	5.45E-06	4.49E-03	1.62E-07	5.01E-08		7.3000	
			310.82	7.3	1.28	8.48	9.46	215.75	4.86E-03	5.45E-04	4.15E-06	4.31E-03	1.29E-07	6.31E-08		7.2000	
			324.46	7.2	9.37	####	0.00	204.94	4.75E-03	6.52E-04	3.13E-06	4.09E-03	1.02E-07	7.94E-08		7.1000	
			341.57	7.1	9.50	####	0.00	192.81	4.63E-03	7.73E-04	2.34E-06	3.85E-03	8.13E-08	1.00E-07		7.0000	
			363.07	7	9.63	####	0.00	179.45	4.49E-03	9.06E-04	1.73E-06	3.59E-03	6.46E-08	1.26E-07		6.9000	
			269.85	7.9	-0.11	7.69	49.41	255.71	5.26E-03	1.61E-04	1.95E-05	5.07E-03	5.13E-07	1.58E-08		7.8000	
			270.21	7.89	-0.10	7.69	49.01	255.31	5.25E-03	1.65E-04	1.90E-05	5.07E-03	5.01E-07	1.62E-08		7.7900	
			270.58	7.88	-0.09	7.69	48.60	254.90	5.25E-03	1.68E-04	1.85E-05	5.06E-03	4.90E-07	1.66E-08		7.7800	
			270.96	7.87	-0.07	7.70	48.19	254.49	5.24E-03	1.72E-04	1.81E-05	5.05E-03	4.79E-07	1.70E-08		7.7700	
			271.34	7.86	-0.06	7.70	47.77	254.07	5.24E-03	1.76E-04	1.77E-05	5.05E-03	4.68E-07	1.74E-08		7.7600	
			271.72	7.85	-0.04	7.71	47.34	253.64	5.23E-03	1.80E-04	1.72E-05	5.04E-03	4.57E-07	1.78E-08		7.7500	
			272.12	7.84	-0.03	7.71	46.91	253.21	5.23E-03	1.84E-04	1.68E-05	5.03E-03	4.47E-07	1.82E-08		7.7400	
			272.52	7.83	-0.01	7.72	46.47	252.77	5.23E-03	1.88E-04	1.64E-05	5.02E-03	4.37E-07	1.86E-08		7.7300	
			272.93	7.82	0.00	7.72	46.02	252.32	5.22E-03	1.92E-04	1.60E-05	5.01E-03	4.27E-07	1.91E-08		7.7200	
			273.34	7.81	0.02	7.73	45.57	251.87	5.22E-03	1.96E-04	1.56E-05	5.01E-03	4.17E-07	1.95E-08		7.7100	
			273.76	7.8	0.03	7.73	45.11	251.41	5.21E-03	2.00E-04	1.52E-05	5.00E-03	4.07E-07	2.00E-08		7.7000	
					-0.01	7.72	46.47	252.77	5.23E-03	1.88E-04	1.64E-05	5.02E-03	4.37E-07	1.86E-08		7.7300	
					-0.01	7.72	46.43	252.73	5.23E-03	1.88E-04	1.64E-05	5.02E-03	4.36E-07	1.87E-08		7.7290	
					-0.01	7.72	46.38	252.68	5.23E-03	1.88E-04	1.63E-05	5.02E-03	4.35E-07	1.87E-08		7.7280	
					-0.01	7.72	46.34	252.64	5.22E-03	1.89E-04	1.63E-05	5.02E-03	4.34E-07	1.87E-08		7.7270	
					-0.01	7.72	46.29	252.59	5.22E-03	1.89E-04	1.62E-05	5.02E-03	4.33E-07	1.88E-08		7.7260	
					-0.01	7.72	46.25	252.55	5.22E-03	1.90E-04	1.62E-05	5.02E-03	4.32E-07	1.88E-08		7.7250	
					0.00	7.72	46.20	252.50	5.22E-03	1.90E-04	1.62E-05	5.02E-03	4.31E-07	1.89E-08		7.7240	
					0.00	7.72	46.16	252.46	5.22E-03	1.90E-04	1.61E-05	5.02E-03	4.30E-07	1.89E-08		7.7230	
					0.00	7.72	46.11	252.41	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.29E-07	1.90E-08		7.7220	
					0.00	7.72	46.07	252.37	5.22E-03	1.91E-04	1.60E-05	5.01E-03	4.28E-07	1.90E-08		7.7210	
					0.00	7.72	46.02	252.32	5.22E-03	1.92E-04	1.60E-05	5.01E-03	4.27E-07	1.91E-08		7.7200	
					0.00	7.72	46.11	252.41	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.29E-07	1.90E-08		7.7220	
					0.00	7.72	46.11	252.41	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.28E-07	1.90E-08		7.7219	
					0.00	7.72	46.10	252.40	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.28E-07	1.90E-08		7.7218	
					0.00	7.72	46.10	252.40	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.28E-07	1.90E-08		7.7217	
					0.00	7.72	46.10	252.39	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.28E-07	1.90E-08		7.7216	
					0.00	7.72	46.09	252.39	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.28E-07	1.90E-08		7.7215	
					0.00	7.72	46.09	252.39	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.28E-07	1.90E-08		7.7214	
					0.00	7.72	46.08	252.38	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.28E-07	1.90E-08		7.7213	
					0.00	7.72	46.08	252.38	5.22E-03	1.91E-04	1.60E-05	5.02E-03	4.28E-07	1.90E-08		7.7212	
					0.00	7.72	46.07	252.37	5.22E-03	1.91E-04	1.60E-05	5.01E-03	4.28E-07	1.90E-08		7.7211	
					0.00	7.72	46.07	252.37	5.22E-03	1.91E-04	1.60E-05	5.01E-03	4.28E-07	1.90E-08		7.7210	
					0.00	7.72	46.10	252.39	5.22E-03	1.91E-04	1.61E-05	5.02E-03	4.28E-07	1.90E-08		7.7216	

Tk 293
 I 0.00853
 E 80.0948
 A 0.50625
 f(l) 0.08455
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.9115
 fd 0.69027
 K1p 4.98E-07
 K2p 6.08E-11
 Kwp 8.13E-15
 Ksp 7.40E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 3b (1): EP003, EP004, & EP005

The RTW Model Ver. 4.0 ID: **Blend 3b (1)**

STEP 1: Enter initial water characteristics.

Measured TDS	405.87	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	268.65	mg/L
Measured Ca, as CaCO3	47.365	mg/L
Measured Cl	87.65	mg/L
Measured SO4	13.4	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired			
Interim alkalinity	269	mg/L	> 40	mg/L	Interim pH	7.90	6.8-9.3	
Interim Ca, as CaCO3	47	mg/L	> 40	mg/L	Precipitation potential	5.56	mg/L	4-10
Alk/(Cl+SO4)	2.7		> 5.0		Langelier index	0.21		>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	279	mg/L
Initial Ca sat, as CaCO3	30	mg/L
Initial DIC, as CaCO3	548	mg/L

Theoretical interim water characteristics

Interim acidity	279	mg/L
Interim Ca sat, as CaCO3	30	mg/L
Ryznar Index	7.48	
Interim DIC, as CaCO3	548	mg/L
Aggressiveness Index	12.00	

Theoretical final water characteristics

after CaCO3 precipitation		
Final alkalinity	263	mg/L
Final Ca	42	mg/L
Final acidity	279	mg/L
Final pH	7.76	
Final DIC, as CaCO3	542	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
[H+]	1.26E-08	1.26E-08													
[DIC]	5.48E-03	5.48E-03													
[HCO3-]	5.32E-03	5.32E-03													
[CO3-]	2.64E-05	2.64E-05	-41219.93	14	-0.20	7.70	47.37	268.65	5.48E-03	1.32E-04	2.64E-05	5.32E-03	6.55E-07	1.26E-08	7.9000
[H2CO3*]	0.000132	1.32E-04	-4124.74	13	0.79	8.16	18.24	239.53	5.19E-03	4.04E-04	6.99E-06	4.78E-03	1.93E-07	4.27E-08	7.3692
[Ca++] _s	2.96E-04	2.96E-04	-413.31	12	9.71	#####	0.00	177.53	4.57E-03	1.02E-03	1.53E-06	3.56E-03	5.68E-08	1.45E-07	6.8385
pHs alk		7.69	-24.38	11	10.51	#####	0.00	94.69	3.74E-03	1.84E-03	2.40E-07	1.89E-03	1.67E-08	4.92E-07	6.3077
			113.46	10	11.46	#####	0.00	36.58	3.16E-03	2.42E-03	2.74E-08	7.33E-04	4.93E-09	1.67E-06	5.7769
			238.95	9	12.48	#####	0.00	11.61	2.91E-03	2.67E-03	2.62E-09	2.38E-04	1.45E-09	5.67E-06	5.2462
			275.75	8	13.52	#####	0.00	2.64	2.82E-03	2.75E-03	2.34E-10	7.21E-05	4.28E-10	1.93E-05	4.7154
			374.48	7	14.59	#####	0.00	-2.21	2.77E-03	2.75E-03	2.03E-11	2.13E-05	1.26E-10	6.54E-05	4.1846
			1331.75	6	15.66	#####	0.00	-10.79	2.68E-03	2.68E-03	1.72E-12	6.10E-06	3.71E-11	2.22E-04	3.6538
			10919.05	5	16.76	#####	0.00	-37.58	2.42E-03	2.41E-03	1.35E-13	1.62E-06	1.09E-11	7.53E-04	3.1231
			108554.38	4	18.03	#####	0.00	-127.82	1.51E-03	1.51E-03	7.32E-15	2.99E-07	3.22E-12	2.56E-03	2.5923
			1261179.97	3	#####	#####	0.00	-279.19	1.72E-96	1.72E-96	7.20E-109	1.00E-100	9.50E-13	8.68E-03	2.0615
			30414660.43	2	#####	#####	0.00	-279.19	5.83E-96	5.83E-96	2.12E-109	1.00E-100	2.80E-13	2.95E-02	1.5308
			2084671927.73	1	#####	#####	0.00	-279.19	1.98E-95	1.98E-95	6.25E-110	1.00E-100	8.24E-14	1.00E-01	1.0000
			275.75	8	-0.20	7.70	47.37	268.65	5.48E-03	1.32E-04	2.64E-05	5.32E-03	6.55E-07	1.26E-08	7.9000
			279.19	7.9	-0.06	7.74	43.56	264.84	5.44E-03	1.65E-04	2.07E-05	5.25E-03	5.20E-07	1.58E-08	7.8000
			283.21	7.8	0.09	7.79	39.14	260.42	5.40E-03	2.04E-04	1.62E-05	5.18E-03	4.13E-07	2.00E-08	7.7000
			288.01	7.7	0.26	7.86	33.96	255.25	5.34E-03	2.52E-04	1.26E-05	5.08E-03	3.28E-07	2.51E-08	7.6000
			293.86	7.6	0.46	7.96	27.86	249.15	5.28E-03	3.10E-04	9.81E-06	4.96E-03	2.61E-07	3.16E-08	7.5000
			301.05	7.5	0.70	8.10	20.69	241.97	5.21E-03	3.80E-04	7.58E-06	4.82E-03	2.07E-07	3.98E-08	7.4000
			309.98	7.4	1.04	8.34	12.30	233.58	5.13E-03	4.62E-04	5.81E-06	4.66E-03	1.64E-07	5.01E-08	7.3000
			321.11	7.3	1.84	9.04	2.58	223.87	5.03E-03	5.58E-04	4.43E-06	4.47E-03	1.31E-07	6.31E-08	7.2000
			335.05	7.2	9.37	#####	0.00	212.76	4.92E-03	6.68E-04	3.34E-06	4.25E-03	1.04E-07	7.94E-08	7.1000
			352.53	7.1	9.50	#####	0.00	200.29	4.79E-03	7.92E-04	2.50E-06	4.00E-03	8.24E-08	1.00E-07	7.0000
			374.48	7	9.63	#####	0.00	186.54	4.66E-03	9.28E-04	1.85E-06	3.73E-03	6.55E-08	1.26E-07	6.9000
			279.19	7.9	-0.06	7.74	43.56	264.84	5.44E-03	1.65E-04	2.07E-05	5.25E-03	5.20E-07	1.58E-08	7.8000
			279.57	7.89	-0.05	7.74	43.15	264.43	5.44E-03	1.68E-04	2.02E-05	5.25E-03	5.08E-07	1.62E-08	7.7900
			279.94	7.88	-0.03	7.75	42.73	264.01	5.43E-03	1.72E-04	1.97E-05	5.24E-03	4.97E-07	1.66E-08	7.7800
			280.33	7.87	-0.02	7.75	42.30	263.59	5.43E-03	1.76E-04	1.93E-05	5.23E-03	4.85E-07	1.70E-08	7.7700
			280.72	7.86	0.00	7.76	41.87	263.15	5.42E-03	1.80E-04	1.88E-05	5.23E-03	4.74E-07	1.74E-08	7.7600
			281.12	7.85	0.01	7.76	41.43	262.72	5.42E-03	1.84E-04	1.83E-05	5.22E-03	4.64E-07	1.78E-08	7.7500
			281.52	7.84	0.03	7.77	40.99	262.27	5.41E-03	1.88E-04	1.79E-05	5.21E-03	4.53E-07	1.82E-08	7.7400
			281.93	7.83	0.04	7.77	40.54	261.82	5.41E-03	1.92E-04	1.75E-05	5.20E-03	4.43E-07	1.86E-08	7.7300
			282.35	7.82	0.06	7.78	40.08	261.36	5.41E-03	1.96E-04	1.70E-05	5.19E-03	4.33E-07	1.91E-08	7.7200
			282.78	7.81	0.08	7.79	39.61	260.90	5.40E-03	2.00E-04	1.66E-05	5.18E-03	4.23E-07	1.95E-08	7.7100
			283.21	7.8	0.09	7.79	39.14	260.42	5.40E-03	2.04E-04	1.62E-05	5.18E-03	4.13E-07	2.00E-08	7.7000
					0.00	7.76	41.87	263.15	5.42E-03	1.80E-04	1.88E-05	5.23E-03	4.74E-07	1.74E-08	7.7600
					0.00	7.76	41.83	263.11	5.42E-03	1.80E-04	1.88E-05	5.22E-03	4.73E-07	1.74E-08	7.7590
					0.00	7.76	41.79	263.07	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.72E-07	1.75E-08	7.7580
					0.00	7.76	41.74	263.02	5.42E-03	1.81E-04	1.87E-05	5.22E-03	4.71E-07	1.75E-08	7.7570
					0.00	7.76	41.70	262.98	5.42E-03	1.81E-04	1.86E-05	5.22E-03	4.70E-07	1.75E-08	7.7560
					0.01	7.76	41.65	262.94	5.42E-03	1.82E-04	1.86E-05	5.22E-03	4.69E-07	1.76E-08	7.7550
					0.01	7.76	41.61	262.89	5.42E-03	1.82E-04	1.85E-05	5.22E-03	4.68E-07	1.76E-08	7.7540
					0.01	7.76	41.57	262.85	5.42E-03	1.82E-04	1.85E-05	5.22E-03	4.67E-07	1.77E-08	7.7530
					0.01	7.76	41.52	262.81	5.42E-03	1.83E-04	1.84E-05	5.22E-03	4.66E-07	1.77E-08	7.7520
					0.01	7.76	41.48	262.76	5.42E-03	1.83E-04	1.84E-05	5.22E-03	4.65E-07	1.77E-08	7.7510
					0.01	7.76	41.43	262.72	5.42E-03	1.84E-04	1.83E-05	5.22E-03	4.64E-07	1.78E-08	7.7500
					0.00	7.76	41.83	263.11	5.42E-03	1.80E-04	1.88E-05	5.22E-03	4.73E-07	1.74E-08	7.7590
					0.00	7.76	41.82	263.11	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.73E-07	1.74E-08	7.7589
					0.00	7.76	41.82	263.10	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.73E-07	1.74E-08	7.7588
					0.00	7.76	41.82	263.10	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.73E-07	1.74E-08	7.7587
					0.00	7.76	41.81	263.09	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.73E-07	1.74E-08	7.7586
					0.00	7.76	41.81	263.09	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.73E-07	1.74E-08	7.7585
					0.00	7.76	41.80	263.09	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.73E-07	1.74E-08	7.7584
					0.00	7.76	41.80	263.08	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.73E-07	1.74E-08	7.7583
					0.00	7.76	41.79	263.08	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.72E-07	1.75E-08	7.7582
					0.00	7.76	41.79	263.07	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.72E-07	1.75E-08	7.7581
					0.00	7.76	41.79	263.07	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.72E-07	1.75E-08	7.7580
					0.00	7.76	41.81	263.09	5.42E-03	1.80E-04	1.87E-05	5.22E-03	4.73E-07	1.74E-08	7.7585

Tk 293
 I 0.01015
 E 80.0948
 A 0.50625
 f(l) 0.09151
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.90514
 fd 0.67122
 K1p 5.05E-07
 K2p 6.25E-11
 Kwp 8.24E-15
 Ksp 7.83E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 4 (1): EP001, EP003, EP004, & EP005

The RTW Model Ver. 4.0 ID: **Blend 3b (2)**

STEP 1: Enter initial water characteristics.

Measured TDS	383.5	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	260.56	mg/L
Measured Ca, as CaCO3	44.065	mg/L
Measured Cl	75.638	mg/L
Measured SO4	13.635	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired			
Interim alkalinity	261	mg/L	> 40	mg/L	Interim pH	7.90	6.8-9.3	
Interim Ca, as CaCO3	44	mg/L	> 40	mg/L	Precipitation potential	4.23	mg/L	4-10
Alk/(Cl+SO4)	2.9		> 5.0		Langelier index	0.17		>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	271	mg/L
Initial Ca sat, as CaCO3	30	mg/L
Initial DIC, as CaCO3	531	mg/L

Theoretical interim water characteristics

Interim acidity	271	mg/L
Interim Ca sat, as CaCO3	30	mg/L
Ryznar Index	7.57	
Interim DIC, as CaCO3	531	mg/L
Aggressiveness Index	11.96	

Theoretical final water characteristics

after CaCO3 precipitation		
Final alkalinity	256	mg/L
Final Ca	40	mg/L
Final acidity	271	mg/L
Final pH	7.79	
Final DIC, as CaCO3	527	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
[H+]	1.26E-08	1.26E-08													
[DIC]	5.31E-03	5.31E-03													
[HCO3-]	5.16E-03	5.16E-03													
[CO3-]	2.54E-05	2.54E-05	-41028.42	14	-0.16	7.74	44.07	260.56	5.31E-03	1.29E-04	2.54E-05	5.16E-03	6.52E-07	1.26E-08	7.9000
[H2CO3*]	0.000129	1.29E-04	-4105.61	13	0.86	8.23	15.73	232.23	5.03E-03	3.93E-04	6.71E-06	4.63E-03	1.92E-07	4.27E-08	7.3692
[Ca++] _s	3.03E-04	3.03E-04	-411.45	12	9.72	#####	0.00	171.94	4.43E-03	9.91E-04	1.47E-06	3.44E-03	5.66E-08	1.45E-07	6.8385
pHs alk		7.73	-24.63	11	10.52	#####	0.00	91.58	3.62E-03	1.79E-03	2.30E-07	1.83E-03	1.67E-08	4.92E-07	6.3077
			110.49	10	11.47	#####	0.00	35.34	3.06E-03	2.35E-03	2.63E-08	7.08E-04	4.91E-09	1.67E-06	5.7769
			231.99	9	12.49	#####	0.00	11.21	2.82E-03	2.59E-03	2.51E-09	2.30E-04	1.45E-09	5.67E-06	5.2462
			267.52	8	13.54	#####	0.00	2.52	2.73E-03	2.66E-03	2.24E-10	6.96E-05	4.26E-10	1.93E-05	4.7154
			363.70	7	14.60	#####	0.00	-2.24	2.69E-03	2.67E-03	1.94E-11	2.05E-05	1.26E-10	6.54E-05	4.1846
			1296.50	6	15.67	#####	0.00	-10.80	2.60E-03	2.59E-03	1.64E-12	5.88E-06	3.70E-11	2.22E-04	3.6538
			10639.27	5	16.78	#####	0.00	-37.58	2.33E-03	2.33E-03	1.28E-13	1.56E-06	1.09E-11	7.53E-04	3.1231
			105837.70	4	18.05	#####	0.00	-127.82	1.43E-03	1.43E-03	6.82E-15	2.81E-07	3.21E-12	2.56E-03	2.5923
			1234917.15	3	#####	#####	0.00	-270.87	1.73E-06	1.73E-06	7.14E-109	1.00E-100	9.45E-13	8.68E-03	2.0615
			30235232.10	2	#####	#####	0.00	-270.87	5.86E-96	5.86E-96	2.10E-109	1.00E-100	2.79E-13	2.95E-02	1.5308
			2091190430.52	1	#####	#####	0.00	-270.87	1.99E-95	1.99E-95	6.19E-110	1.00E-100	8.21E-14	1.00E-01	1.0000
			267.52	8	-0.16	7.74	44.07	260.56	5.31E-03	1.29E-04	2.54E-05	5.16E-03	6.52E-07	1.26E-08	7.9000
			270.87	7.9	-0.02	7.78	40.36	256.86	5.28E-03	1.61E-04	1.99E-05	5.10E-03	5.18E-07	1.58E-08	7.8000
			274.78	7.8	0.14	7.84	36.06	252.56	5.23E-03	1.99E-04	1.56E-05	5.02E-03	4.11E-07	2.00E-08	7.7000
			279.46	7.7	0.31	7.91	31.03	247.52	5.18E-03	2.46E-04	1.21E-05	4.93E-03	3.27E-07	2.51E-08	7.6000
			285.14	7.6	0.51	8.01	25.09	241.59	5.12E-03	3.02E-04	9.43E-06	4.81E-03	2.59E-07	3.16E-08	7.5000
			292.15	7.5	0.77	8.17	18.11	234.61	5.05E-03	3.70E-04	7.28E-06	4.68E-03	2.06E-07	3.98E-08	7.4000
			300.85	7.4	1.14	8.44	9.94	226.44	4.97E-03	4.50E-04	5.58E-06	4.52E-03	1.64E-07	5.01E-08	7.3000
			311.69	7.3	2.57	9.77	0.49	216.99	4.88E-03	5.43E-04	4.25E-06	4.33E-03	1.30E-07	6.31E-08	7.2000
			325.27	7.2	9.38	#####	0.00	206.19	4.77E-03	6.50E-04	3.21E-06	4.12E-03	1.03E-07	7.94E-08	7.1000
			342.30	7.1	9.51	#####	0.00	194.06	4.65E-03	7.70E-04	2.40E-06	3.88E-03	8.21E-08	1.00E-07	7.0000
			363.70	7	9.64	#####	0.00	180.70	4.52E-03	9.03E-04	1.78E-06	3.61E-03	6.52E-08	1.26E-07	6.9000
			270.87	7.9	-0.02	7.78	40.36	256.86	5.28E-03	1.61E-04	1.99E-05	5.10E-03	5.18E-07	1.58E-08	7.8000
			271.24	7.89	0.00	7.79	39.96	256.46	5.27E-03	1.64E-04	1.94E-05	5.09E-03	5.06E-07	1.62E-08	7.7900
			271.60	7.88	0.01	7.79	39.55	256.05	5.27E-03	1.68E-04	1.90E-05	5.08E-03	4.94E-07	1.66E-08	7.7800
			271.98	7.87	0.03	7.80	39.14	255.64	5.27E-03	1.71E-04	1.85E-05	5.08E-03	4.83E-07	1.70E-08	7.7700
			272.36	7.86	0.04	7.80	38.72	255.22	5.26E-03	1.75E-04	1.81E-05	5.07E-03	4.72E-07	1.74E-08	7.7600
			272.74	7.85	0.06	7.81	38.30	254.79	5.26E-03	1.79E-04	1.76E-05	5.06E-03	4.61E-07	1.78E-08	7.7500
			273.14	7.84	0.07	7.81	37.86	254.36	5.25E-03	1.83E-04	1.72E-05	5.05E-03	4.51E-07	1.82E-08	7.7400
			273.54	7.83	0.09	7.82	37.42	253.92	5.25E-03	1.87E-04	1.68E-05	5.04E-03	4.41E-07	1.86E-08	7.7300
			273.95	7.82	0.10	7.82	36.98	253.48	5.24E-03	1.91E-04	1.64E-05	5.04E-03	4.31E-07	1.91E-08	7.7200
			274.36	7.81	0.12	7.83	36.52	253.02	5.24E-03	1.95E-04	1.60E-05	5.03E-03	4.21E-07	1.95E-08	7.7100
			274.78	7.8	0.14	7.84	36.06	252.56	5.23E-03	1.99E-04	1.56E-05	5.02E-03	4.11E-07	2.00E-08	7.7000
					0.00	7.79	39.96	256.46	5.27E-03	1.64E-04	1.94E-05	5.09E-03	5.06E-07	1.62E-08	7.7900
					0.00	7.79	39.92	256.42	5.27E-03	1.64E-04	1.94E-05	5.09E-03	5.05E-07	1.63E-08	7.7890
					0.00	7.79	39.88	256.38	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.04E-07	1.63E-08	7.7880
					0.00	7.79	39.84	256.34	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.63E-08	7.7870
					0.00	7.79	39.80	256.30	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.01E-07	1.64E-08	7.7860
					0.00	7.79	39.76	256.26	5.27E-03	1.66E-04	1.92E-05	5.09E-03	5.00E-07	1.64E-08	7.7850
					0.00	7.79	39.72	256.22	5.27E-03	1.66E-04	1.92E-05	5.09E-03	4.99E-07	1.64E-08	7.7840
					0.01	7.79	39.68	256.18	5.27E-03	1.67E-04	1.91E-05	5.08E-03	4.98E-07	1.65E-08	7.7830
					0.01	7.79	39.63	256.13	5.27E-03	1.67E-04	1.91E-05	5.08E-03	4.97E-07	1.65E-08	7.7820
					0.01	7.79	39.59	256.09	5.27E-03	1.67E-04	1.90E-05	5.08E-03	4.96E-07	1.66E-08	7.7810
					0.01	7.79	39.55	256.05	5.27E-03	1.68E-04	1.90E-05	5.08E-03	4.94E-07	1.66E-08	7.7800
					0.00	7.79	39.84	256.34	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.63E-08	7.7870
					0.00	7.79	39.83	256.33	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.63E-08	7.7869
					0.00	7.79	39.83	256.33	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.63E-08	7.7868
					0.00	7.79	39.83	256.33	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.63E-08	7.7867
					0.00	7.79	39.82	256.32	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.63E-08	7.7866
					0.00	7.79	39.82	256.32	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.63E-08	7.7865
					0.00	7.79	39.81	256.31	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.64E-08	7.7864
					0.00	7.79	39.81	256.31	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.64E-08	7.7863
					0.00	7.79	39.81	256.31	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.64E-08	7.7862
					0.00	7.79	39.80	256.30	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.01E-07	1.64E-08	7.7861
					0.00	7.79	39.80	256.30	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.01E-07	1.64E-08	7.7860
					0.00	7.79	39.83	256.33	5.27E-03	1.65E-04	1.93E-05	5.09E-03	5.02E-07	1.63E-08	7.7869

Tk 293
 I 0.00959
 E 80.0948
 A 0.50625
 f(l) 0.08918
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.90725
 fd 0.6775
 K1p 5.03E-07
 K2p 6.19E-11
 Kwp 8.21E-15
 Ksp 7.68E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 4 (2): EP001, EP003, EP004, & EP005

STEP 1: Enter initial water characteristics.

Measured TDS	369.7	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	266.38	mg/L
Measured Ca, as CaCO3	54.529	mg/L
Measured Cl	67.58	mg/L
Measured SO4	13.935	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired			
Interim alkalinity	266	mg/L	> 40	mg/L	Interim pH	7.90	6.8-9.3	
Interim Ca, as CaCO3	55	mg/L	> 40	mg/L	Precipitation potential	7.73	mg/L	4-10
Alk/(Cl+SO4)	3.3		> 5.0		Langelier index	0.27		>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	277	mg/L
Initial Ca sat, as CaCO3	29	mg/L
Initial DIC, as CaCO3	543	mg/L

Theoretical interim water characteristics

Interim acidity	277	mg/L
Interim Ca sat, as CaCO3	29	mg/L
Ryznar Index	7.36	
Interim DIC, as CaCO3	543	mg/L
Aggressiveness Index	12.06	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	259	mg/L
Final Ca	47	mg/L
Final acidity	277	mg/L
Final pH	7.71	
Final DIC, as CaCO3	536	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim	Interim	Delta	Final	Final	Final	Final	Final	Final	Final	Final	Final	Final
			Acid, mg/l	pH	pH	pH	Ca	Alk	[DIC]	[H2CO3*]	[CO3--]	[HCO3-]	{OH-}	{H+}	pH
							mg CaCO3/L	mg CaCO3/L							
{H+}	1.26E-08	1.26E-08													
[DIC]	5.43E-03	5.43E-03													
[HCO3-]	5.28E-03	5.28E-03													
[CO3-]	2.58E-05	2.58E-05	-40906.80	14	-0.27	7.63	54.53	266.38	5.43E-03	1.32E-04	2.58E-05	5.28E-03	6.50E-07	1.26E-08	7.9000
[H2CO3*]	0.000132	1.32E-04	-4093.45	13	0.64	8.01	25.50	237.35	5.14E-03	4.03E-04	6.82E-06	4.73E-03	1.91E-07	4.27E-08	7.3692
{Ca++}s	2.94E-04	2.94E-04	-410.18	12	9.71	#####	0.00	175.63	4.53E-03	1.01E-03	1.49E-06	3.51E-03	5.64E-08	1.45E-07	6.8385
pHs alk		7.63	-23.97	11	10.51	#####	0.00	93.46	3.70E-03	1.83E-03	2.34E-07	1.87E-03	1.66E-08	4.92E-07	6.3077
			113.49	10	11.46	#####	0.00	36.05	3.13E-03	2.41E-03	2.66E-08	7.23E-04	4.89E-09	1.67E-06	5.7769
			237.34	9	12.48	#####	0.00	11.43	2.88E-03	2.65E-03	2.54E-09	2.34E-04	1.44E-09	5.67E-06	5.2462
			273.55	8	13.52	#####	0.00	2.59	2.80E-03	2.72E-03	2.27E-10	7.10E-05	4.25E-10	1.93E-05	4.7154
			372.13	7	14.59	#####	0.00	-2.22	2.75E-03	2.73E-03	1.97E-11	2.09E-05	1.25E-10	6.54E-05	4.1846
			1328.58	6	15.66	#####	0.00	-10.79	2.66E-03	2.66E-03	1.67E-12	6.00E-06	3.89E-11	2.22E-04	3.6538
			10907.81	5	16.77	#####	0.00	-37.58	2.39E-03	2.39E-03	1.30E-13	1.59E-06	1.09E-11	7.53E-04	3.1231
			108476.03	4	18.03	#####	0.00	-127.82	1.49E-03	1.49E-03	7.05E-15	2.93E-07	3.20E-12	2.56E-03	2.5923
			1261780.05	3	#####	#####	0.00	-276.98	1.73E-96	1.73E-96	7.10E-109	1.00E-100	9.43E-13	8.68E-03	2.0615
			30557000.64	2	#####	#####	0.00	-276.98	5.87E-96	5.87E-96	2.09E-109	1.00E-100	2.78E-13	2.95E-02	1.5308
			2099727242.10	1	#####	#####	0.00	-276.98	1.99E-95	1.99E-95	6.16E-110	1.00E-100	8.18E-14	1.00E-01	1.0000
			273.55	8	-0.27	7.63	54.53	266.38	5.43E-03	1.32E-04	2.58E-05	5.28E-03	6.50E-07	1.26E-08	7.9000
			276.98	7.9	-0.13	7.67	50.74	262.59	5.40E-03	1.65E-04	2.02E-05	5.21E-03	5.16E-07	1.58E-08	7.8000
			280.98	7.8	0.01	7.71	46.34	258.19	5.35E-03	2.04E-04	1.58E-05	5.14E-03	4.19E-07	1.95E-08	7.7099
			285.77	7.7	0.17	7.77	41.17	253.02	5.30E-03	2.52E-04	1.23E-05	5.04E-03	3.26E-07	2.51E-08	7.6000
			291.60	7.6	0.35	7.85	35.09	246.94	5.24E-03	3.10E-04	9.58E-06	4.92E-03	2.59E-07	3.16E-08	7.5000
			298.78	7.5	0.57	7.97	27.94	239.79	5.17E-03	3.79E-04	7.40E-06	4.78E-03	2.05E-07	3.98E-08	7.4000
			307.69	7.4	0.84	8.14	19.57	231.42	5.08E-03	4.61E-04	5.67E-06	4.62E-03	1.63E-07	5.01E-08	7.3000
			318.81	7.3	1.25	8.45	9.89	221.74	4.99E-03	5.57E-04	4.32E-06	4.43E-03	1.30E-07	6.31E-08	7.2000
			332.73	7.2	9.37	#####	0.00	210.68	4.88E-03	6.66E-04	3.26E-06	4.21E-03	1.03E-07	7.94E-08	7.1000
			350.20	7.1	9.49	#####	0.00	198.27	4.75E-03	7.90E-04	2.44E-06	3.96E-03	8.18E-08	1.00E-07	7.0000
			372.13	7	9.62	#####	0.00	184.59	4.62E-03	9.26E-04	1.80E-06	3.69E-03	6.50E-08	1.26E-07	6.9000
			276.98	7.9	-0.13	7.67	50.74	262.59	5.40E-03	1.65E-04	2.02E-05	5.21E-03	5.16E-07	1.58E-08	7.8000
			277.35	7.89	-0.12	7.67	50.33	262.18	5.39E-03	1.68E-04	1.98E-05	5.20E-03	5.04E-07	1.62E-08	7.7900
			277.72	7.88	-0.10	7.68	49.91	261.76	5.39E-03	1.72E-04	1.93E-05	5.20E-03	4.93E-07	1.66E-08	7.7800
			278.11	7.87	-0.09	7.68	49.49	261.34	5.38E-03	1.76E-04	1.88E-05	5.19E-03	4.82E-07	1.70E-08	7.7700
			278.50	7.86	-0.07	7.69	49.06	260.91	5.38E-03	1.79E-04	1.84E-05	5.18E-03	4.71E-07	1.74E-08	7.7600
			278.89	7.85	-0.06	7.69	48.62	260.47	5.37E-03	1.83E-04	1.79E-05	5.17E-03	4.60E-07	1.78E-08	7.7500
			279.29	7.84	-0.04	7.70	48.18	260.03	5.37E-03	1.87E-04	1.75E-05	5.17E-03	4.50E-07	1.82E-08	7.7400
			279.70	7.83	-0.03	7.70	47.73	259.58	5.37E-03	1.91E-04	1.71E-05	5.16E-03	4.39E-07	1.86E-08	7.7300
			280.12	7.82	-0.02	7.70	47.27	259.12	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.29E-07	1.91E-08	7.7200
			280.55	7.81	0.00	7.71	46.81	258.66	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.20E-07	1.95E-08	7.7100
			280.98	7.8	0.01	7.71	46.34	258.19	5.35E-03	2.04E-04	1.58E-05	5.13E-03	4.10E-07	2.00E-08	7.7000
					0.00	7.71	46.81	258.66	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.20E-07	1.95E-08	7.7100
					0.00	7.71	46.76	258.61	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7099
					0.00	7.71	46.71	258.56	5.36E-03	2.01E-04	1.62E-05	5.14E-03	4.18E-07	1.96E-08	7.7080
					0.00	7.71	46.67	258.52	5.35E-03	2.01E-04	1.61E-05	5.14E-03	4.17E-07	1.96E-08	7.7070
					0.01	7.71	46.62	258.47	5.35E-03	2.02E-04	1.61E-05	5.14E-03	4.16E-07	1.97E-08	7.7060
					0.01	7.71	46.57	258.42	5.35E-03	2.02E-04	1.60E-05	5.14E-03	4.15E-07	1.97E-08	7.7050
					0.01	7.71	46.52	258.38	5.35E-03	2.02E-04	1.60E-05	5.14E-03	4.14E-07	1.98E-08	7.7040
					0.01	7.71	46.48	258.33	5.35E-03	2.03E-04	1.60E-05	5.13E-03	4.13E-07	1.98E-08	7.7030
					0.01	7.71	46.43	258.28	5.35E-03	2.03E-04	1.59E-05	5.13E-03	4.12E-07	1.99E-08	7.7020
					0.01	7.71	46.38	258.23	5.35E-03	2.04E-04	1.59E-05	5.13E-03	4.11E-07	1.99E-08	7.7010
					0.01	7.71	46.34	258.19	5.35E-03	2.04E-04	1.58E-05	5.13E-03	4.10E-07	2.00E-08	7.7000
					0.00	7.71	46.81	258.66	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.20E-07	1.95E-08	7.7100
					0.00	7.71	46.80	258.65	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7099
					0.00	7.71	46.80	258.65	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7098
					0.00	7.71	46.79	258.64	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7097
					0.00	7.71	46.79	258.64	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7096
					0.00	7.71	46.78	258.63	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7095
					0.00	7.71	46.78	258.63	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7094
					0.00	7.71	46.77	258.63	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7093
					0.00	7.71	46.77	258.62	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7092
					0.00	7.71	46.76	258.62	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7091
					0.00	7.71	46.76	258.61	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7090
					0.00	7.71	46.80	258.65	5.36E-03	2.00E-04	1.62E-05	5.14E-03	4.19E-07	1.95E-08	7.7099

Tk 293
 I 0.00924
 E 80.0948
 A 0.50625
 f(l) 0.08771
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.9086
 fd 0.68153
 K1p 5.02E-07
 K2p 6.16E-11
 Kwp 8.18E-15
 Ksp 7.59E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model

Blend 5 (1): EP001, EP002, EP003, EP004, & EP005

The RTW Model Ver. 4.0 ID: **Blend 4 (2)**

STEP 1: Enter initial water characteristics.

Measured TDS	367.33	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	265.38	mg/L
Measured Ca, as CaCO3	52.824	mg/L
Measured Cl	65.787	mg/L
Measured SO4	14.012	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired
Interim alkalinity	265	mg/L	> 40	mg/L	
Interim Ca, as CaCO3	53	mg/L	> 40	mg/L	
Alk/(Cl+SO4)	3.3		> 5.0		
			Interim pH	7.90	6.8-9.3
			Precipitation potential	7.18	mg/L
			Langelier index	0.26	>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	276	mg/L
Initial Ca sat, as CaCO3	30	mg/L
Initial DIC, as CaCO3	541	mg/L

Theoretical interim water characteristics

Interim acidity	276	mg/L
Interim Ca sat, as CaCO3	30	mg/L
Ryznar Index	7.39	
Interim DIC, as CaCO3	541	mg/L
Aggressiveness Index	12.05	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	258	mg/L
Final Ca	46	mg/L
Final acidity	276	mg/L
Final pH	7.72	
Final DIC, as CaCO3	534	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
(H+)	1.26E-08	1.26E-08													
[DIC]	5.41E-03	5.41E-03													
[HCO3-]	5.26E-03	5.26E-03													
[CO3-]	2.57E-05	2.57E-05	-40885.70	14	-0.25	7.65	52.82	265.38	5.41E-03	1.32E-04	2.57E-05	5.26E-03	6.49E-07	1.26E-08	7.9000
[H2CO3*]	0.000132	1.32E-04	-4091.34	13	0.67	8.04	23.89	236.45	5.12E-03	4.02E-04	6.79E-06	4.72E-03	1.91E-07	4.27E-08	7.3692
[Ca++] _s	2.95E-04	2.95E-04	-409.98	12	9.71	#####	0.00	174.94	4.51E-03	1.01E-03	1.48E-06	3.50E-03	5.64E-08	1.45E-07	6.8385
pHs alk		7.64	-24.01	11	10.51	#####	0.00	93.09	3.69E-03	1.83E-03	2.33E-07	1.86E-03	1.66E-08	4.92E-07	6.3077
			113.11	10	11.46	#####	0.00	35.90	3.12E-03	2.40E-03	2.65E-08	7.20E-04	4.89E-09	1.67E-06	5.7769
			236.48	9	12.48	#####	0.00	11.38	2.87E-03	2.64E-03	2.53E-09	2.33E-04	1.44E-09	5.67E-06	5.2462
			272.53	8	13.53	#####	0.00	2.57	2.79E-03	2.71E-03	2.26E-10	7.07E-05	4.25E-10	1.93E-05	4.7154
			370.79	7	14.59	#####	0.00	-2.23	2.74E-03	2.72E-03	1.96E-11	2.08E-05	1.25E-10	6.54E-05	4.1846
			1324.16	6	15.66	#####	0.00	-10.80	2.65E-03	2.65E-03	1.66E-12	5.98E-06	3.68E-11	2.22E-04	3.6538
			10872.58	5	16.77	#####	0.00	-37.58	2.38E-03	2.38E-03	1.30E-13	1.59E-06	1.09E-11	7.53E-04	3.1231
			108133.61	4	18.04	#####	0.00	-127.82	1.48E-03	1.48E-03	6.99E-15	2.90E-07	3.20E-12	2.56E-03	2.5923
			1258457.35	3	#####	#####	0.00	-275.95	1.73E-06	1.73E-06	7.09E-109	1.00E-100	9.42E-13	8.68E-03	2.0615
			30533039.56	2	#####	#####	0.00	-275.95	5.88E-06	5.88E-06	2.09E-109	1.00E-100	2.78E-13	2.95E-02	1.5308
			2100413340.75	1	#####	#####	0.00	-275.95	1.99E-05	1.99E-05	6.15E-110	1.00E-100	8.18E-14	1.00E-01	1.0000
			272.53	8	-0.25	7.65	52.82	265.38	5.41E-03	1.32E-04	2.57E-05	5.26E-03	6.49E-07	1.26E-08	7.9000
			275.95	7.9	-0.12	7.68	49.04	261.60	5.38E-03	1.64E-04	2.02E-05	5.19E-03	5.16E-07	1.58E-08	7.8000
			279.94	7.8	0.03	7.73	44.66	257.22	5.33E-03	2.03E-04	1.58E-05	5.11E-03	4.10E-07	2.00E-08	7.7000
			284.71	7.7	0.19	7.79	39.51	252.07	5.28E-03	2.51E-04	1.23E-05	5.02E-03	3.26E-07	2.51E-08	7.6000
			290.52	7.6	0.38	7.88	33.45	246.01	5.22E-03	3.09E-04	9.53E-06	4.90E-03	2.59E-07	3.16E-08	7.5000
			297.68	7.5	0.59	7.99	26.32	238.88	5.15E-03	3.78E-04	7.36E-06	4.76E-03	2.05E-07	3.98E-08	7.4000
			306.56	7.4	0.87	8.17	17.99	230.55	5.06E-03	4.60E-04	5.65E-06	4.60E-03	1.63E-07	5.01E-08	7.3000
			317.65	7.3	1.33	8.53	8.34	220.90	4.97E-03	5.55E-04	4.30E-06	4.41E-03	1.30E-07	6.31E-08	7.2000
			331.53	7.2	9.37	#####	0.00	209.88	4.86E-03	6.64E-04	3.25E-06	4.19E-03	1.03E-07	7.94E-08	7.1000
			348.93	7.1	9.49	#####	0.00	197.50	4.73E-03	7.87E-04	2.43E-06	3.95E-03	8.18E-08	1.00E-07	7.0000
			370.79	7	9.63	#####	0.00	183.87	4.60E-03	9.23E-04	1.80E-06	3.67E-03	6.49E-08	1.26E-07	6.9000
			275.95	7.9	-0.12	7.68	49.04	261.60	5.38E-03	1.64E-04	2.02E-05	5.19E-03	5.16E-07	1.58E-08	7.8000
			276.32	7.89	-0.10	7.69	48.63	261.20	5.37E-03	1.68E-04	1.97E-05	5.18E-03	5.04E-07	1.62E-08	7.7900
			276.69	7.88	-0.09	7.69	48.22	260.78	5.37E-03	1.71E-04	1.92E-05	5.18E-03	4.93E-07	1.66E-08	7.7800
			277.08	7.87	-0.07	7.70	47.80	260.36	5.36E-03	1.75E-04	1.87E-05	5.17E-03	4.81E-07	1.70E-08	7.7700
			277.46	7.86	-0.06	7.70	47.37	259.93	5.36E-03	1.79E-04	1.83E-05	5.16E-03	4.71E-07	1.74E-08	7.7600
			277.86	7.85	-0.04	7.71	46.94	259.50	5.35E-03	1.83E-04	1.78E-05	5.15E-03	4.60E-07	1.78E-08	7.7500
			278.26	7.84	-0.03	7.71	46.49	259.06	5.35E-03	1.87E-04	1.74E-05	5.15E-03	4.49E-07	1.82E-08	7.7400
			278.67	7.83	-0.01	7.72	46.05	258.61	5.35E-03	1.91E-04	1.70E-05	5.14E-03	4.39E-07	1.86E-08	7.7300
			279.08	7.82	0.00	7.72	45.59	258.15	5.34E-03	1.95E-04	1.66E-05	5.13E-03	4.29E-07	1.91E-08	7.7200
			279.51	7.81	0.02	7.73	45.13	257.69	5.34E-03	1.99E-04	1.62E-05	5.12E-03	4.19E-07	1.95E-08	7.7100
			279.94	7.8	0.03	7.73	44.66	257.22	5.33E-03	2.03E-04	1.58E-05	5.11E-03	4.10E-07	2.00E-08	7.7000
					-0.01	7.72	46.05	258.61	5.35E-03	1.91E-04	1.70E-05	5.14E-03	4.39E-07	1.86E-08	7.7300
					-0.01	7.72	46.00	258.56	5.35E-03	1.91E-04	1.69E-05	5.14E-03	4.38E-07	1.87E-08	7.7290
					-0.01	7.72	45.96	258.52	5.34E-03	1.92E-04	1.69E-05	5.14E-03	4.37E-07	1.87E-08	7.7280
					-0.01	7.72	45.91	258.47	5.34E-03	1.92E-04	1.68E-05	5.14E-03	4.36E-07	1.87E-08	7.7270
					-0.01	7.72	45.87	258.43	5.34E-03	1.92E-04	1.68E-05	5.13E-03	4.35E-07	1.88E-08	7.7260
					-0.01	7.72	45.82	258.38	5.34E-03	1.93E-04	1.68E-05	5.13E-03	4.34E-07	1.88E-08	7.7250
					0.00	7.72	45.77	258.33	5.34E-03	1.93E-04	1.67E-05	5.13E-03	4.33E-07	1.89E-08	7.7240
					0.00	7.72	45.73	258.29	5.34E-03	1.94E-04	1.67E-05	5.13E-03	4.32E-07	1.89E-08	7.7230
					0.00	7.72	45.68	258.24	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.31E-07	1.90E-08	7.7220
					0.00	7.72	45.64	258.20	5.34E-03	1.95E-04	1.66E-05	5.13E-03	4.30E-07	1.90E-08	7.7210
					0.00	7.72	45.59	258.15	5.34E-03	1.95E-04	1.66E-05	5.13E-03	4.29E-07	1.91E-08	7.7200
					0.00	7.72	45.68	258.24	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.31E-07	1.90E-08	7.7220
					0.00	7.72	45.68	258.24	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.31E-07	1.90E-08	7.7219
					0.00	7.72	45.67	258.23	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.31E-07	1.90E-08	7.7218
					0.00	7.72	45.67	258.23	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.31E-07	1.90E-08	7.7217
					0.00	7.72	45.66	258.22	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.31E-07	1.90E-08	7.7216
					0.00	7.72	45.66	258.22	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.31E-07	1.90E-08	7.7215
					0.00	7.72	45.66	258.22	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.30E-07	1.90E-08	7.7214
					0.00	7.72	45.65	258.21	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.30E-07	1.90E-08	7.7213
					0.00	7.72	45.65	258.21	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.30E-07	1.90E-08	7.7212
					0.00	7.72	45.64	258.20	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.30E-07	1.90E-08	7.7211
					0.00	7.72	45.64	258.20	5.34E-03	1.95E-04	1.66E-05	5.13E-03	4.30E-07	1.90E-08	7.7210
					0.00	7.72	45.64	258.20	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.30E-07	1.90E-08	7.7211
					0.00	7.72	45.64	258.20	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.30E-07	1.90E-08	7.7210
					0.00	7.72	45.64	258.20	5.34E-03	1.94E-04	1.66E-05	5.13E-03	4.30E-07	1.90E-08	7.7211

Tk 293
 I 0.00918
 E 80.0948
 A 0.50625
 f(l) 0.08745
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.90883
 fd 0.68224
 K1p 5.01E-07
 K2p 6.15E-11
 Kwp 8.18E-15
 Ksp 7.58E-09

		Forms of CaCO ₃ and their solubility product constants			
Form #		1	2	3	4
Preferred		Calcite	Aragonite	Vaterite	General
1		3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

RTW Model
**Blend 5 (2): EP001, EP002, EP003,
EP004, & EP005**

STEP 1: Enter initial water characteristics.

Measured TDS	373.54	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	266.32	mg/L
Measured Ca, as CaCO3	53.14	mg/L
Measured Cl	68.68	mg/L
Measured SO4	13.99	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics		Desired	Theoretical interim water characteristics		Desired			
Interim alkalinity	266	mg/L	> 40	mg/L	Interim pH	7.90	6.8-9.3	
Interim Ca, as CaCO3	53	mg/L	> 40	mg/L	Precipitation potential	7.30	mg/L	4-10
Alk/(Cl+SO4)	3.2		> 5.0		Langelier index	0.26		>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	277	mg/L
Initial Ca sat, as CaCO3	29	mg/L
Initial DIC, as CaCO3	543	mg/L

Theoretical interim water characteristics

Interim acidity	277	mg/L
Interim Ca sat, as CaCO3	29	mg/L
Ryznar Index	7.38	
Interim DIC, as CaCO3	543	mg/L
Aggressiveness Index	12.05	

Theoretical final water characteristics after CaCO3 precipitation

Final alkalinity	259	mg/L
Final Ca	46	mg/L
Final acidity	277	mg/L
Final pH	7.72	
Final DIC, as CaCO3	536	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
(H+)	1.26E-08	1.26E-08													
[DIC]	5.43E-03	5.43E-03													
[HCO3-]	5.27E-03	5.27E-03													
[CO3-]	2.58E-05	2.58E-05	-40940.93	14	-0.26	7.64	53.14	266.32	5.43E-03	1.32E-04	2.58E-05	5.27E-03	6.50E-07	1.26E-08	7.9000
[H2CO3*]	0.000132	1.32E-04	-4096.86	13	0.66	8.03	24.13	237.31	5.14E-03	4.03E-04	6.83E-06	4.73E-03	1.92E-07	4.27E-08	7.3692
[Ca++] _s	2.95E-04	2.95E-04	-410.53	12	9.71	#####	0.00	175.63	4.53E-03	1.01E-03	1.49E-06	3.51E-03	5.64E-08	1.45E-07	6.8385
pHs alk		7.64	-24.04	11	10.51	#####	0.00	93.49	3.70E-03	1.83E-03	2.34E-07	1.87E-03	1.66E-08	4.92E-07	6.3077
			113.35	10	11.46	#####	0.00	36.06	3.13E-03	2.41E-03	2.67E-08	7.23E-04	4.90E-09	1.67E-06	5.7769
			237.24	9	12.48	#####	0.00	11.44	2.88E-03	2.65E-03	2.55E-09	2.34E-04	1.44E-09	5.67E-06	5.2462
			273.47	8	13.53	#####	0.00	2.59	2.79E-03	2.72E-03	2.27E-10	7.10E-05	4.25E-10	1.93E-05	4.7154
			371.96	7	14.59	#####	0.00	-2.22	2.75E-03	2.73E-03	1.98E-11	2.09E-05	1.25E-10	6.54E-05	4.1846
			1327.39	6	15.66	#####	0.00	-10.79	2.66E-03	2.66E-03	1.67E-12	6.01E-06	3.69E-11	2.22E-04	3.6538
			10896.48	5	16.77	#####	0.00	-37.58	2.39E-03	2.39E-03	1.31E-13	1.59E-06	1.09E-11	7.53E-04	3.1231
			108361.84	4	18.03	#####	0.00	-127.82	1.49E-03	1.49E-03	7.06E-15	2.93E-07	3.20E-12	2.56E-03	2.5923
			1260489.02	3	#####	#####	0.00	-276.90	1.73E-06	1.73E-06	7.11E-109	1.00E-100	9.43E-13	8.68E-03	2.0615
			30529128.38	2	#####	#####	0.00	-276.90	5.87E-06	5.87E-06	2.09E-109	1.00E-100	2.78E-13	2.95E-02	1.5308
			2097952278.87	1	#####	#####	0.00	-276.90	1.99E-05	1.99E-05	6.17E-110	1.00E-100	8.19E-14	1.00E-01	1.0000
			273.47	8	-0.26	7.64	53.14	266.32	5.43E-03	1.32E-04	2.58E-05	5.27E-03	6.50E-07	1.26E-08	7.9000
			276.90	7.9	-0.12	7.68	49.35	262.53	5.39E-03	1.64E-04	2.03E-05	5.21E-03	5.17E-07	1.58E-08	7.8000
			280.90	7.8	0.03	7.73	44.95	258.13	5.35E-03	2.04E-04	1.59E-05	5.13E-03	4.10E-07	2.00E-08	7.7000
			285.68	7.7	0.19	7.79	39.79	252.97	5.30E-03	2.52E-04	1.24E-05	5.03E-03	3.26E-07	2.51E-08	7.6000
			291.51	7.6	0.37	7.87	33.72	246.90	5.24E-03	3.10E-04	9.59E-06	4.92E-03	2.59E-07	3.16E-08	7.5000
			298.68	7.5	0.59	7.99	26.57	239.75	5.17E-03	3.79E-04	7.41E-06	4.78E-03	2.06E-07	3.98E-08	7.4000
			307.59	7.4	0.87	8.17	18.21	231.39	5.08E-03	4.61E-04	5.68E-06	4.62E-03	1.63E-07	5.01E-08	7.3000
			318.70	7.3	1.31	8.51	8.54	221.72	4.99E-03	5.56E-04	4.33E-06	4.43E-03	1.30E-07	6.31E-08	7.2000
			332.60	7.2	9.37	#####	0.00	210.67	4.88E-03	6.66E-04	3.27E-06	4.21E-03	1.03E-07	7.94E-08	7.1000
			350.05	7.1	9.49	#####	0.00	198.26	4.75E-03	7.89E-04	2.44E-06	3.96E-03	8.19E-08	1.00E-07	7.0000
			371.96	7	9.62	#####	0.00	184.59	4.61E-03	9.25E-04	1.81E-06	3.69E-03	6.50E-08	1.26E-07	6.9000
			276.90	7.9	-0.12	7.68	49.35	262.53	5.39E-03	1.64E-04	2.03E-05	5.21E-03	5.17E-07	1.58E-08	7.8000
			277.27	7.89	-0.10	7.69	48.94	262.12	5.39E-03	1.68E-04	1.98E-05	5.20E-03	5.05E-07	1.62E-08	7.7900
			277.64	7.88	-0.09	7.69	48.52	261.70	5.39E-03	1.72E-04	1.93E-05	5.19E-03	4.93E-07	1.66E-08	7.7800
			278.03	7.87	-0.08	7.69	48.10	261.28	5.38E-03	1.75E-04	1.88E-05	5.19E-03	4.82E-07	1.70E-08	7.7700
			278.42	7.86	-0.06	7.70	47.67	260.85	5.38E-03	1.79E-04	1.84E-05	5.18E-03	4.71E-07	1.74E-08	7.7600
			278.81	7.85	-0.05	7.70	47.24	260.42	5.37E-03	1.83E-04	1.79E-05	5.17E-03	4.60E-07	1.78E-08	7.7500
			279.22	7.84	-0.03	7.71	46.79	259.97	5.37E-03	1.87E-04	1.75E-05	5.16E-03	4.50E-07	1.82E-08	7.7400
			279.62	7.83	-0.02	7.71	46.34	259.52	5.36E-03	1.91E-04	1.71E-05	5.16E-03	4.40E-07	1.86E-08	7.7300
			280.04	7.82	0.00	7.72	45.89	259.07	5.36E-03	1.95E-04	1.67E-05	5.15E-03	4.30E-07	1.91E-08	7.7200
			280.46	7.81	0.01	7.72	45.42	258.60	5.36E-03	2.00E-04	1.63E-05	5.14E-03	4.20E-07	1.95E-08	7.7100
			280.90	7.8	0.03	7.73	44.95	258.13	5.35E-03	2.04E-04	1.59E-05	5.13E-03	4.10E-07	2.00E-08	7.7000
					0.00	7.72	45.89	259.07	5.36E-03	1.95E-04	1.67E-05	5.15E-03	4.30E-07	1.91E-08	7.7200
					0.00	7.72	45.84	259.02	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.29E-07	1.91E-08	7.7190
					0.00	7.72	45.80	258.98	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.28E-07	1.91E-08	7.7180
					0.00	7.72	45.75	258.93	5.36E-03	1.97E-04	1.65E-05	5.15E-03	4.27E-07	1.92E-08	7.7170
					0.00	7.72	45.70	258.88	5.36E-03	1.97E-04	1.65E-05	5.14E-03	4.26E-07	1.92E-08	7.7160
					0.01	7.72	45.66	258.84	5.36E-03	1.97E-04	1.65E-05	5.14E-03	4.25E-07	1.93E-08	7.7150
					0.01	7.72	45.61	258.79	5.36E-03	1.98E-04	1.64E-05	5.14E-03	4.24E-07	1.93E-08	7.7140
					0.01	7.72	45.56	258.74	5.36E-03	1.98E-04	1.64E-05	5.14E-03	4.23E-07	1.94E-08	7.7130
					0.01	7.72	45.52	258.70	5.36E-03	1.99E-04	1.63E-05	5.14E-03	4.22E-07	1.94E-08	7.7120
					0.01	7.72	45.47	258.65	5.36E-03	1.99E-04	1.63E-05	5.14E-03	4.21E-07	1.95E-08	7.7110
					0.01	7.72	45.42	258.60	5.36E-03	2.00E-04	1.63E-05	5.14E-03	4.20E-07	1.95E-08	7.7100
					0.00	7.72	45.84	259.02	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.29E-07	1.91E-08	7.7190
					0.00	7.72	45.84	259.02	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.29E-07	1.91E-08	7.7189
					0.00	7.72	45.83	259.01	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.29E-07	1.91E-08	7.7188
					0.00	7.72	45.83	259.01	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.28E-07	1.91E-08	7.7187
					0.00	7.72	45.82	259.00	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.28E-07	1.91E-08	7.7186
					0.00	7.72	45.82	259.00	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.28E-07	1.91E-08	7.7185
					0.00	7.72	45.81	258.99	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.28E-07	1.91E-08	7.7184
					0.00	7.72	45.81	258.99	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.28E-07	1.91E-08	7.7183
					0.00	7.72	45.80	258.98	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.28E-07	1.91E-08	7.7182
					0.00	7.72	45.80	258.98	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.28E-07	1.91E-08	7.7181
					0.00	7.72	45.80	258.98	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.28E-07	1.91E-08	7.7180
					0.00	7.72	45.84	259.02	5.36E-03	1.96E-04	1.66E-05	5.15E-03	4.29E-07	1.91E-08	7.7190

Tk 293
 I 0.00934
 E 80.0948
 A 0.50625
 f(l) 0.08812
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.90822
 fd 0.6804
 K1p 5.02E-07
 K2p 6.17E-11
 Kwp 8.19E-15
 Ksp 7.62E-09

Forms of CaCO3 and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6

Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
n	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					

* See User's Manual for information on user specified chemicals

The RTW Model Ver. 4.0 ID: **Blend 5 (2)**

STEP 1: Enter initial water characteristics.

Measured TDS	368.15	mg/L
Measured temperature	20	deg C
Measured pH	7.9	
Measured alk, as CaCO3	262.85	mg/L
Measured Ca, as CaCO3	50.656	mg/L
Measured Cl	66	mg/L
Measured SO4	14.01	mg/L

For CT and TTHM functions enter current:

Treated water pH	7.9	
Chlorine residual		mg/L
Chlorine or hypochlorite dose as chlorine equivalent		mg/L

STEP 2: Enter amount of each chemical to be added (expressed as 100% chemical). Press Ctrl+C to select chemicals for this list.

Alum *14H2O	0	mg/L
Carbon dioxide	0	mg/L
Caustic soda	0	mg/L
Chlorine gas	0	mg/L
Ferric chloride (anhydrous)	0	mg/L
Ferrous sulfate *7H2O	0	mg/L
Hydrochloric acid	0	mg/L
Hydrofluosilicic acid	0	mg/L
Lime (slaked)	0	mg/L
Sulfuric Acid	0	mg/L

STEP 3: Adjust at Step 2 until interim water characteristics meet your criteria.

Theoretical interim water characteristics	Desired	Theoretical interim water characteristics	Desired		
Interim alkalinity	263 mg/L	> 40 mg/L	Interim pH	7.90	6.8-9.3
Interim Ca, as CaCO3	51 mg/L	> 40 mg/L	Precipitation potential	6.38 mg/L	4-10 mg/L
Alk/(Cl+SO4)	3.3	> 5.0	Langelier index	0.23	>0

Press PAGE DOWN for additional initial, interim and final water characteristics if desired.

Calculated initial water characteristics

Initial acidity	273	mg/L
Initial Ca sat, as CaCO3	30	mg/L
Initial DIC, as CaCO3	536	mg/L

Theoretical interim water characteristics

Interim acidity	273	mg/L
Interim Ca sat, as CaCO3	30	mg/L
Ryznar Index	7.43	
Interim DIC, as CaCO3	536	mg/L
Aggressiveness Index	12.02	

Theoretical final water characteristics

after CaCO3 precipitation		
Final alkalinity	256	mg/L
Final Ca	44	mg/L
Final acidity	273	mg/L
Final pH	7.74	
Final DIC, as CaCO3	530	mg/L

Press PAGE UP to review measured initial water characteristics, chemical addition quantities and additional interim water characteristics.

CT and TTHM Results

Required chlorine residual to maintain current level of giardia inactivation	N/A	mg/L
Estimated maximum total trihalomethane concentration change from current level	N/A	%

	Initial	Interim	Interim Acid, mg/l	Interim pH	Delta pH	Final pH	Final Ca mg CaCO3/L	Final Alk mg CaCO3/L	[DIC]	Final [H2CO3*]	Final [CO3--]	Final [HCO3-]	Final [OH-]	Final [H+]	Final pH
(H+)	1.26E-08	1.26E-08													
[DIC]	5.36E-03	5.36E-03													
[HCO3-]	5.21E-03	5.21E-03													
[CO3-]	2.54E-05	2.54E-05	-40893.04	14	-0.23	7.67	50.66	262.85	5.36E-03	1.31E-04	2.54E-05	5.21E-03	6.50E-07	1.26E-08	7.9000
[H2CO3*]	0.000131	1.31E-04	-4092.08	13	0.71	8.08	22.00	234.20	5.08E-03	3.98E-04	6.73E-06	4.67E-03	1.91E-07	4.27E-08	7.3692
[Ca++] _s	2.98E-04	2.98E-04	-410.07	12	9.71	#####	0.00	173.28	4.47E-03	1.00E-03	1.47E-06	3.46E-03	5.64E-08	1.45E-07	6.8385
pHs alk		7.67	-24.21	11	10.52	#####	0.00	92.21	3.66E-03	1.81E-03	2.30E-07	1.84E-03	1.66E-08	4.92E-07	6.3077
			111.95	10	11.46	#####	0.00	35.56	3.09E-03	2.38E-03	2.62E-08	7.13E-04	4.89E-09	1.67E-06	5.7769
			234.21	9	12.48	#####	0.00	11.27	2.85E-03	2.61E-03	2.51E-09	2.31E-04	1.44E-09	5.67E-06	5.2462
			269.93	8	13.53	#####	0.00	2.54	2.76E-03	2.69E-03	2.24E-10	7.00E-05	4.25E-10	1.93E-05	4.7154
			367.24	7	14.59	#####	0.00	-2.24	2.71E-03	2.69E-03	1.94E-11	2.06E-05	1.25E-10	6.54E-05	4.1846
			1311.35	6	15.66	#####	0.00	-10.80	2.63E-03	2.62E-03	1.64E-12	5.92E-06	3.69E-11	2.22E-04	3.6538
			10767.24	5	16.77	#####	0.00	-37.58	2.36E-03	2.36E-03	1.28E-13	1.57E-06	1.09E-11	7.53E-04	3.1231
			107102.72	4	18.04	#####	0.00	-127.82	1.45E-03	1.45E-03	6.87E-15	2.85E-07	3.20E-12	2.56E-03	2.5923
			1248139.02	3	#####	#####	0.00	-273.31	1.73E-96	1.73E-96	7.09E-109	1.00E-100	9.42E-13	8.68E-03	2.0615
			30426658.11	2	#####	#####	0.00	-273.31	5.87E-96	5.87E-96	2.09E-109	1.00E-100	2.78E-13	2.95E-02	1.5308
			2099027456.52	1	#####	#####	0.00	-273.31	1.99E-95	1.99E-95	6.15E-110	1.00E-100	8.18E-14	1.00E-01	1.0000
			269.93	8	-0.23	7.67	50.66	262.85	5.36E-03	1.31E-04	2.54E-05	5.21E-03	6.50E-07	1.26E-08	7.9000
			273.31	7.9	-0.09	7.71	46.91	259.11	5.32E-03	1.63E-04	2.00E-05	5.14E-03	5.16E-07	1.58E-08	7.8000
			277.26	7.8	0.06	7.76	42.57	254.77	5.28E-03	2.01E-04	1.56E-05	5.06E-03	4.10E-07	2.00E-08	7.7000
			281.99	7.7	0.22	7.82	37.47	249.67	5.23E-03	2.49E-04	1.22E-05	4.97E-03	3.26E-07	2.51E-08	7.6000
			287.75	7.6	0.41	7.91	31.47	243.67	5.17E-03	3.06E-04	9.45E-06	4.85E-03	2.59E-07	3.16E-08	7.5000
			294.83	7.5	0.63	8.03	24.41	236.61	5.10E-03	3.75E-04	7.29E-06	4.72E-03	2.05E-07	3.98E-08	7.4000
			303.63	7.4	0.92	8.22	16.15	228.35	5.02E-03	4.55E-04	5.59E-06	4.56E-03	1.63E-07	5.01E-08	7.3000
			314.61	7.3	1.43	8.63	6.60	218.80	4.92E-03	5.50E-04	4.26E-06	4.37E-03	1.30E-07	6.31E-08	7.2000
			328.35	7.2	9.37	#####	0.00	207.88	4.81E-03	6.58E-04	3.22E-06	4.15E-03	1.03E-07	7.94E-08	7.1000
			345.59	7.1	9.50	#####	0.00	195.63	4.69E-03	7.79E-04	2.40E-06	3.91E-03	8.18E-08	1.00E-07	7.0000
			367.24	7	9.63	#####	0.00	182.13	4.55E-03	9.14E-04	1.78E-06	3.64E-03	6.50E-08	1.26E-07	6.9000
			273.31	7.9	-0.09	7.71	46.91	259.11	5.32E-03	1.63E-04	2.00E-05	5.14E-03	5.16E-07	1.58E-08	7.8000
			273.68	7.89	-0.08	7.71	46.51	258.71	5.32E-03	1.66E-04	1.95E-05	5.13E-03	5.04E-07	1.62E-08	7.7900
			274.05	7.88	-0.06	7.72	46.10	258.29	5.32E-03	1.70E-04	1.90E-05	5.13E-03	4.93E-07	1.66E-08	7.7800
			274.43	7.87	-0.05	7.72	45.68	257.88	5.31E-03	1.73E-04	1.86E-05	5.12E-03	4.82E-07	1.70E-08	7.7700
			274.82	7.86	-0.03	7.73	45.26	257.45	5.31E-03	1.77E-04	1.81E-05	5.11E-03	4.71E-07	1.74E-08	7.7600
			275.21	7.85	-0.02	7.73	44.83	257.02	5.30E-03	1.81E-04	1.77E-05	5.10E-03	4.60E-07	1.78E-08	7.7500
			275.60	7.84	0.00	7.74	44.39	256.59	5.30E-03	1.85E-04	1.72E-05	5.10E-03	4.49E-07	1.82E-08	7.7400
			276.01	7.83	0.01	7.74	43.94	256.14	5.29E-03	1.89E-04	1.68E-05	5.09E-03	4.39E-07	1.86E-08	7.7300
			276.42	7.82	0.03	7.75	43.49	255.69	5.29E-03	1.93E-04	1.64E-05	5.08E-03	4.29E-07	1.91E-08	7.7200
			276.84	7.81	0.04	7.75	43.03	255.23	5.29E-03	1.97E-04	1.60E-05	5.07E-03	4.19E-07	1.95E-08	7.7100
			277.26	7.8	0.06	7.76	42.57	254.77	5.28E-03	2.01E-04	1.56E-05	5.06E-03	4.10E-07	2.00E-08	7.7000
					0.00	7.74	44.39	256.59	5.30E-03	1.85E-04	1.72E-05	5.10E-03	4.49E-07	1.82E-08	7.7400
					0.00	7.74	44.34	256.54	5.30E-03	1.85E-04	1.72E-05	5.10E-03	4.48E-07	1.82E-08	7.7390
					0.00	7.74	44.30	256.50	5.30E-03	1.86E-04	1.72E-05	5.10E-03	4.47E-07	1.83E-08	7.7380
					0.00	7.74	44.26	256.45	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.46E-07	1.83E-08	7.7370
					0.00	7.74	44.21	256.41	5.30E-03	1.87E-04	1.71E-05	5.09E-03	4.45E-07	1.84E-08	7.7360
					0.00	7.74	44.17	256.36	5.30E-03	1.87E-04	1.70E-05	5.09E-03	4.44E-07	1.84E-08	7.7350
					0.01	7.74	44.12	256.32	5.30E-03	1.87E-04	1.70E-05	5.09E-03	4.43E-07	1.85E-08	7.7340
					0.01	7.74	44.08	256.28	5.30E-03	1.88E-04	1.69E-05	5.09E-03	4.42E-07	1.85E-08	7.7330
					0.01	7.74	44.03	256.23	5.30E-03	1.88E-04	1.69E-05	5.09E-03	4.41E-07	1.85E-08	7.7320
					0.01	7.74	43.99	256.19	5.30E-03	1.89E-04	1.69E-05	5.09E-03	4.40E-07	1.86E-08	7.7310
					0.01	7.74	43.94	256.14	5.29E-03	1.89E-04	1.68E-05	5.09E-03	4.39E-07	1.86E-08	7.7300
					0.00	7.74	44.30	256.50	5.30E-03	1.86E-04	1.72E-05	5.10E-03	4.47E-07	1.83E-08	7.7380
					0.00	7.74	44.30	256.49	5.30E-03	1.86E-04	1.71E-05	5.10E-03	4.47E-07	1.83E-08	7.7379
					0.00	7.74	44.29	256.49	5.30E-03	1.86E-04	1.71E-05	5.10E-03	4.47E-07	1.83E-08	7.7378
					0.00	7.74	44.29	256.48	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.47E-07	1.83E-08	7.7377
					0.00	7.74	44.28	256.48	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.47E-07	1.83E-08	7.7376
					0.00	7.74	44.28	256.48	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.47E-07	1.83E-08	7.7375
					0.00	7.74	44.27	256.47	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.47E-07	1.83E-08	7.7374
					0.00	7.74	44.27	256.47	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.47E-07	1.83E-08	7.7373
					0.00	7.74	44.26	256.46	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.47E-07	1.83E-08	7.7372
					0.00	7.74	44.26	256.46	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.46E-07	1.83E-08	7.7371
					0.00	7.74	44.26	256.45	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.46E-07	1.83E-08	7.7370
					0.00	7.74	44.28	256.48	5.30E-03	1.86E-04	1.71E-05	5.09E-03	4.47E-07	1.83E-08	7.7375

Tk 293
 I 0.0092
 E 80.0948
 A 0.50625
 f(l) 0.08754
 K1 4.14E-07
 K2 4.20E-11
 Kw 6.75E-15
 Ks 3.53E-09
 fm 0.90875
 fd 0.68199
 K1p 5.01E-07
 K2p 6.15E-11
 Kwp 8.18E-15
 Ksp 7.58E-09

Forms of CaCO ₃ and their solubility product constants				
Form #	1	2	3	4
Preferred	Calcite	Aragonite	Vaterite	General
1	3.53E-09	4.95E-09	1.34E-08	5.41253E-09

Coagulant	no. of waters of hydrations
Aluminum Sulfate	14 Enter 14 or 18
Ferric sulfate	9 Enter 9,5,3 or 0
Ferric Chloride	0 Enter 0 or 6


Chemicals Available for Use in RTW Model

Indicate with a Y those chemicals which you want to include in the input area.
Up to 10 may be used at one time. Press HOME to return to the main screen.

Y or N ?	Chemical Name	Alk	Acid	Ca	Cl	SO4
y	Alum *14H2O	-0.51	0.51	0	0	0.48
n	Alum 50% solution	-0.24	0.24	0	0	0.23
n	Aluminum Chloride	-1.12	1.12	0	0.8	0
n	Calcium carbonate	1	0	1	0	0
n	Calcium chloride	0	0	0.9	0.64	0
n	Calcium hypochlorite	0.7	-0.7	0.7	0	0
y	Carbon dioxide	0	2.28	0	0	0
y	Caustic soda	1.25	-1.25	0	0	0
y	Chlorine gas	-1.41	1.41	0	0.5	0
y	Ferric chloride (anhydrous)	-0.93	0.93	0	0.66	0
n	Ferric sulfate *9H2O	-0.53	0.53	0	0	0.51
y	Ferrous sulfate *7H2O	-0.36	0.36	0	0	0.36
y	Hydrochloric acid	-1.37	1.37	0	0.97	0
y	Hydrofluosilicic acid	-2.08	2.08	0	0	0
y	Lime (slaked)	1.35	-1.35	1.35	0	0
n	Phosphoric acid	-1.53	1.53	0	0	0
n	Potassium Hydroxide	0.89	-0.89	0	0	0
n	Quicklime	1.79	-1.79	1.79	0	0
n	Soda ash	0.94	0	0	0	0
n	Sodium bicarbonate	0.6	0.6	0	0	0
n	Sodium hypochlorite	0.67	-0.67	0	0	0
y	Sulfuric Acid	-1.02	1.02	0	0	0.98
n	Zinc Sulfate	-0.35	0.35	0	0	0.33
n	Magnesium hydroxide	1.71	-1.71	0	0	0
n	User Specified*					


* See User's Manual for information on user specified chemicals

Appendix D: Manufacturer Information



PLAN VIEW

BACK VIEW



FRONT VIEW

RIGHT SIDE VIEW

SALES DRAWING



2055 Boggs Road
Duluth, GA 30096
P. 678-835-0052 F. 678-835-0057
www.adedgetechnologies.com

This drawing is the exclusive property of AdEdge Water Technologies, L.L.C. Its acceptance constitutes an agreement that it shall be expressly used for subject project and shall be returned upon request. Information contained on, or derived from this drawing, is not to be communicated, disclosed, used or copied without prior authorization.

TP.	SERVICE CONNECTIONS:	TYPE/MATERIAL:	REV. #	DATE:	BY:	APPROVED BY:	REVISION DESCRIPTION:	DRAWN BY:	CHECKED BY:	APPROVED BY:	PROJECT #:	DATE:	SCALE:		
A	SYSTEM RAW WATER INLET	4" 150# SCH80 PVC FLANGE	-	-	-	-	-	MC	CN	GG	TBD-0000	12/15/21	NTS		
B	SYSTEM TREATED OUTLET	4" 150# SCH80 PVC FLANGE						MODEL:		AEDGE MODULAR PFAS TREATMENT SYSTEM APUPFx-7260CS-2-MT-LL					
C	SYSTEM BACKWASH OUTLET	4" BUTTERFLY VALVE FLANGE						COSTUMER:		TBD					
D	AUX. BACKWASH INLET	4" 150# SCH80 PVC FLANGE						TITLE:		SALES GENERAL ARRANGEMENT		DRAWING NUMBER:	M-001	SHEET:	3 OF 4

DIMENSIONAL NOTES:



1. ALL DIMENSIONS ARE +/- 2".
2. DO NOT SCALE DRAWING. REFER TO AEDGE ENGINEERING DEPT FOR ALL DIMENSIONS
3. (##): REFERENCE DIMENSION

GENERAL SYSTEM SPECIFICATIONS:


1. SCH80 PVC INLET/OUTLET WITH FLANGED TIE POINTS
2. SCH80 PVC VALVE TREE PIPING
3. LUG-STYLE BUTTERFLY VALVES WITH MANUEL OPERATOR ON VALVE TREE
4. LUG-STYLE BUTTERFLY VALVE WITH MANUAL OPERATOR FOR BACKWASH OUTLET
5. 304SS HYDRAULIC PANEL WITH DP GAUGE FOR EACH VESSEL.
6. PRESSURE GAUGES AND SAMPLE VALVES ON EACH VESSEL'S INLET AND OUTLET

SYSTEM WEIGHT:

1. APPROXIMATE SHIPPING WEIGHT: 13,500 LBS



PLAN VIEW
FRONT AND BACK CLEARANCE



VESSEL INTERNAL VIEW


SALES DRAWING



2055 Boggs Road
Duluth, GA 30096
P. 678-835-0052 F. 678-835-0057
www.adedgetechnologies.com


This drawing is the exclusive property of AdEdge Water Technologies, L.L.C. Its acceptance constitutes an agreement that it shall be expressly used for subject project and shall be returned upon request. Information contained on, or derived from this drawing, is not to be communicated, disclosed, used or copied without prior authorization.

TP.	SERVICE CONNECTIONS:	TYPE/MATERIAL:	REV. #	DATE:	BY:	APPROVED BY:	REVISION DESCRIPTION:	DRAWN BY:	CHECKED BY:	APPROVED BY:	PROJECT #:	DATE:	SCALE:
			-	-	-	-	-	MC	CN	GG	TBD-0000	12/15/21	NTS
								MODEL:		COSTUMER:			
								AEDGE MODULAR PFAS TREATMENT SYSTEM APUPFX-7260CS-2-MT-LL		TBD			
								TITLE:		DRAWING NUMBER:		SHEET:	
								SALES GENERAL ARRANGEMENT		M-002		4 OF 4	



PLAN VIEW

BACK VIEW



FRONT VIEW

RIGHT SIDE VIEW

SALES DRAWING



2055 Boggs Road
Duluth, GA 30096
P. 678-835-0052 F. 678-835-0057
www.adedgetechnologies.com

This drawing is the exclusive property of AdEdge Water Technologies, L.L.C. Its acceptance constitutes an agreement that it shall be expressly used for subject project and shall be returned upon request. Information contained on, or derived from this drawing, is not to be communicated, disclosed, used or copied without prior authorization.

TP.	SERVICE CONNECTIONS:	TYPE/MATERIAL:	REV. #	DATE:	BY:	APPROVED BY:	REVISION DESCRIPTION:
A	SYSTEM RAW WATER INLET	6" 150# DI FLANGE	-	-	-	-	-
B	SYSTEM TREATED OUTLET	6" 150# DI FLANGE	-	-	-	-	-
C	SYSTEM BACKWASH OUTLET	6" BUTTERFLY VALVE	-	-	-	-	-
D	AUX. BACKWASH INLET	6" 150# DI FLANGE	-	-	-	-	-
E	SLUICING NOZZLE (DISCHARGE)	4" 316SS PLUG	-	-	-	-	-
F	SLUICING NOZZLE (FILL)	4" 316SS PLUG	-	-	-	-	-

DRAWN BY:	CHECKED BY:	APPROVED BY:	PROJECT #:	DATE:	SCALE:
MC	CN	GG	TBD-0000	12/15/21	NTS
MODEL:			COSTUMER:		
ADEGE MODULAR PFAS TREATMENT SYSTEM MODPFx-9660CS-2-MVT-LL			TBD		
TITLE:			DRAWING NUMBER:		SHEET:
SALES GENERAL ARRANGEMENT			M-001		3 OF 4

DIMENSIONAL NOTES:


1. ALL DIMENSIONS ARE +/- 2".
2. DO NOT SCALE DRAWING. REFER TO AEDGE ENGINEERING DEPT FOR ALL DIMENSIONS
3. (##): REFERENCE DIMENSION

GENERAL SYSTEM SPECIFICATIONS:


1. DUCTILE IRON INLET/OUTLET WITH FLANGED TIE POINTS
2. DUCTILE IRON VALVE TREE PIPING
3. LUG-STYLE BUTTERFLY VALVES WITH MANUEL OPERATOR ON VALVE TREE
4. LUG-STYLE BUTTERFLY VALVE WITH MANUAL OPERATOR FOR BACKWASH OUTLET
5. 304SS HYDRAULIC PANEL WITH DP GAUGE FOR EACH VESSEL.
6. PRESSURE GAUGES AND SAMPLE VALVES ON EACH VESSEL'S INLET AND OUTLET

SYSTEM WEIGHT:

1. APPROXIMATE SHIPPING WEIGHT:



(OPERATOR LOCATION)
 PLAN VIEW
 FRONT AND BACK CLEARANCE



SALES DRAWING




2055 Boggs Road
 Duluth, GA 30096
 P. 678-835-0052 F. 678-835-0057
 www.adedgetechnologies.com

This drawing is the exclusive property of AdEdge Water Technologies, L.L.C. Its acceptance constitutes an agreement that it shall be expressly used for subject project and shall be returned upon request. Information contained on, or derived from this drawing, is not to be communicated, disclosed, used or copied without prior authorization.

TP.	SERVICE CONNECTIONS:	TYPE/MATERIAL:	REV. #	DATE:	BY:	APPROVED BY:	REVISION DESCRIPTION:
			-	-	-	-	-

DRAWN BY:	CHECKED BY:	APPROVED BY:	PROJECT #:	DATE:	SCALE:
MC	CN	GG	TBD-0000	12/15/21	NTS
MODEL:			COSTUMER:		
AEDGE MODULAR PFAS TREATMENT SYSTEM MODPFx-9660CS-2-MVT-LL			TBD		
TITLE:			DRAWING NUMBER:	SHEET:	
SALES GENERAL ARRANGEMENT			M-002	4 OF 4	





MODPFx-12060CS-2-MVT-LL AEDGE TREATMENT SYSTEM



2055 Boggs Road
Duluth, GA 30096
P. 678-835-0052 F. 678-835-0057
www. adedgetechnologies.com

This drawing is the exclusive property of AdEdge Water Technologies, L.L.C. Its acceptance constitutes an agreement that it shall be expressly used for subject project and shall be returned upon request. Information contained on, or derived from this drawing, is not to be communicated, disclosed, used or copied without prior authorization.

CONTRACTOR		SHEET INDEX			REV. #	DATE	BY:	APPROVED BY:	REVISION DESCRIPTION:	DRAWN BY:	CHECKED BY:	APPROVED BY:	PROJECT #:	DATE:	SCALE:
---		DRAWING NO.	TITLE	SHEET NO.						MC	CN	GG	TBD-0000	12/15/21	NTS
MODEL: AEDGE MODULAR PFAS TREATMENT SYSTEM MODPFx-12060CS-2-MVT-LL												COSTUMER: TBD			
TITLE: COVER												SALES DRAWING			



SALES DRAWING



2055 Boggs Road
 Duluth, GA 30096
 P. 678-835-0052 F. 678-835-0057
 www.adedgetechnologies.com

This drawing is the exclusive property of AdEdge Water Technologies, L.L.C. Its acceptance constitutes an agreement that it shall be expressly used for subject project and shall be returned upon request. Information contained on, or derived from this drawing, is not to be communicated, disclosed, used or copied without prior authorization.

TP.	SERVICE CONNECTIONS:	TYPE/MATERIAL:	REV. #	DATE:	BY:	APPROVED BY:	REVISION DESCRIPTION:
A	SYSTEM RAW WATER INLET	6" 150# DI FLANGE	-	-	-	-	-
B	SYSTEM TREATED OUTLET	6" 150# DI FLANGE	-	-	-	-	-
C	SYSTEM BACKWASH OUTLET	6" BUTTERFLY VALVE	-	-	-	-	-
D	AUX. BACKWASH INLET	6" 150# DI FLANGE	-	-	-	-	-
E	SLUICING NOZZLE (DISCHARGE)	4" 316SS PLUG	-	-	-	-	-
F	SLUICING NOZZLE (FILL)	4" 316SS PLUG	-	-	-	-	-

DRAWN BY:	CHECKED BY:	APPROVED BY:	PROJECT #:	DATE:	SCALE:
MC	CN	GG	TBD-0000	12/15/21	NTS
MODEL:			COSTUMER:		
ADEGE MODULAR PFAS TREATMENT SYSTEM MODPFx-12060CS-2-MT-LL			TBD		
TITLE:			DRAWING NUMBER:		SHEET:
SALES GENERAL ARRANGEMENT			M-001		3 OF 4

8 7 6 5 4 3 2 1

DIMENSIONAL NOTES:



- 1. ALL DIMENSIONS ARE +/- 2".
- 2. DO NOT SCALE DRAWING. REFER TO AEDGE ENGINEERING DEPT FOR ALL DIMENSIONS
- 3. (##): REFERENCE DIMENSION

GENERAL SYSTEM SPECIFICATIONS:

- 1. DUCTILE IRON INLET/OUTLET WITH FLANGED TIE POINTS
- 2. DUCTILE IRON VALVE TREE PIPING
- 3. LUG-STYLE BUTTERFLY VALVES WITH MANUEL OPERATOR ON VALVE TREE
- 4. LUG-STYLE BUTTERFLY VALVE WITH MANUAL OPERATOR FOR BACKWASH OUTLET
- 5. 304SS HYDRAULIC PANEL WITH DP GAUGE FOR EACH VESSEL.
- 6. PRESSURE GAUGES AND SAMPLE VALVES ON EACH VESSEL'S INLET AND OUTLET

SYSTEM WEIGHT:

- 1. APPROXIMATE SHIPPING WEIGHT:



D
C
B
A

D
C
B
A

SALES DRAWING



2055 Boggs Road
 Duluth, GA 30096
 P. 678-835-0052 F. 678-835-0057
 www.adedgetechnologies.com

This drawing is the exclusive property of AdEdge Water Technologies, L.L.C. Its acceptance constitutes an agreement that it shall be expressly used for subject project and shall be returned upon request. Information contained on, or derived from this drawing, is not to be communicated, disclosed, used or copied without prior authorization.

TP.	SERVICE CONNECTIONS:	TYPE/MATERIAL:	REV. #	DATE:	BY:	APPROVED BY:	REVISION DESCRIPTION:
			-	-	-	-	-

DRAWN BY:	CHECKED BY:	APPROVED BY:	PROJECT #:	DATE:	SCALE:
MC	CN	GG	TBD-0000	12/15/21	NTS
MODEL:			COSTUMER:		
AEDGE MODULAR PFAS TREATMENT SYSTEM MODPFx-12060CS-2-MVT-LL			TBD		
TITLE:			DRAWING NUMBER:	SHEET:	
SALES GENERAL ARRANGEMENT			M-002	4 OF 4	

8 7 6 5 4 3 2 1



CUSTOMER NAME: Zahra Anwar
 SITE NAME: Bay City Well A
 DATE OF SAMPLE: 9/26/2022

Estimated Arsenic Removal Performance With pH Control, Bed Volumes, Is Between:

188,400 & 200,400

For those sites where pH adjustment is recommended (see commentary below), the performance estimated is based on the adjusted pH of 7.0-7.2

Estimated Arsenic Removal Performance Without pH Control, Bed Volumes, Is Between:

70,800 & 82,800

Arsenic Removal Performance Cannot Be Calculated Because The Following Data is Missing:

Parameter	Units	Minimum Optimal Value	Maximum Optimal Value	Value	Commentary
Arsenic	ppb	N.A	100	10.4	Value is within range, performance estimate can be generated
Calcium	ppm	8	N.A	13.7	Total of Calcium and magnesium is used in the Calcium Addition Calculation when hardness is less than the minimum optimal value & is used as a check to the hardness value.
Iron	ppb	0	300	28	Value less than MCL. No impact.
Magnesium	ppm	N.A	N.A	5.53	Total of Calcium and magnesium is used in the Calcium Addition Calculation when hardness is less than the minimum optimal value & is used as a check to the hardness value.
Manganese	ppb	0	50	8.1	Value less than MCL. No impact.
Phosphorus	ppb	0	180	0	Phosphorus is a significant competing ion and its presence will negatively impact arsenic removal performance. However, the phosphorus is shown as zero so will not affect treatment..
Silica	ppm	0	35	17.3	Silica is a significant competing ion and its presence will negatively impact arsenic removal performance. However, the silica level is within normal range so the impact is minimal.
Vanadium	ppb	0	50	0	Vanadium is a significant competing ion and its presence will negatively impact arsenic removal performance. Vanadium is shown as zero so will not affect treatment.
Fluoride	ppm	0	1		Value less than MCL. No impact.
pH		5.5	9.5	8.28	pH is between 7.5 and 8.5. pH adjustment to 7.0 - 7.5 is highly recommended for optimum arsenic removal performance
T-Alkalinity	ppm as CaCO ₃	N.A	N.A	246	Used for pH adjustment calculation.
Hardness	ppm as CaCO ₃	21	300	88	Water contains enough calcium and magnesium to prevent silica gel formation.
Total Dissolved Solids	ppm	N.A	500	330	Value less than MCL. No impact.
Conductivity	S/cm	N.A	1000	592	Value used to check Total Dissolved Solids value.

Note: N.A. = Not Applicable Yellow = Indicates Parameter is out of Optimal Range

Note the following:

Water with pH greater than 9 may still require pH adjustment for optimum performance.

Economical treatment can still be achieved, if the ideal range for a parameter is exceeded. Particularly, for increased levels of phosphorus and vanadium compared to other adsorptive medias.

Date: November 3, 2022

Quote No: WT22-11-1675

TO: Zahra Anwar Garver Engineering 12141 Wickchester Lane Suite 200 Houston, TX 77079	Phone: 713-482-4794 Email: ZBAnwar@GarverUSA.com
RE: 700 GPM Arsenic Removal System – Bay City Well A	
Pages: 2 Est. Delivery: 24 – 26 Weeks ARO F.O.B.: Scottsdale, AZ	Delivery To: TBD
Quoted By: Christy McDonnel	Phone: (480) 998-4097 Fax: (480) 951-8434 Email: christy@apewater.com

To place an order email to orders@apewater.com

QTY	Description	Unit Price	Amount
1	Multiple Tank SKID with Backwash Plumbing and Control <i>System includes:</i> <ul style="list-style-type: none"> • (4) 72" OD x 60" Side Shell Vertical Media Tank • Internal coating is 3M Scotchkote 134, NSF 61 Certified • Exterior Paint and Coating, Carboline Carboguard 60 and 134 HG Urethane • Max pressure of 100 PSI • Max Temperature 150 °F • 6" Inlet and Outlet Flanged -Double RFSO 150# from Main Carbon Steel Manifold • Top and Side Shell Manways with Carbon Steel Hinge, 150 # Flanged, 12"x16" Elliptical • 316 Stainless Steel, Hub and Lateral • AUTOMATION DETAIL: Automatic Butterfly Valve Allen Bradley MicroLogix 1400 with Nema 4 enclosure • System is fully assembled, plumbed, and wired with tanks bolted onto a structural steel skid • Installation and Operation & Maintenance Manuals Included 	\$334,245	\$334,245.00
265	Cubic Feet of ATOMUS Z21 Media , to be filled in three of the four media vessels. Fourth vessel is for backwash water or filled with additional media and used for media changeover	\$525/cu ft	\$139,125.00
	NOTE: Standard price for ATOMUS Z21 media is \$625/ cu ft when purchasing a supersack which contains 30 cu ft. Given the size of the system, the price has been discounted to \$525/cu ft. This price will be extended to replacement media.		

24	Cubic Feet of Underbed Gravel , to be filled in three of the four media vessels. Fourth vessel is for backwash water or filled with additional media and used for media changeover	\$45/CUFT	\$1,080.00
1	40,000 Gallon HORIZONTAL Storage Tank for Water Application: Aboveground Type: SINGLE WALL Material: MILD CARBON STEEL	\$185,798.00	\$185,798.00
1	Backwash Pump w/Motor – 2000 GPM	\$5,500.00	\$5,500.00
1	WALCHEM pH Adjustment System Components ONLY <ul style="list-style-type: none"> • W120 pH Controller and sensor • 0.6 GPH Metering Pump • 275 Gallon Double-wall Tank • 2" Static Mixer • Flow switch *275 Gallons Hydrochloric Acid to be supplied by others.	\$12,985	\$12,985.00
	OPTIONAL EQUIPMENT (not included in total below)		
1	Optional C02 pH adjustment system	\$25,169	
3	Onsite Technician for Startup and Training. \$1900/ day + travel. Estimating 3 Days	\$1900.00	
	Estimated Shipping & Handling:		TBD
	This Quote does not include applicable sales tax. Minimum order \$50.00. Credit card charges will incur a surcharge of 3%.	Total:	\$678,733.00

SUBMITTED BY:

Christy McDonnel

APPLIED PROCESS EQUIPMENT, INC.

ACCEPTED BY:

Bay City Well A

BULK MEDIA Caclulate Cost Per 1000 Gallons Treated Water

USAGE GPD	633,600	
USAGE GPY	231,264,000	
Price per CUFT	525	ATOMUS Z21 Bulk Media
CUFT Needed	<u>265</u>	
Cost Per Change	\$139,125.00	
	\$139,125.00	Annual Cost (100% Treated Water)
	<u>1</u>	X # of media changes in 1 year
	\$139,125.00	= cost per year
	\$139,125.00	Cost per year
	<u>231,264,000</u>	Annual Blend Treated to OPPB
	0.000601585	Cost per gallon
	0.000601585	Cost per gallon
	<u>1000</u>	X 1000 Gallons
	\$0.60	Cost per 1000 Gallons Treated to 0 PPB



Date: November 3, 2022

Quote No: WT22-09-1665

TO: Zahra Anwar Garver Engineering 12141 Wickchester Lane Suite 200 Houston, TX 77079	Phone: 713-482-4794 Email: ZBAnwar@GarverUSA.com
RE: 700 GPM Arsenic Removal System – Bay City Well A	
Pages: 2 Est. Delivery: 24 – 26 Weeks ARO F.O.B.: Scottsdale, AZ	Delivery To: TBD
Quoted By: Christy McDonnel	Phone: (480) 998-4097 Fax: (480) 951-8434 Email: christy@apewater.com

To place an order email to orders@apewater.com

QTY	Description	Unit Price	Amount
7	100 GPM Applied Cartridge System SKID with ATOMUS F11 Arsenic Removal Cartridges System Includes: <ul style="list-style-type: none"> (1) Skid with four stainless steel 25 GPM vessels (p/n ISO-100-SK) (1) Totalizing Flow Meter, 2" (4) Air/vacuum relief valves, Max working pressure of 100 psi, threaded, 3/4" NPT (DT-040-LP) (1) EZ Lift Handle - Cartridge Extraction Tool Required valves, ports, and gauges One Installation & Maintenance manual <p><i>NOTE: Replacement ATOMUS F11 Cartridges (p/n AT-042) priced at \$981</i></p>	\$92,500.00	\$647,500.00
-7	25% Multi Skid Discount	-\$23,125	-\$161,875.00
	Subtotal		\$485,625.00
2	ACS SS Eight Bag Pre-Filter Bag Housing Material: Stainless Steel 304 Inlet/Outlet size: 8" ANSI Flange Shell O-ring: EPDM Configuration: install 8pcs of size 2 filter bags	\$25,280	\$50,560.00
-2	25% Multi Unit Discount	-\$6,320	-12,640.00
	Subtotal		\$37,920.00



140	ACS - ATOMUS F11 Arsenic Removal Cartridge <i>NSF/ANSI 61, Use with ACS Systems</i>	\$1,308.00	\$183,120.00
-140	25% Multi Pallet Discount	-\$327.00	-\$45,780.00
	Subtotal		\$137,340.00
1	WALCHEM pH Adjustment System Components ONLY <ul style="list-style-type: none"> • W120 pH Controller and sensor • 0.6 GPH Metering Pump • 275 Gallon Double-wall Tank • 2" Static Mixer • Flow switch <i>*275 Gallons Hydrochloric Acid to be supplied by others.</i>	\$12,985	\$12,985.00
-1	25% Multi Pallet Discount	-\$3,246.00	-\$3,246.00
			\$9,739.00
	OPTIONAL EQUIPMENT (not included in total below)		
1	C02 pH adjustment system	\$25,169	
	Estimated Shipping & Handling:		TBD
	This Quote does not include applicable sales tax. Minimum order \$50.00. Credit card charges will incur a surcharge of 3%.	Total:	\$670,624.00

SUBMITTED BY: Christy McDonnell

APPLIED PROCESS EQUIPMENT, INC.

ACCEPTED BY: _____

Bay City Well A				
WATER Chemistry				
As	10.4	ppb		
pH	8.28			
Ph	0	ppb		
Va	0	ppb		
Si	17.3	ppm		
Hardness	88	ppm		
Fe	28	ppb		
Mn	8.1	ppb		
Fl	4220	ppb		
Flowrate	700	GPM		
Number Cartridges	140			
Daily Usage	633600	gallons	Calculated from annual	
Annual	231,264,000	gallons		
Treatment Summary				
	ISOLUX	ISOLUX	ATOMUS F11	ATOMUS F11
Pretreatment for pH Adjustment	NO	YES	NO	YES
Bed Volumes Treated per Cartridge	69,000	157,000	82,800	200,400
Gallons treated per Cartridge	155,250	353,250	186,300	450,900
Total Gallons treated	21,735,000	49,455,000	26,082,000	63,126,000
Estimated media life (years)	0.09	0.21	0.11	0.27
Cartridge System	YES	YES	YES	YES
Backwash	NO	NO	NO	NO
Media Replacement Cost Summary				
Number of Cartridges Used	140	140	140	140
Price per Cartridge	\$ 1,200	\$ 1,200	\$ 981	\$ 981
Volume of Bulk Media Used (ft3)				
Price of Bulk Media per ft3				
Total Cost of One Media Replacement	\$ 168,000	\$ 168,000	\$ 137,340	\$ 137,340
Total Cost per year	\$ 1,787,548	\$ 785,610	\$ 1,217,767	\$ 503,149
		plus pH Chemicals		plus pH Chemicals

Bay City Well A

CARTRIDGE Caclulate Cost Per 1000 Gallons Treated Water

USAGE GPD	633,600
USAGE GPY	231,264,000
Price per Cartridge	981 ATOMUS F11
Numb Of Carts	<u>140</u>
Cost Per Change	\$137,340.00
	\$137,340.00 Annual Cost (100% Treated Water)
	<u>4</u> X # of cart changes in 1 year
	\$549,360.00 = cost per year
	\$549,360.00 Cost per year
	<u>231,264,000</u> Annual Blend Treated to 0 PPB
	0.002375467 Cost per gallon
	\$0.00 Cost per gallon
	<u>1000</u> X 1000 Gallons
	\$2.38 Cost per 1000 Gallons Treated to 0 PPB

WATER TREATMENT SKID SYSTEMS



NSF 61 CERTIFIED SYSTEMS | SIMPLE TO OPERATE | NO BACKWASHING




50 & 100 GPM

- **Stainless Steel Vessel Housings**
- **Prefilters**
- **Choice of Cartridges**

Applied
**CARTRIDGE
SYSTEMS**

NSF 61 CERTIFIED

50 GPM SKIDS



Model: ISO-50-SK



NSF 61 Certified System Packages

Applied Cartridge Systems skids were designed for quick, complication-free regulatory compliance. Each skid is a self-contained water treatment cartridge system with 304 stainless steel housings, prefilters and a choice of cartridges, all NSF 61 certified together as a single package.

No Backwashing! Easy To Maintain

Applied Cartridge Systems skids are exceptionally easy to operate. There's no need to backwash. No hazardous waste streams. No large media tanks, media pumping or disposal. Just periodic one-man cartridge replacement. Maintenance downtime can be minimized or even eliminated. The multi-vessel skid configuration allows continuous operation during cartridge change-out.

Choice of Treatment Cartridges

The growing family of ATOMUS® cartridges addresses a range of water treatment issues. All cartridges are designed exclusively for Applied Cartridge Systems.


Building on two Arsenic removal cartridges, ISOLUX® (also known as ATOMUS® I22), and the new ATOMUS® F11 cartridge, Applied Cartridge Systems has expanded the cartridge offering to include treatment for Phosphorus, Fluoride and coming soon, PFAS.

Every cartridge is fully sealed to prevent media contact. Cartridge housings, and the media they hold, are NSF 61 certified and landfill safe.*

MANAGERS A TRULY SIMPLE TO OPERATE WATER TREATMENT SOLU

NSF 61 CERTIFIED

100 GPM SKIDS



Model: ISO-100-SK



Fast, Drop-In Ready Installation

Skids typically don't require electrical service or sewer tie-in. With simple, inlet/outlet flange connections and optional pre-plumbed piping sub-assemblies, a cartridge skid system can be assembled and ready to hook-up to a water supply in less than a day.

Small Footprints

With Applied Cartridge System skids there is no need for large media storage tanks. 50 GPM skid footprints are 5' long by 1.5' deep, and the 100 GPM units are only 5' long by 3' deep.

Truly easy to operate and maintain. Simple one-person cartridge loading and replacement.



* USEPA TCLP tested as non-hazardous waste safe for landfill, but due to variances in influent water quality, users are urged to perform independent verification of the non-hazardous character of spent media cartridges. Additionally, some states may have disposal criteria different from Federal guidelines (TCLP)

TWO STANDARD SIZES – STAINLESS STEEL CONSTRUCTION

	50-GPM Model: ISO-50-SK	100-GPM Model: ISO-100-SK
No. of Media Cartridges (Replaceable)	10 (Five per vessel)	20 (Five per vessel)
Number of Vessels per Skid	2	4
Vessel Construction	150 psi, 304 Stainless Steel	150 psi, 304 Stainless Steel
Cartridge Size	4.5" OD x 42" L	4.5" OD x 42" L
System Shipping Weight	675 lbs	1,200 lbs
Inlet/Outlet Connection	2", 150 lb ANSI Flange	3", 150 lb ANSI Flange
Footprint	64" L x 18" D x 75" H	58" L x 39" D x 75" H
Minimum Required Headroom (for cartridge removal)	120"	120"

Small System Water Treatment Simplified.

Applied Cartridge Systems 50 GPM and 100 GPM Skids offer a unique, exceptionally easy to operate cartridge technology that's head and shoulders above other water treatment systems.

Ideal for small to mid-size water treatment applications up to 500 GPM, Applied Cartridge Systems skids have been installed in community drinking water systems, rural water utilities, schools, hotels and resorts, RV parks, office complexes, subdivisions and multi-user wells all across North America.

NSF 61 CERTIFIED



5, 10, 15, 20, 25 GPM models

NSF 61 CERTIFIED SYSTEMS | SMALL FOOTPRINTS | SIMPLE OPERATION | NO BACKWASHING

Applied
**CARTRIDGE
SYSTEMS**

9332 North 95th Way
Scottsdale, AZ 85258

sales@appliedcartridgesystems.com 480-315-8430



ISO-05-SS, ISO-10-SS, ISO-15-SS, ISO-20-SS, ISO-25-SS, ISO-50-SK and ISO-100-SK have been certified by IAPMO R&T against standard NSF/ANSI/CAN 61 and 372 for material safety and lead free requirements. Not certified for contaminant reduction or structural integrity by IAPMO R&T.

ARSENIC REMOVAL MEDIA

ATOMUS Z21[®] Arsenic Removal Media, is a binary mixed metal adsorption media uniquely formulated to remove Arsenic from drinking water. With large, solid, high surface area granules, ATOMUS[®] Z21 media has demonstrated twice the arsenic loading capacity, longer life and shorter reaction time (EBT) than other arsenic removal medias.

Ideal for medium to high flow rate applications up to 2,000 gpm. ATOMUS[®] Z21 is NSF 61 certified and delivers unmatched performance than other arsenic adsorption media.

- Unparalleled non-leachable Arsenic bond
- Removes Arsenic III & V simultaneously
- NSF 61 certified for drinking water use
- Non-toxic – Media has passed USEPA TCLP and California wet tests*
- Imparts no odors, taste or color to water
- pH range greater than any other Arsenic adsorption media
- Least impacted by competing ions like Silica, Phosphorus or Vanadium




High-capacity tanks manufactured to specific application requirements

Media Specifications:

System Type:	Granular media in pressure vessels	Contaminant Removal:	Arsenic III & V, plus phosphate, chromium, selenium, fluoride
Media Type:	Patented Binary Metal adsorption media	Backwashing:	Monthly
Surface Area:	Greater than 200 m ² /g	pH range:	5.5 – 10.5
Bulk Density (weight):	48 lbs./Cubic ft.	pH Zero point-of-charge: (ZETA point)	12
Minimum Empty bed contact time (EBCT):	2.5 to 3 minutes	Media Disposal:	Landfill*
Surface Loading Rate:	7-9 gpm/ft ²	Pressure Drop:	Less than 10 psi
Particle Size:	10 x 65 mesh	Cost per Gallon Treated:	Low

* USEPA TCLP tested as non-hazardous for landfill, but due to variances in influent water quality, users are urged to perform independent verification of the disposal character of spent media cartridges. Additionally, some states may have disposal criteria different from federal guidelines (TCLP).



Atomus Z21[®] Arsenic removal granules



Certified to
NSF/ANSI 61


CARBON STEEL TREATMENT VESSELS

Designed for use with **ATOMUS[®] Z21 Bulk Granular Adsorption Media**

- NSF/ANSI 61 certified interior coating
- Carbon steel construction
- Coated finish in "Safety Blue" epoxy
- 100 PSIG working pressures
- 150 PSIG is available
- Seismically rated supports (optional)
- ASME Code available on request
- Custom sizes available



10 Standard vessel sizes from 20"–72" for a wide range of applications. Custom high-capacity tank sizes also available




Standard Capacity Vessels

MODEL NO.	DIAMETER	HEIGHT (OVERALL)	VOLUME (GAL)	MEDIA (CUBIC FT.)	INLET/OUTLET
2060LC	20"	76"	85	6	2" NPS*
2460LC	24"	78"	124	9	2" NPS
3060LC-3	30"	85"	205	14	3" NPT**
3672LC	36"	101"	350	20	3" NPT
4272LC	42"	103"	484	28	3" NPT

* (NPS) National Pipe Straight ** (NPT) National Pipe Threaded



All vessel sizes include precision stainless steel internal distributors



High-Capacity Vessels

MODEL NO.	DIAMETER	HEIGHT (OVERALL)	VOLUME (GAL)	MEDIA (CUBIC FT.)	INLET/OUTLET
4872LC	48"	111"	660	36	4" NPT
5472LC	54"	113"	848	46	4" NPT
6072LC	60"	115"	1060	8	4" NPT
6672LC	66"	115"	1276	70	4" NPT
7272LC	72"	119"	1568	84	4" NPT

* (NPS) National Pipe Straight ** (NPT) National Pipe Threaded



Certified to NSF/ANSI 61



Budgetary Proposal for a Pall ARIA™ Membrane Filtration System

City of Bay City, TX Arsenic Removal WTP



1/0/1900
Proposal #: OPP1876513 -0-B

Submitted to:

Zahra Anwar
Garver
713-482-4794
ZBAnwar@GarverUSA.com

Submitted by:

Rick Moro
Regional Sales Manager
516-924-2054
rick_moro@pall.com

PROPRIETARY & CONFIDENTIAL
INFORMATION NOTICE

This proposal document is proprietary to Pall Corporation and is furnished in confidence solely for use in evaluating the proposal and for no other direct or indirect use. No rights are granted to the recipient for any information disclosed in this proposal. It contains proprietary information which may be the subject of an issued patent or pending application in the United States or elsewhere. By accepting this document from Pall Corporation the recipient agrees:

- to use this document and the information it contains exclusively for the above-stated purpose and to avoid use of the information for performance of the proposed work by recipient itself or any third party.
- to avoid publication or other disclosure of this document or the information it contains to any third party without the prior approval of Pall Corporation.
- to make only those copies needed for recipient's internal review, and
- to return this document and any copies thereof when they are no longer needed for the purpose for which furnished or upon the request of Pall Corporation.

Table of Contents

1. Pall Offering
 - 1.1 Scope Summary
 - 1.2 Pricing Summary
 - 1.3 Delivery Schedule
 - 1.4 Terms and Conditions

2. Scope of Supply
 - 2.1 Scope Summary Table
 - 2.2 Equipment Description
 - 2.3 Submittal Description
 - 2.4 Services and Labor

3. Technical Summary
 - 3.1 Process Summary
 - 3.2 Treated Water Objectives
 - 3.3 Operational Parameters
 - 3.4 Acceptance Criteria

The following information can be provided upon request

Warranty
Overview of Pall Corporation
Hollow Fiber Membrane System Overview
Pall Standard Terms and Conditions

1 Pall Offering

1.1 Scope Summary

660-gpm Membrane Filtration System for Arsenic Removal

1.2 Pricing Summary

Item	Description	Sale Price (US)
1	Aria™ Membrane Filtration System (Details Per Section 2)	\$2,000,000

1.3 Delivery Schedule

The schedule provided is Pall's standard and reflects typical project execution. If requested, we would be happy to review customer schedule requirements and adjust where possible to accommodate project specific needs.

	Milestone	Typical Schedule
1	Acknowledgement of Purchase Order	Typically 1 to 2 weeks after Receipt of Purchase Order
2	Submittals/Shop Drawings	Typically 4 weeks after Acknowledgement of Purchase Order
3	Commence Manufacturing ¹	Typically 2 weeks after Submittals/Shop Drawings submitted
4	Equipment Ready to Ship and Preliminary O&M Manual	Typically 22 -26 weeks after Commence Manufacturing
5	Installation Completed (by Others)	Variable
6	Commissioning Complete/Final Acceptance	Approximately 5 weeks after Installation Completed

Note 1: For standard equipment, manufacturing may commence order acknowledgement. The schedule above assumes standard equipment and standard submittals.

1.4 Terms and Conditions

All sales made by Pall are subject to the terms contained within this Section 1.4 and *Additional Terms and Conditions of Sale of Systems and Made to Order Goods – The Americas* (Available upon request).

Price Validity	This proposal is for discussion purposes only, does not constitute a binding agreement on either party, and remains subject to corporate approval by both parties. The information contained herein is deemed confidential and is not to be shared with any third party.
Shipping Terms	The price does not include shipping costs. Delivery shall be FCA Seller’s Shipping Point, INCOTERMS® 2010.
Payment Terms	Payment of invoiced amounts due to Seller shall be paid Net 30 days and as further defined in <i>Additional Terms and Conditions of Sale Systems and Made to Order Goods – The Americas</i> .
Bonds	No bonds of any type are included with this proposal.
Taxes	No taxes are included in the pricing. Payment of all Taxes related to the Goods and Services proposed shall be the exclusive responsibility of the Buyer as further defined in <i>Additional Terms and Conditions of Sale Systems and Made to Order Goods – The Americas</i> .

2 Scope of Supply

2.1 Scope Summary Table

Item Description	By PALL	By OTHERS
(1) Master Control Panel with Allen Bradley Logix PLC, or equal	X	
Design and supply of systems prior to membrane filtration system.		X
Feed Tank Included as part of packaged system - Shipped Loose	X	
Feed Pump(s) and VFD(s) included as part of AP skid	X	
Feed Strainer included as part of AP Skid	X	
2 (1 + 1) AP6 Units, each factory assembled and tested unit including valves, instruments & I/O required for operation	X	
Each AP Unit will include a membrane module rack for on-site assembly and (30) hollow fiber membrane modules	X	
RF Tank Included as part of packaged system - Shipped Loose	X	
RF Pump(s) included as part of AP Skid	X	
(1) 2500 gallon CIP System factory assembled and tested prior to shipment with valves, instruments, pumps, tank, heater as needed for operation	X	
(1) 10500 gallon Neutralization System factory assembled per the P&ID and tested prior to shipment:	X	
(2) Air Compressors (1) Air Receiver	X	
Chemical Storage Equipment		X
Supply of any required chemicals		X
Design and supply of anchor bolts for Pall supplied Equipment		X
Receiving, unloading and safe storage of equipment until ready for installation		X
Installation of all equipment		X
Design and supply of interconnecting pipe, inclusive of pipe supports and flexible connectors		X
Motor Control Center (MCC)		X
All wiring, cabling, and tubing for power supply, signals, communications, and to connections on Pall supplied equipment		X
Design, supply, and installation of all civil infrastructure inclusive of buildings, fire and safety protection, HVAC, walkways, platforms, etc.		X
All Permits		X

2.3 Submittal Description

The project schedule is based on submittals/shop drawings provided in electronic format via a secure FTP site for information only. This allows work to proceed on the project without a document approval process.

Submittals/Shop Drawings
P&ID
General Arrangement Drawings for Pall-Supplied Equipment
Electrical Interconnect Drawing (Power One-Line, I/O Interconnection, and Network Layout)
Electrical Drawings for Pall-Supplied Panels
Mechanical Replacement Parts List
Electrical Replacement Parts List
Compressed Air System Information
Installation Manual
Cutsheets for Pall-Supplied Off-Skid Components
Installation & Startup Checklist
Final Submittal (provided at completion of commissioning)
Operation and Maintenance Manual
Software License Transfer Documentation

2.4 Services and Labor

Commissioning & Training time is estimated to be 4 man-weeks. Training activities occur during the commissioning process.

Commissioning

Each day shall be considered 8 hours on site. Commissioning will begin once the system is fully installed. A commissioning Checklist is prepared specifically for each project during project execution. Commissioning shall consist of the activities outlined in the project specific Commissioning Checklist.

Commissioning activities include:

- Confirmation of network communications
- Confirmation that I/O is connected to the control system
- Confirmation of MF System functionality (components are functioning and control system sequences are functional)
- Startup and tuning of Pall controls

Operator Training

Operator training is estimated to take 1 to 3 days depending on system complexity. Training is provided on-site by a Pall Field Service Engineer. The estimated time assumes that all staff are trained at the same time. Training time will be split between a classroom presentation and hands-on training with the equipment.

3 Technical Summary

3.1 Process Summary

Source Description:

Bay City, Texas Water Plant Arsenic Removal project for arsenic removal for two groundwater wells and Treatment processes prior to Membrane Filtration System:

Coagulation and pH adjustment of 1 ppm of Ferric Chloride per 10-20 ppb of Arsenic if optimized. The

Membrane System Feed Water Characteristics

Quality of the water entering the Pall Membrane Filtration System as summarized in table below forms the basis of design for this proposal. In the event that the feed water to the membrane filtration system is outside these parameters the system performance, cleaning protocol, operating parameters, and/or warranties may be affected.

Parameter	Units	Range
Turbidity	NTU	< 5
TOC	ppm	< 3
Hardness	ppm	50-350
Alkalinity	ppm	60-320
TSS	ppm	< 20
Fe	ppm	< 1.0
Mn	ppm	< 0.5

Notes:

1 – Assumed Water Quality is based on typical water quality for similar source waters. The design parameters may change after review of actual source water quality data.

3.2 Treated Water Objectives

The proposed membrane system is designed to achieve the following results given the feed fluid conditions described in Section 3.1 of this proposal and operation of the system in accordance with the operation and maintenance manual.

Net Filtrate Capacity of 0.95 MGD

Turbidity less than 0.10 NTU 95% of the time, below 0.20 NTU at all times.

The membrane system shall produce effluent with Silt Density Index (SDI) value of 2.5 or less in 95% of samples using ASTM 4189-95 and a Pall nylon test membrane.

3.3 Operational Parameters

Hollow Fiber Membrane System operational parameters at design flow		
Net Filtrate Capacity	0.950	MGD
Recovery	96.9%	%
Instantaneous Flux	70	GFD
FM (Backwash) Interval	42	Minutes
EFM Interval	3	Day(s)
CIP Interval	60	Days

3.4 Acceptance Criteria

The system shall be accepted by the end user upon completion of the following:

- 1) Completed system commissioning per section 2.4
- 2) Production of 1st useable effluent

O&M Cost Summary

All informations regarding waste, chemical usage and electricity are based on the following assumptions:

1. All racks (including redundant racks if any) are on line
2. EFM is triggered by volume and occurs less frequently at lower flux.
3. Chemical solutions are reused up to 1 times
4. Solution strength, chemical pricing and electricity pricing assumptions are provided on the next page.
5. The values provided are estimated and do not account for fluid volumes associated with field piping or other plant specific conditions.

Waste Volumes			
	Frequency	Waste per Event	Daily Waste (Gal)
Flux Maintenance (Reverse Filtration)	Approximately 33 per rack each day	420	27,720

Chemical Cleaning Waste Volumes			
	Frequency	Monthly Waste (Gal)	Annual Waste (MGal)
Enhanced Flux Maintenance (EFM) & Clean in Place (CIP) Waste	EFM 6 day(s) CIP 60 days	40,620	0.49


Electrical Usage		
kWhr/month	kWhr/yr	\$USD/yr
4,018	48,210	\$4,821

	Chemical Usage		
	Gal/year	Gal/month	\$USD/yr
Chlorine: (Sodium Hypochlorite)	376	31	\$526
Caustic (NaOH): (Sodium Hydroxide)	799	67	\$1,438
Citric Acid:	818	68	\$4,419
Sodium Bisulfite:	0	0	\$0

O&M Cost Summary		
Energy and Chemical Cost Assumptions		
Electricity:	Cost Per KWH	\$0.10
Chlorine: (Sodium Hypochlorite)	Cost Per Gallon of Stock Solution	\$1.40
	Concentration of Stock Solution	12.5%
Caustic (NaOH): (Sodium Hydroxide)	Cost Per Gallon of Stock Solution	\$1.80
	Concentration of Stock Solution	25.0%
Citric Acid:	Cost Per Gallon of Stock Solution	\$5.40
	Concentration of Stock Solution	50.0%
Sodium Bisulfite:	Cost Per Gallon of Stock Solution	\$2.45
	Concentration of Stock Solution	40.0%




8 7 6 5 4 3 2 1

D
C
B
A





8 7 6 5 4 3


<p>DO NOT SCALE DRAWING</p>			<p>DO NOT SCALE DRAWING</p>		
<p>DRW BY: PROJECT ENGINEER</p> <p>CHECKER: MANUFACTURING</p> <p>ENGINEERING MANAGER: QUALITY CONTROL</p> <p>RELEASED BY:</p>	<p>NAME: PROJECT ENGINEER</p> <p>DATE: PROJECT ENGINEER</p> <p>DATE: MANUFACTURING</p> <p>DATE: QUALITY CONTROL</p> <p>DATE: PROJECT ENGINEER</p>	<p>PROJECT NO: INCH ONLY</p> <p>SCALE: 1/2" = 1'-0"</p> <p>DATE: PROJECT ENGINEER</p> <p>DATE: MANUFACTURING</p> <p>DATE: QUALITY CONTROL</p> <p>DATE: PROJECT ENGINEER</p>	<p>PALL Pall Corporation PALL TRINITY MICRO CORTLAND, NEW YORK</p>		
<p>COMPANY CONFIDENTIAL</p> <p>This information is the property of PALL CORPORATION and is provided for use of the customer only. It is not to be used for any other purpose without the written consent of PALL CORPORATION. This drawing is not to be used for any other purpose without the written consent of PALL CORPORATION.</p>			<p>PRELIMINARY LAYOUT (2) AP-6</p>		<p>DATE: PROJECT ENGINEER</p> <p>SCALE: 1:32</p> <p>DATE: MANUFACTURING</p> <p>DATE: QUALITY CONTROL</p> <p>DATE: PROJECT ENGINEER</p>




LEFT SIDE VIEW



TOP VIEW



FRONT VIEW



LEFT/FRONT ISOMETRIC VIEW (REMOTE MODULE RACK REMOVED FOR CLARITY)

ARIA SM AP6 SYSTEM WEIGHT				
EQUIPMENT	WEIGHT			
	DRY Lbs.	DRY Kgs.	WET Lbs.	WET Kgs.
SKID	3600	1633	4100	1860
INTERCONNECT	500	227	1900	862
MODULE RACK	3500	1587.5	9000	4082
TOTAL WEIGHT	8400	3810	34000	15422

ITEM	DESCRIPTION	TYPE
P	PARTICLE COUNTER	1/2" FNPT NOTE 9
F	COMPRESSED AIR SUPPLY	1-1/2" FNPT NOTE 9
E	CP MAKE UP WATER	2" FLG NOTE 8 & 9
D	FILTRATE FORWARD	6" FLG NOTE 8 & 9
C5	REVERSE FILTRATION TANK T-2 OVERFLOW	4" NOTE 9
C4	REVERSE FILTRATION TANK T-2 DRAIN	2" SW NOTE 9
C3	FEED TANK T-1 OVERFLOW	6" NOTE 9
C2	FEED TANK T-1 DRAIN	2" SW NOTE 9
C1	MISC. DRAIN	2" FLG NOTE 8 & 9
B	CP/RF/AS DRAIN	6" FLG NOTE 8 & 9
A	FEED	6" FLG NOTE 8 & 9

BATTERY LIMIT CONNECTIONS

DIMENSIONS PROVIDED WITHIN THIS DRAWING ARE FOR REFERENCE ONLY. BECAUSE OF FITTING SIZE VARIATIONS, PRIOR TO MAKING FINAL WELDS, PIPING SHALL BE DRY FIT UP TO FRAME TO ENSURE PROPER ALIGNMENT OF PIPING, FLANGES, BOLT HOLES, ETC.

- NOTES:**
- DO NOT STORE THE MODULES OR THEIR SHIPPING CONTAINERS OUTSIDE OR IN AN AREA WHERE THERE WILL BE EXPOSURE TO DIRECT SUNLIGHT, EXCESSIVE HEAT, OR COLD. PALL CORPORATION REQUIRES MEMBRANES BE STORED IN A CONTROLLED, SECURE ENVIRONMENT TO GUARANTEE MODULES ARE NOT DAMAGED DURING STORAGE.
 - DO NOT DROP OR EXPOSE THE MODULES OR THEIR SHIPPING CONTAINERS TO SHOCK OR IMPACT. THERE MAY BE DAMAGE TO THE MEMBRANE EVEN IF NO VISIBLE DAMAGE TO THE MODULE CASE IS EVIDENT.
 - THE MODULE RACK ASSEMBLY, INTERCONNECT PIPING ASSEMBLY, AND TANKS WILL BE SHIPPED SEPARATELY FOR INSTALLATION IN THE FIELD.
 - THIS DRAWING SHOWS (1) COMPLETE AP6 ASSEMBLY.
 - THE DISKS ON ELASTOMER-SEALED BUTTERFLY VALVES MUST BE AT LEAST PARTIALLY OPEN WHEN TIGHTENING FLANGE BOLTS. FAILURE TO DO SO WILL CAUSE PREMATURE FAILURE, AND WILL VOID ALL WARRANTIES ON THE VALVE.
 - REFER TO INSTALLATION INSTRUCTIONS FOR PIPING ASSEMBLY.
 - THE CONTROL ENCLOSURE IS CONSTRUCTED OF CARBON STEEL, PAINTED BLUE AND RATED NEMA 4. THE USE OF ALL CONDUIT PENETRATION HUBS OF THE SAME ENVIRONMENTAL RATING AS THE ENCLOSURE IS REQUIRED. **DO NOT PENETRATE THE TOP OF THE ENCLOSURE.**
 - ALL FLANGES ARE BOLT CIRCLE/HOLE SIZE EQUIVALENT TO ANSI 150# RATED FLANGES.
 - PIPING, CONNECTING TO PALL EQUIPMENT, MUST BE ADEQUATELY SUPPORTED TO PREVENT ANY NOZZLE LOADS ON THE EQUIPMENT. **DO NOT USE SKID CONNECTIONS TO SUPPORT PIPING.**

SHEET #	DESCRIPTION
1	TOP SYSTEM ASSEMBLY
2	FOOTPRINT LAYOUT/MODULE RACK FRAME ASSEMBLY
3	TANK TO AP SKID INTERCONNECTING PIPING DETAIL
4	AP SKID TO MODULE RACK INTERCONNECTING PIPING DETAIL
5	MODULE RACK ASSEMBLY

ARIASM IS A SERVICE MARK OF PALL CORPORATION.

CODE IDENT. NO. 17238	NAME	DATE	DO NOT SCALE DRAWING
DRAWN BY S. SMITH 02/27/2003	PROJECT ENGINEER M. POORE 02/27/2003		
ENGINEER	ENGINEER	DRAWING NO. 1000000283	TOLERANCE
ENGINEER	ENGINEER	INCHES ONLY	DEC. #
ENGINEER	ENGINEER	FRACTIONS	FRACTION #
CHECKER D. CLARK 02/27/2003		FRESH (LAST)	ANGLE #


PALL Pall Corporation
PALL ADVANCED SEPARATIONS SYSTEMS
CORTLAND, NEW YORK

1000000283 00 D

SYSTEM MF, 02.00013 Z5006

SCALE 1/40

15413 SHEET 1 OF 5



- NOTES:
- AIR SUPPLY: CLEAN, DRY, AND OIL FREE INSTRUMENT GRADE AIR @ 90 PSIG MIN. DELIVERY PRESSURE; 4 SCFM/MODULE + 0.5 CFM FOR VALVES
 - ELECTRICAL SUPPLY: 460VAC
 - ALL FLOWS SHOWN ARE MAXIMUM
 - ALL PIPING IS SCHEDULE 40 PVC U O N


ITEM	DESCRIPTION	TYPE	ZONE
F	AIR SUPPLY FOR AIR SCRUB	2" [50] NPT	C6
E	CIP MAKE UP/EFM WATER	2" [50] FLG	DB
D	FILTRATE FORWARD	6" [150] FLG	D1
C5	MISC. DRAIN OVERFLOW (RF TANK)	4" [100] SW	C2
C3	MISC. DRAIN OVERFLOW (FEED TANK)	6" [150] SW	C7
C2/4	MISC. DRAIN (FEED & RF TANK)	2" [50] SW	B2/C7
C1	MISC. DRAIN (SKID)	2" [50] FLG	AB
B	CIP/RF/AS DRAIN	6" [200] FLG	BB
A	FEED	6" [150] FLG	CB

BATTERY LIMIT CONNECTIONS

LEGEND
 (PALL) (PURCHASER) BATTERY LIMIT - PIPING AND TUBING

CODE BENT. NO. 17238	NAME	DATE	--- DO NOT SCALE DRAWING ---	
DRAWN BY	S. SMITH	12/20/2004	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION PERTAINS ONLY TO THIS SHEET	
PROJECT ENGINEER	M. POORE	12/20/2004	INCHES ARE IN TOLERANCE	
ENGINEER			INCHES ONLY	1/8" ±
ENGINEER			FRACTIONS 1/8"	± 0.005
ENGINEER			SURFACE FINISH	1/8" ±
CHECKER	A. HERRING	12/20/2004	FRONT VIEW	1/8" ±
Copyright 2004 PALL CORPORATION This document may contain confidential technical data. Including trade secrets proprietary to Pall Corporation. The drawing, design rights and all other documents in this document are the property of Pall Corporation. Reproduction, use, copying, distribution to third parties, modification, or reproduction in whole or in part is prohibited.			DRAWING NUMBER 10000001350	
			REVISION 00	
			DWG. SIZE D	
SYSTEM, MF, AP6, 2004, STOCK, R1, P&ID				
			SCALE NONE	
			SHEET 2 of 4	

IMPORTANT: BEFORE ATTEMPTING TO OPERATE OR INSTALL THIS SYSTEM, IT IS ESSENTIAL TO READ AND UNDERSTAND THIS PRODUCT'S OPERATION AND MAINTENANCE MANUAL (SHIPPED UNDER SEPARATE COVER). FAILURE TO READ THE OPERATION AND MAINTENANCE MANUAL BEFORE ATTEMPTING TO OPERATE ANY PALL CORPORATION EQUIPMENT MAY RESULT IN SERIOUS PERSONAL INJURY AND/OR PRODUCT DAMAGE, AND MAY VOID ANY AND/OR ALL WARRANTIES.



ITEM	DESCRIPTION	TYPE	MAT'L	ZONE
L4B/C	EFM INJECTION FROM CIP SKID (P-91, 92)	1/2" [15] TUBE	ODPE	B2,3/C5
L4A	EFM INJECTION FROM CIP SKID (P-90)	3/8" [10] TUBE	ODPE	B4, C5
L2A/B	CIP XFER SYSTEM MANIFOLD (TO AP SKIDS)	2" [50] FLG	PVC	C4
J1B	COMPRESSED AIR EFM SKID TO CIP SKID	1/2" [15] FNPT	ODPE	A4/B5
J1A	COMPRESSED AIR EFM	1/2" [15] FNPT	SST	B8
H5	NaOCl FOR EFM	3/8" [10] TUBE	PE	B5
H4	EFM SKID OUTLET (TO NEUTRALIZATION)	2" [50] FLG	PVC	C3
H3	HOT WATER TANK DRAIN	1" [25] FLG	PVC	C8
H2	HOT WATER TANK OVERFLOW DRAIN	2" [50] SW	PVC	D8
H1	EFM SKID INLET	2" [50] FLG	PVC	D5

BATTERY LIMIT TABLE

- NOTES:
 1 HOT WATER TANK TO BE SHIPPED LOOSE AND INSTALLED IN FIELD BY OTHERS.
 2 ALL INSTRUMENTS AND/OR EQUIPMENT TO BE CONNECTED TO CHN PANEL.

CODE IDENT. NO. 17238 NAME DATE --- DO NOT SCALE DRAWING ---

DESIGNED BY S. SMITH SCHWABCO
 PROJECT ENGINEER M. POOLE SCHWABCO

ENGINEER
 ENGINEER
 ENGINEER
 CHECKER J. HOSBY SCHWABCO

UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION APPLIES ONLY TO THIS SHEET

UNITS ARE IN INCHES ONLY

SCALE: SURFACE FINISH

PROJECTION: THIRD ANGLE

SCALE: NONE

INTEGRAL NUMBER

DATE: 10/00

REVISION: 00

DWG SIZE: D

DRAWING NUMBER: 10000001350

PROJECT: SYSTEM, MF, AP6, 2004, STOCK, R1, P&ID

Copyright 2004 PALL CORPORATION


This document may contain confidential technical data, including trade secrets proprietary to Pall Corporation. The drawing, design rights and all other disclosures in this document are the property of Pall Corporation. Unauthorized use, copying, distribution to third parties, reproduction, or reproduction in whole or in part is prohibited.

PALL Pall Corporation
 Pall Advanced Separations Systems
 Corland, New York


SHEET 3 OF 4

IMPORTANT: BEFORE ATTEMPTING TO OPERATE OR INSTALL THIS SYSTEM, IT IS ESSENTIAL TO READ AND UNDERSTAND THIS PRODUCT'S OPERATION AND MAINTENANCE MANUAL (SHIPPED UNDER SEPARATE COVER). FAILURE TO READ THE OPERATION AND MAINTENANCE MANUAL BEFORE ATTEMPTING TO OPERATE ANY PALL CORPORATION EQUIPMENT MAY RESULT IN SERIOUS PERSONAL INJURY AND/OR PRODUCT DAMAGE AND MAY VOID ANY AND/OR ALL WARRANTIES.


VALVE SYMBOLS



TYPICAL SYMBOLS




TYPICAL SYMBOLS



COLOR CODE
R=RED
A=AMBER
G=GREEN
B=BLUE
W=WHITE

TYPICAL SYMBOLS



FLOW INSTRUMENTS

FC	FLOW CONTROLLER (BLIND)
FCV	FLOW CONTROL VALVE
FE	FLOW ELEMENT
FFC	FLOW RATIO CONTROLLER
FG	FLOW SIGHT GLASS
FI	FLOW INDICATOR
FIC	FLOW INDICATOR CONTROLLER
FIT	FLOW INDICATOR TRANSMITTER
FM	FLOW METER
FQ	FLOW TOTALIZER
FQC	FLOW TOTALIZER CONTROLLER
FR	FLOW RECORDER
FRC	FLOW RECORDER CONTROLLER
FSH	FLOW SWITCH HIGH
FSHH	FLOW SWITCH HIGH HIGH
FSL	FLOW SWITCH LOW
FSLL	FLOW SWITCH LOW LOW
FT	FLOW TRANSMITTER (BLIND)
FX	FLOW INTEGRATOR

PRESSURE INSTRUMENTS

DSPH	DIFFERENTIAL SET POINT INDICATOR
PC	PRESSURE CONTROLLER (BLIND)
PCV	PRESSURE CONTROL VALVE
PDC	PRESSURE DIFFERENTIAL CONTROLLER
PDH	DIFFERENTIAL PRESSURE HIGH
PDHH	DIFFERENTIAL PRESSURE HIGH HIGH
PDI	DIFFERENTIAL PRESSURE INDICATOR
PDS	DIFFERENTIAL PRESSURE SWITCH
PHC	PRESSURE HAND CONTROL (REGULATOR)
PI	PRESSURE INDICATOR
PIC	PRESSURE INDICATING CONTROLLER
PIS	PRESSURE INDICATING SWITCH
PIT	PRESSURE INDICATING TRANSMITTER
PLH	PRESSURE LIMIT HIGH
PR	PRESSURE RECORDER
PRC	PRESSURE RECORDER CONTROLLER
PSH	PRESSURE SWITCH HIGH
PSHH	PRESSURE SWITCH HIGH HIGH
PSL	PRESSURE SWITCH LOW
PSLL	PRESSURE SWITCH LOW LOW
PT	PRESSURE TRANSMITTER (BLIND)

LEVEL INSTRUMENTS

LC	LEVEL CONTROLLER (BLIND)
LCV	LEVEL CONTROL VALVE
LE	LEVEL ELEMENT
LG	LEVEL GAGE GLASS
L	LEVEL INDICATOR
LIC	LEVEL INDICATOR CONTROLLER
LIT	LEVEL INDICATING TRANSMITTER
LR	LEVEL RECORDER
LRC	LEVEL RECORDING CONTROLLER
LSH	LEVEL SWITCH HIGH
LSHH	LEVEL SWITCH HIGH HIGH
LSL	LEVEL SWITCH LOW
LSLL	LEVEL SWITCH LOW LOW
LSM	LEVEL SWITCH MID
LT	LEVEL TRANSMITTER (BLIND)

TEMPERATURE INSTRUMENTS





TC	TEMPERATURE CONTROLLER (BLIND)
TCV	TEMPERATURE CONTROL VALVE
TE	TEMPERATURE ELEMENT
TI	TEMPERATURE INDICATOR
TIC	TEMPERATURE INDICATING CONTROLLER
TIT	TEMPERATURE INDICATING TRANSMITTER
TLH	TEMPERATURE LIMIT HIGH
TR	TEMPERATURE RECORDER
TRC	TEMPERATURE RECORDER CONTROLLER
TSH	TEMPERATURE SWITCH HIGH
TSHH	TEMPERATURE SWITCH HIGH HIGH
TSL	TEMPERATURE SWITCH LOW
TSLL	TEMPERATURE SWITCH LOW LOW
TT	TEMPERATURE TRANSMITTER

MISCELLANEOUS

AE	ANALYTICAL ELEMENT
AIT	ANALYTICAL INDICATING TRANSMITTER
A.S.	AIR SUPPLY
A.T.A.	AIR TO ACTIVATE
A.T.C.	AIR TO CLOSE
A.T.O.	AIR TO OPEN
CY	CHECK VALVE
DE	DE-ENERGIZE
DPI	DIFFERENTIAL PRESSURE INDICATOR
E	ENERGIZE
EX	EXHAUST
H	HEATER
HV	HAND VALVE (MANUAL)
I/P	CURRENT TO PNEUMATIC TRANSDUCER
LS	LIMIT SWITCH
M	MECHANICAL DEVICE/MISCELLANEOUS
N.C.	NORMALLY CLOSED
N.O.	NORMALLY OPEN
NV	NEEDLE VALVE
O/C/A	OPEN-CLOSE-AUTO
ORP	OXIDATION REDUCTION POTENTIAL
P	PUMP
P/A	PULSE TO ANALOG
P/I	PNEUMATIC TO CURRENT TRANSDUCER
PRD	PRESSURE RUPTURE DISK
PS	PUMP SPEED
REV.	REVERSING
SG	SIGHT GLASS
S.P.	SET POINT
SS	SELECTOR SWITCH
SV	SOLENOID VALVE
T	TANK
TS	TRAVEL STOP
TYP	TYPICAL
UA	MULTIVARIABLE ALARM
UON	UNLESS OTHERWISE NOTED
V	VALVE (ACTUATED)
VFC	VOLT FREE CONTACT
VFD	VARIABLE FREQUENCY DRIVE
Y	CONVERTER

IMPORTANT: BEFORE ATTEMPTING TO OPERATE OR INSTALL THIS SYSTEM, IT IS ESSENTIAL TO READ AND UNDERSTAND THIS PRODUCT'S OPERATION AND MAINTENANCE MANUAL (SHIPPED UNDER SEPARATE COVER). FAILURE TO READ THE OPERATION AND MAINTENANCE MANUAL BEFORE ATTEMPTING TO OPERATE ANY PALL CORPORATION EQUIPMENT MAY RESULT IN SERIOUS PERSONAL INJURY AND/OR PRODUCT DAMAGE, AND MAY VOID ANY AND/OR ALL WARRANTIES.

CODE IDENT. NO. 17238	NAME	DATE	DO NOT SCALE DRAWING	
DRAWN BY S. SMITH	DATE	DATE	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION APPLIES ONLY TO THIS SHEET	
PROJECT ENGINEER M. POOLE	DATE	DATE	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION APPLIES ONLY TO THIS SHEET	
ENGINEER	DATE	DATE	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION APPLIES ONLY TO THIS SHEET	
ENGINEER	DATE	DATE	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION APPLIES ONLY TO THIS SHEET	
ENGINEER	DATE	DATE	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION APPLIES ONLY TO THIS SHEET	
CHECKER	DATE	DATE	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION APPLIES ONLY TO THIS SHEET	
Copyright 2004 PALL CORPORATION			PALL Pall Corporation	
This document contains confidential technical data, including trade secrets proprietary to Pall Corporation. The drawing design rights and all other documents in this document are the property of Pall Corporation. Unauthorized use, copying, distribution to third parties, modification, or reproduction in whole or in part is prohibited.			Pall Advanced Separations Systems Corland, New York	
DRAWING NAME			DRAWING NUMBER	
SYSTEM, MF, AP6, 2004, STOCK, R1, P&ID			1000001350	
SCALE			NONE	
SHEET NUMBER			00	
SHEET SIZE			D	
SHEET 4 OF 4				



ITEM	DESCRIPTION	TYPE	
F	COMPRESSED AIR SUPPLY	1-1/2" [40] FNPT	NOTE 9
E	CIP MAKE UP WATER	2" [50] FLG	NOTE 8 & 9
D	FILTRATE FORWARD	6" [150] FLG	NOTE 8 & 9
C5	REVERSE FILTRATION TANK T-2 OVERFLOW	4" [100] SW	NOTE 9
C4	REVERSE FILTRATION TANK T-2 DRAIN	2" [50] SW	NOTE 9
C3	FEED TANK T-1 OVERFLOW	8" [200] SW	NOTE 9
C2	FEED TANK T-1 DRAIN	2" [50] SW	NOTE 9
C1	MISC. DRAIN	2" [50] FLG	NOTE 8 & 9
B	CIP/RF/AS DRAIN	8" [200] FLG	NOTE 8 & 9
A	FEED	6" [150] FLG	NOTE 8 & 9

BATTERY LIMIT CONNECTIONS

- NOTES:
- DO NOT STORE THE MODULES OR THEIR SHIPPING CONTAINERS OUTSIDE OR IN AN AREA WHERE THERE WILL BE EXPOSURE TO DIRECT SUNLIGHT, EXCESSIVE HEAT, OR COLD. PALL CORPORATION REQUIRES MEMBRANES BE STORED IN A CONTROLLED, SECURE ENVIRONMENT TO GUARANTEE MODULES ARE NOT DAMAGED DURING STORAGE.
 - DO NOT DROP OR EXPOSE THE MODULES OR THEIR SHIPPING CONTAINERS TO SHOCK OR IMPACT. THERE MAY BE DAMAGE TO THE MEMBRANE EVEN IF NO VISIBLE DAMAGE TO THE MODULE CASE IS EVIDENT.
 - THE MODULE RACK ASSEMBLY, INTERCONNECT PIPING ASSEMBLY, AND TANKS WILL BE SHIPPED SEPARATELY FOR INSTALLATION IN THE FIELD.
 - THIS DRAWING SHOWS (1) COMPLETE AP6 ASSEMBLY.
 - THE DISKS ON ELASTOMER-SEATED BUTTERFLY VALVES MUST BE AT LEAST PARTIALLY OPEN WHEN TIGHTENING FLANGE BOLTS. FAILURE TO DO SO WILL CAUSE PREMATURE FAILURE, AND WILL VOID ALL WARRANTIES ON THE VALVE.
 - REFER TO INSTALLATION INSTRUCTIONS FOR PIPING ASSEMBLY.
 - THE CONTROL ENCLOSURE IS CONSTRUCTED OF CARBON STEEL, PAINTED BLUE AND RATED NEMA 4. THE USE OF ALL CONDUIT PENETRATION HUBS OF THE SAME ENVIRONMENTAL RATING AS THE ENCLOSURE IS REQUIRED.
DO NOT PENETRATE THE TOP OF THE ENCLOSURE.
 - ALL FLANGES ARE BOLT CIRCLE/HOLE SIZE EQUIVALENT TO ANSI 150# RATED FLANGES.
 - PIPING, CONNECTING TO PALL EQUIPMENT, MUST BE ADEQUATELY SUPPORTED TO PREVENT ANY NOZZLE LOADS ON THE EQUIPMENT.
DO NOT USE SKID CONNECTIONS TO SUPPORT PIPING.

AP6 SYSTEM WEIGHT				
WEIGHT				
EQUIPMENT	DRY Lbs.	DRY Kgs.	WET Lbs.	WET Kgs.
SKID	3,600	1,633	4,100	1,860
INTERCONNECT	1,000	453	2,100	953
MODULE RACK	7,200	3,266	9,000	4,082
TANKS	800	363	19,000	8,618
TOTAL WEIGHT	12,600	5,715	34,200	15,513

TABLE OF CONTENTS	
SHEET #	DESCRIPTION
1	TOP SYSTEM ASSEMBLY
2	AP6 SKID LAYOUT
3	FOOTPRINT LAYOUT
4	TANK TO AP SKID INTERCONNECTING PIPING DETAIL
5	AP SKID TO MODULE RACK INTERCONNECTING PIPING DETAIL

DIMENSIONS PROVIDED WITHIN THIS DRAWING ARE FOR REFERENCE ONLY. BECAUSE OF FITTING SIZE VARIATIONS, PRIOR TO MAKING FINAL WELDS, PIPING SHALL BE DRY FIT UP TO FRAME TO ENSURE PROPER ALIGNMENT OF PIPING, FLANGES, BOLT HOLES, ETC.


PALL ARIA™ AP-6 SYSTEM

IMPORTANT: BEFORE ATTEMPTING TO OPERATE OR INSTALL THIS SYSTEM, IT IS ESSENTIAL TO READ AND UNDERSTAND THIS PRODUCT'S OPERATION AND MAINTENANCE MANUAL (SHIPPED UNDER SEPARATE COVER). FAILURE TO READ THE OPERATION AND MAINTENANCE MANUAL BEFORE ATTEMPTING TO OPERATE ANY PALL CORPORATION EQUIPMENT MAY RESULT IN SERIOUS PERSONAL INJURY AND/OR PRODUCT DAMAGE, AND MAY VOID ANY AND/OR ALL WARRANTIES.


CODE IDENT. NO. 17238	NAME	DATE	--> DO NOT SCALE DRAWING <--	
DRAWN BY S. SMITH	08AUG2007	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION PERTAINS ONLY TO THIS SHEET		
PROJECT ENGINEER M. POOLE	21AUG2007	TOLERANCE		
ENGINEER		DIMENSIONS ARE IN	X ±	XXX ±
ENGINEER		INCHES [mm]		
ENGINEER		SURFACE FINISH	X ±	FRACTION ± 1/8
CHECKER J. HOSKINS	21AUG2007		XX ±	ANGLE ± 7'
Copyright 2007 PALL CORPORATION		DRAWING NAME		
This document may contain confidential technical data, including trade secrets proprietary to Pall Corporation. The drawing, design rights and all other disclosures in this document are the property of Pall Corporation. Unauthorized use, copying, distribution to third parties, manufacture, or reproduction in whole or in part is prohibited.		ASSY,FILTSKID,AP6,2008,R1,0DEG,QUAD,C		
THIRD ANGLE PROJECTION		SCALE	MATERIAL NUMBER	SHEET 1 OF 5
		1/40		

PALL Pall Corporation
Pall Advanced Separations Systems
Corland, New York


DRAWING NUMBER: **1000014584** REVISION: **00** DWG SIZE: **D**




LEFT/FRONT ISOMETRIC VIEW




TOP VIEW
(AP6 SKID ONLY)




RIGHT/REAR ISOMETRIC VIEW



LEFT SIDE VIEW
(AP6 SKID ONLY)




FRONT VIEW
(AP6 SKID ONLY)




RIGHT SIDE VIEW
(AP SKID MODULE RACK INTERCONNECT)
SCALE: 1/16

CODE IDENT. NO. 17238	NAME	DATE	--> DO NOT SCALE DRAWING <--	
DRAWN BY	S. SMITH	08AUG2007	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION PERTAINS ONLY TO THIS SHEET	
PROJECT ENGINEER	M. POOLE	21AUG2007	DIMENSIONS ARE IN INCHES [mm]	
ENGINEER			TOLERANCE	
ENGINEER			X ± XXX ±	
ENGINEER			SURFACE FINISH: XX ± FRACTION ± 1/8	
CHECKER	J. HOSKINS	21AUG2007	ANGLE ± 7'	
Copyright 2007 PALL CORPORATION			DRAWING NAME	
This document may contain confidential technical data, including trade secrets proprietary to Pall Corporation. The drawing, design rights and all other disclosures in this document are the property of Pall Corporation. Unauthorized use, copying, distribution to third parties, manufacture, or reproduction in whole or in part is prohibited.			ASSY,FILTSKID,AP6,2008,R1,0DEG,QUAD,C	
IMPORTANT: BEFORE ATTEMPTING TO OPERATE OR INSTALL THIS SYSTEM, IT IS ESSENTIAL TO READ AND UNDERSTAND THIS PRODUCT'S OPERATION AND MAINTENANCE MANUAL (SHIPPED UNDER SEPARATE COVER). FAILURE TO READ THE OPERATION AND MAINTENANCE MANUAL BEFORE ATTEMPTING TO OPERATE ANY PALL CORPORATION EQUIPMENT MAY RESULT IN SERIOUS PERSONAL INJURY AND/OR PRODUCT DAMAGE, AND MAY VOID ANY AND/OR ALL WARRANTIES.			SCALE 1/20	
Page 210			MATERIAL NUMBER	
			REVISION 00	
			DWG SIZE D	
			DRAWING NUMBER 1000014584	
			SHEET 2 OF 5	


PALL ARIA™ AP-6 SYSTEM




INTERCONNECT SUPPORT BASEPAD
(5) REQUIRED
SCALE: 1/4




MODULE RACK BASEPAD DETAIL
TOP VIEW - (5) REQUIRED
SCALE: 1/8



MODULE RACK/TANK HOUSEKEEPING PAD DETAIL
(BY OTHERS)
SEE NOTE 1 & 2
SCALE: 1/16



BASEPAD FOOTPRINT LAYOUT
TOP VIEW
SEE NOTE 1
SCALE: 1/2"=1'



AP6 BASEPAD DETAIL
(6) REQUIRED
SCALE: 1/4

NOTES:

- 1.) THE TANKS T-1, T-2 AND THE MODULE RACK BASE PLATES ARE ELEVATED 7-1/2" HIGHER THAN THE AP6 BASE PLATES; THE EQUIPMENT MOUNTING PADS SHALL BE POURED TO ACCOMMODATE THIS DIFFERENCE. HOUSEKEEPING PAD TO BE SIZED, SUPPLIED AND INSTALLED BY OTHERS. HOUSEKEEPING PAD IS TO BE POURED LEVEL TO ACCOMMODATE MODULE RACK AND TANKS T-1 AND T-2.
- 2.) IT IS RECOMMENDED THAT THE MODULE RACK/TANK HOUSEKEEPING PADS EXTEND 6" ON ALL SIDES OF EQUIPMENT.
- 3.) ANCHOR BOLTS FOR SECURING MODULE RACK TO HOUSEKEEPING PAD TO BE SIZED, SUPPLIED AND INSTALLED BY OTHERS.
- 4.) AFTER LEVELING OF MODULE RACK, SHIM AND GROUT AS NECESSARY (BY OTHERS).
- 5.) THE MODULE RACK FRAME IS SHIPPED UNASSEMBLED.
- 6.) DO NOT ANCHOR MODULE RACK FRAME UNTIL ALL INTERCONNECT PIPING FROM AP6 SKID TO MODULE RACK IS INSTALLED.

CODE IDENT. NO. 17238	NAME	DATE	-- DO NOT SCALE DRAWING --	
DRAWN BY	S. SMITH	08AUG2007	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION PERTAINS ONLY TO THIS SHEET	
PROJECT ENGINEER	M. POOLE	21AUG2007	DIMENSIONS ARE IN	TOLERANCE
ENGINEER	----	----	INCHES [mm]	X ± XXX ±
ENGINEER	----	----		FRACTION ± 1/8
ENGINEER	----	----	SURFACE FINISH	XX ± ANGLE ± °
CHECKER	J. HOSKINS	21AUG2007		

PALL ARIA™ AP-6 SYSTEM

IMPORTANT: BEFORE ATTEMPTING TO OPERATE OR INSTALL THIS SYSTEM, IT IS ESSENTIAL TO READ AND UNDERSTAND THIS PRODUCT'S OPERATION AND MAINTENANCE MANUAL (SHIPPED UNDER SEPARATE COVER). FAILURE TO READ THE OPERATION AND MAINTENANCE MANUAL BEFORE ATTEMPTING TO OPERATE ANY PALL CORPORATION EQUIPMENT MAY RESULT IN SERIOUS PERSONAL INJURY AND/OR PRODUCT DAMAGE, AND MAY VOID ANY AND/OR ALL WARRANTIES.

PALL Corporation

Pall Advanced Separations Systems
Cortland, New York










DRAWING NUMBER
1000014584

REVISION
00

DWG SIZE
D

ASSY,FILTSKID,AP6,2008,R1,0DEG,QUAD,C

THIRD ANGLE PROJECTION	SCALE 1/16	MATERIAL NUMBER	SHEET 3 OF 5
------------------------	---------------	-----------------	-----------------




TANK T-1/T-2 DRAIN CONNECTION "C2" (2505) & "C4" (2602)
 (RF TANK TO CUSTOMER DRAIN)
 (SEE NOTE 3 THIS SHEET)



INTERCONNECT-TANK/P-2 (2600)
 (FEED TANK TO ARIA AP6 FEED PUMP P-2)
 (SEE NOTE 2 THIS SHEET)

"TANK T-2 OVERFLOW CONNECTION "C5" (2601)
 (RF TANK TO CUSTOMER DRAIN)
 (SEE NOTE 3 THIS SHEET)


INTERCONNECT-TANK/P-1 (2500)
 (FEED TANK TO ARIA AP6 FEED PUMP P-1)
 (SEE NOTE 2 THIS SHEET)



INTERCONNECT-TANK/AP SKID EXCESS RECIRC. (2502)
 (FEED TANK TO AP6 EXCESS RECIRC. CONNECTION)





TANK T-1 OVERFLOW CONNECTION "C3" (2504)
 (FEED TANK TO CUSTOMER DRAIN)
 (SEE NOTE 3 THIS SHEET)




DIMENSIONS PROVIDED WITHIN THIS DRAWING ARE FOR REFERENCE ONLY.

- NOTES:**
- 1.) INTERCONNECT PIPING SUPPORTS TO BE LOCATED AS CLOSE TO TANK CONNECTION AS POSSIBLE. ADJUSTMENT OF SUPPORTS TO REMOVE NOZZLE LOAD FROM TANKS IS REQUIRED.
 - 2.) INTERCONNECT PIPING ITEMS 2500 & 2600 ARE TO BE INSTALLED PRIOR TO ALL OTHER INTERCONNECT PIPE RUNS FROM AP SKID. TANK LOCATION TO BE ADJUSTED FOR FIT-UP.
 - 3.) TANK OVERFLOW AND DRAIN PIPING TO BE SUPPORTED AT TANK CONNECTION (BY OTHERS).
 - 4.) ANCHOR BOLTS FOR SECURING PIPE SUPPORTS TO BE SIZED, SUPPLIED AND INSTALLED BY OTHERS.
 - 5.) ALL TANK INTERCONNECT PIPING TO BE SHIPPED LOOSE AND TO INCLUDE 6" ADDITIONAL LENGTH PER CUT FOR FIELD FIT-UP TO PALL AUSTRALIA SUPPLIED TANKS.




INTERCONNECT-TANK/POTABLE WATER (2501)
 (FEED TANK TO ARIA AP6 CONNECTION "E")



INTERCONNECT-TANK/FEED WATER (2503)
 (FEED TANK TO ARIA AP6 CONNECTION "A")
 SCALE: 1/20








- △ LABEL PIPE OR EQUIPMENT FOR FIELD INSTALLATION. INSTRUMENTS TO BE PACKAGED AND LABELED ON OUTSIDE OF BOX. TEXT IS TO BE WRITTEN IN BLACK CHARACTERS ON A LAMINATED WHITE ADHESIVE LABEL, WITH A TEXT HEIGHT OF 3/16."
- △ PACKAGE AND LABEL PARTS ACCORDING TO ITEM NUMBER. PACKAGES WITH MULTIPLE PARTS WILL HAVE QUANTITY INDICATED.
- △ TAKE NOTE; MACHINE GROOVE ON INTERCONNECT PIPING TO BE UTILIZED FOR CONNECTION TO TANKS AND SKID.



NOTE:
 ALL TANK INTERCONNECT PIPING TO BE SHIPPED LOOSE AND TO INCLUDE 6" ADDITIONAL LENGTH PER CUT FOR FIELD FIT-UP TO PALL AUSTRALIA SUPPLIED TANKS.

ITEM	QTY	UNIT	SAP NO	DESCRIPTION
2612	1	EA	12782	CLAMP,6.0IN,GRV,7000,CS,GALV,18-8BLT
2611	1	EA	12780	CLAMP,4.0IN,GRV,7000,CS,GALV,18-8BLT
2605	1	EA	10731	PRESS TRANS,ROSEMOUNT,0-30PSI (LIT-2)
2604	1	EA	12660	TANK, 1100 GAL, HDPE (T-2)
2603	1	EA	14895	FILTER, TANK VENT, 3.00 IN MPT (F-1)
2602	1	EA	-----	PIPE, ASSEMBLY, TANK T-2 DRAIN, PVC
2601	1	EA	-----	PIPE, ASSEMBLY, TANK T-2 OVERFLOW, PVC
2600	1	EA	-----	PIPE, ASSEMBLY, AP PUMP P-2 TO TANK T-2, SST
2513	2	EA	12784	CLAMP,8.0IN,GRV,7000,CS,GALV,18-8BLT
2512	2	EA	12782	CLAMP,6.0IN,GRV,7000,CS,GALV,18-8BLT
2511	2	EA	12780	CLAMP,4.0IN,GRV,7000,CS,GALV,18-8BLT
2510	2	EA	12776	CLAMP,2.0IN,GRV,7000,CS,GALV,18-8BLT
2509	1	EA	12660	TANK, 1100 GAL, HDPE (T-1)
2508	1	EA	-----	PIPE SUPPORT, EXCESS RECIRC. INT. TO T-1, CS
2506	1	EA	10731	PRESS TRANS,ROSEMOUNT,0-30PSI (LIT-1)
2505	1	EA	-----	PIPE,ASSY,TANK T-1 DRAIN,PVC
2504	1	EA	-----	PIPE,ASSY,TANK T-1 OVERFLOW,PVC
2503	1	EA	-----	PIPE,ASSY,AP SKID CONN. "A" TO TANK T-1, PVC
2502	1	EA	-----	PIPE,ASSY,AP SKID EXCESS RECIRC. TO TANK T-1, PVC
2501	1	EA	-----	PIPE,ASSY,AP SKID CONNECTION "E" TO TANK T-1, PVC
2500	1	EA	-----	PIPE,ASSY,AP PUMP P-1 TO TANK T-1, SST

CODE IDENT. NO. 17238	NAME	DATE	-- DO NOT SCALE DRAWING --	
DRAWN BY S. SMITH	08AUG2007	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION PERTAINS ONLY TO THIS SHEET		
PROJECT ENGINEER M. POOLE	21AUG2007	DIMENSIONS ARE IN INCHES [mm]		
ENGINEER	-----	TOLERANCE	X ± XXX ±	
ENGINEER	-----	SURFACE FINISH	X ± FRACTION ± 1/8	
CHECKER J. HOSKINS	21AUG2007	ANGLE	XX ± Z	
Copyright 2007 PALL CORPORATION		DRAWING NAME		
THIS DOCUMENT MAY CONTAIN CONFIDENTIAL TECHNICAL DATA, INCLUDING TRADE SECRETS PROPRIETARY TO PALL CORPORATION. THE DRAWING, DESIGN RIGHTS AND ALL OTHER DISCLOSURES IN THIS DOCUMENT ARE THE PROPERTY OF PALL CORPORATION. UNAUTHORIZED USE, COPYING, DISTRIBUTION TO THIRD PARTIES, MANUFACTURE, OR REPRODUCTION IN WHOLE OR IN PART IS PROHIBITED.		ASSY,FILTSKID,AP6,2008,R1,ODEG,QUAD,C		
PALL ARIA™ AP-6 SYSTEM		SCALE	1/16	
IMPORTANT: BEFORE ATTEMPTING TO OPERATE OR INSTALL THIS SYSTEM, IT IS ESSENTIAL TO READ AND UNDERSTAND THIS PRODUCT'S OPERATION AND MAINTENANCE MANUAL (SHIPPED UNDER SEPARATE COVER). FAILURE TO READ THE OPERATION AND MAINTENANCE MANUAL BEFORE ATTEMPTING TO OPERATE ANY PALL CORPORATION EQUIPMENT MAY RESULT IN SERIOUS PERSONAL INJURY AND/OR PRODUCT DAMAGE, AND MAY VOID ANY AND/OR ALL WARRANTIES.		MATERIAL NUMBER	1000014584	
Page 212		THIRD ANGLE PROJECTION	REVISION 00 DWG SIZE D	
				SHEET 4 OF 5



DIMENSIONS PROVIDED WITHIN THIS DRAWING ARE FOR REFERENCE ONLY.

- △ LABEL PIPE OR EQUIPMENT FOR FIELD INSTALLATION, INSTRUMENTS TO BE PACKAGED AND LABELED ON OUTSIDE OF BOX. TEXT IS TO BE WRITTEN IN BLACK CHARACTERS ON A LAMINATED WHITE ADHESIVE LABEL, WITH A TEXT HEIGHT OF 3/16."
- △ PACKAGE AND LABEL PARTS ACCORDING TO ITEM NUMBER. PACKAGES WITH MULTIPLE PARTS WILL HAVE QUANTITY INDICATED.
- △ TAKE NOTE; MACHINE GROOVE ON INTERCONNECT PIPING TO BE UTILIZED FOR CONNECTION TO MODULE RACK AND SKID.

- NOTES:**
- 1.) INTERCONNECT PIPING ITEM 2200/2207 TO BE INSTALLED PRIOR TO ALL OTHER INTERCONNECT PIPE RUNS FROM AP SKID TO MODULE RACK.
 - 2.) INTERCONNECT PIPING SUPPORTS TO BE LOCATED AS CLOSE TO AP SKID/MODULE RACK CONNECTIONS AS POSSIBLE TO AVOID NOZZLE LOAD.

ITEM	QTY	UNIT	SAP NO	DESCRIPTION
2207	1	EA	19039	ASSY,AIR,HOSE,FLEX,ODEG,AP6
2206	1	EA	-----	PIPE SUPPORT, INTERCONNECT PIPE RUN SUPPORT, CS
2205	1	EA	-----	PIPE SUPPORT, INTERCONNECT PIPE RUN SUPPORT, CS
2204	2	EA	-----	PIPE SUPPORT, INTERCONNECT PIPE RUN SUPPORT, CS
2203	1	EA	-----	PIPE,ASSY,XR,SKID TO MODULE RACK,PVC
2202	1	EA	-----	PIPE,ASSY,FILT,SKID TO MODULE RACK,PVC/HDPE
2201	1	EA	-----	PIPE,ASSY,FEED,SKID TO MODULE RACK,PVC/HDPE
2200	1	EA	-----	PIPE,ASSY,AS, SKID TO MODULE RACK,HDPE
1917	3	EA	12782	CLAMP,6.0IN,GRV,7000,CS,GALV,18-8BLT
1916	3	EA	28799	CLAMP,6.0IN,GRV,7307,CS,GALV,18-8BLT
1908	8	EA	30019	CLAMP,6.0IN,GRV,7305,CS,GALV,18-8BLT
1907	4	EA	12776	CLAMP,2.0IN,GRV,7000,CS,GALV,18-8BLT

CODE IDENT. NO. 17238	NAME	DATE	--> DO NOT SCALE DRAWING <--	
DRAWN BY	S. SMITH	08AUG2007	UNLESS OTHERWISE SPECIFIED, THE FOLLOWING INFORMATION PERTAINS ONLY TO THIS SHEET	
PROJECT ENGINEER	M. POOLE	21AUG2007	DIMENSIONS ARE IN INCHES [mm]	
ENGINEER	-----	-----	TOLERANCE	XXX ±
ENGINEER	-----	-----	X ±	XXX ±
ENGINEER	-----	-----	XX ±	XXX ±
CHECKER	J. HOSKINS	21AUG2007	SURFACE FINISH	XX ±
			ANGLE	7'

Copyright 2007 PALL CORPORATION
This document may contain confidential technical data, including trade secrets proprietary to Pall Corporation. The drawing, design rights and all other disclosures in this document are the property of Pall Corporation. Unauthorized use, copying, distribution to third parties, manufacture, or reproduction in whole or in part is prohibited.

PALL ARIA™ AP-6 SYSTEM

IMPORTANT: BEFORE ATTEMPTING TO OPERATE OR INSTALL THIS SYSTEM, IT IS ESSENTIAL TO READ AND UNDERSTAND THIS PRODUCT'S OPERATION AND MAINTENANCE MANUAL (SHIPPED UNDER SEPARATE COVER). FAILURE TO READ THE OPERATION AND MAINTENANCE MANUAL BEFORE ATTEMPTING TO OPERATE ANY PALL CORPORATION EQUIPMENT MAY RESULT IN SERIOUS PERSONAL INJURY AND/OR PRODUCT DAMAGE, AND MAY VOID ANY AND/OR ALL WARRANTIES.

PALL Corporation
Pall Advanced Separations Systems
Cortland, New York

DRAWING NUMBER: **1000014584** REVISION: **00** DWG SIZE: **D**

DRAWING NAME: **ASSY,FILTSKID,AP6,2008,R1,ODEG,QUAD,C**





THIRD ANGLE PROJECTION

SCALE: **1/16**

MATERIAL NUMBER

SHEET **5** OF **5**

EXAMPLE SALES DRAWING



DO NOT SCALE DRAWING REFER TO AEDGE ENGINEERING DEPARTMENT FOR ALL DIMENSIONS.

REV #	DATE	REVISIONS

This drawing is the exclusive property of AdEdge Water Technologies, LLC. Its acceptance constitutes an agreement that it shall be expressly used for subject project and shall be returned upon request. Information contained on, or derived from this drawing, is not to be communicated, disclosed, used or copied without prior authorization.


AdEdge
water technologies
2055 Boggs Road
Duluth, GA 30096
P. 678-835-0052 F. 678-835-0053
www.adedgetechnologies.com

TP	SERVICE CONNECTIONS	TYPE / MATERIAL
A/D	RAW WATER INLET	6" FLANGE, SCH 80 PVC
B/E	BLENDED PRODUCT OUTLET	6" FLANGE, SCH 80 PVC
C/F	REJECT WATER OUTLET	3" FLANGE, SCH 80 PVC

Title: GENERAL ARRANGEMENT DRAWING RO1 AND RO2
REVERSE OSMOSIS SYSTEM
MODEL: ADRO8-6L-10H (7 x 3 ARRAY)

Designed by	Checked by	Approved by	Project	Date	Scale
			FCPA-0616		
Customer: GENERAL ARRANGEMENT					
Dwg. File	FCPA-0616.GA.01_A(1)	Rev. Date	Rev.No	Sheet	

EXAMPLE SALES DRAWING



DESIGN CRITERIA:

RAW WATER FLOW:	500 GPM
PUMP FLOW:	355 GPM
PERMEATE FLOW:	270 GPM
BYPASS HEADER FLOW:	170 GPM
REJECT FLOW:	85 GPM
RECIRCULATION:	25 GPM
REJECT FLOW TO DRAIN:	60 GPM
BLENDED PRODUCT FLOW:	440 GPM
FEED PRESSURE TO 1st STAGE:	169 PSI
REJECT PRESSURE:	104 PSI
PERMEATE PRESSURE:	20 PSI

DO NOT SCALE DRAWING REFER TO AEDGE ENGINEERING DEPARTMENT FOR ALL DIMENSIONS.

REV #	DATE	REVISIONS

This drawing is the exclusive property of AdEdge Water Technologies, LLC. Its acceptance constitutes an agreement that it shall be expressly used for subject project and shall be returned upon request. Information contained on, or derived from this drawing, is not to be communicated, disclosed, used or copied without prior authorization.

AdEdge
water technologies
2055 Boggs Road
Duluth, GA 30096
P. 678-835-0052 F. 678-835-0057
www.adedgetechnologies.com

TP	SERVICE CONNECTIONS	TYPE / MATERIAL
A/D	RAW WATER INLET	6" FLANGE, SCH 80 PVC
B/E	BLENDED PRODUCT OUTLET	6" FLANGE, SCH 80 PVC
C/F	REJECT WATER OUTLET	3" FLANGE, SCH 80 PVC

Title: GENERAL ARRANGEMENT DRAWING RO1 ADN RO2
REVERSE OSMOSIS SYSTEM
MODEL: ADRO8-6L-10H (7 x 3 ARRAY)

Designed by	Checked by	Approved by	Project	Date	Scale
			FCPA-0616		
Customer: GENERAL ARRANGEMENT					
Dwg. File	FCPA-0616.GA.01_A(1)	Rev. Date	Rev.No	Sheet	

Date: November 11, 2022

Quote No: WT22-11-1679

TO: Zahra Anwar Garver Engineering 12141 Wickchester Lane Suite 200 Houston, TX 77079	Phone: 713-482-4794 Email: ZBAnwar@GarverUSA.com
RE: 700 GPM Arsenic Removal System – Bay City Well A	
Pages: 2 Est. Delivery: 16 Weeks upon receipt of approved signed final drawings F.O.B.: Scottsdale, AZ	Delivery To: TBD
Quoted By: Christy McDonnel	Phone: (480) 998-4097 Fax: (480) 951-8434 Email: christy@apewater.com
To place an order email to orders@apewater.com	

QTY	Description	Unit Price	Amount
1	Multiple Tank SKID with Backwash Plumbing and Control <i>System includes:</i> <ul style="list-style-type: none"> (10) 54" OD x 48" Side Shell Vertical Media Tank Internal coating is 3M Scotchkote 134, NSF 61 Certified Max pressure of 100 PSI Max Temperature 150 °F 10" Inlet and Outlet Flanged 316 Stainless Steel, Hub and Lateral AUTOMATION DETAIL: Synergy NEMA 4X ; Solenoid 24 VAC; 454D Pneumatic Backwash Valves System is fully assembled, plumbed, and wired with tanks bolted onto a structural steel skid Installation and Operation & Maintenance Manuals Included 	\$430,238.00	\$430,238.00
476	Cubic Feet of ATOMUS Z21 Media, 47.6 CUFT per Vessel	\$525/cu ft	\$249,900.00
	NOTE: Standard price for ATOMUS Z21 media is \$625/ cu ft when purchasing a supersack which contains 30 cu ft. Given the size of the system, the price has been discounted to \$525/cu ft. This price will be extended to replacement media.		
100	Cubic Feet of Underbed 2mm Sand/gravel, 10CUFT per vessel	\$45/CUFT	\$4,500.00
1	HORIZONTAL Storage Tank for Water Application: Aboveground Type: SINGLE WALL Material: MILD CARBON STEEL		TBD

1	Backwash Pump w/Motor	\$7,780.00	\$7,780.00
1	WALCHEM pH Adjustment System Components ONLY <ul style="list-style-type: none"> • W120 pH Controller and sensor • 0.6 GPH Metering Pump • 275 Gallon Double-wall Tank • 2" Static Mixer • Flow switch <small>*275 Gallons Hydrochloric Acid to be supplied by others.</small>	\$17,985	\$17,985.00
	OPTIONAL EQUIPMENT (not included in total below)		
1	Optional CO2 pH adjustment system	\$35,169	
3	Onsite Technician for Startup and Training. \$1900/ day + travel. Estimating 3 Days	\$1900.00	
	Estimated Shipping & Handling:		TBD
	<small>This Quote does not include applicable sales tax. Minimum order \$50.00. Credit card charges will incur a surcharge of 3%.</small>	Total:	\$710,403.00




SUBMITTED BY:

Christy McDonnell


APPLIED PROCESS EQUIPMENT, INC.

ACCEPTED BY:

5472-10A



- NOTES:
1. FLOW RATE DESIGN: 420 GPM
 2. BACKWASH RATE: 10 GPM/FT²
 3. MAXIMUM WORKING PRESSURE: 80 PSI
 4. ELECTRICAL REQUIREMENTS:
 - CONTROLLED 24VAC, FACTORY WIRED
 - SOLENOIDS 24VAC, 120V
 - AIR SUPPLY REQUIRED: 2 CFM @ 70 PSIG (MIN).
 5. MEDIA REQUIREMENT PER TANK:
 - A. 1/2" X 3/4" CRUSHED ROCK
 - B. GRANULAR ACTIVATED CARBON
 6. WEIGHTS (APPROX):
 - EQUIPMENT: 14,980 LBS (LESS MEDIA)
 - MEDIA: 28,016 LBS
 - OPERATION: 84,000 LBS
 7. EXTERIOR PAINT COLOR: STANDARD BLUE, RAL 5010.



APPROVAL DATE: _____ GAC 5472-10A FILTER SYSTEM	
1. REPLACE HEAD BRASS/SSA w/1000SSS 2. CHANGE 4\"/>	APPROVAL DATE: _____ GAC 5472-10A FILTER SYSTEM
3. UNTESTED VENDOR LINED FINISHES 4. ADDED 4\"/>	APPROVAL DATE: _____ GAC 5472-10A FILTER SYSTEM
5. BY DATE: _____ SYSTEM: GAC	APPROVAL DATE: _____ GAC 5472-10A FILTER SYSTEM

The Terms and Conditions of contained herein are the exclusive terms and conditions for the sale of products from Applied Process Equipment, Inc., an Arizona corporation ("APE") to you, its Customer. Customer agrees that the terms and conditions stated herein and, to the extent not stated herein but contained on any APE invoice, constitute the final, complete, exclusive expression of the agreement between APE and Customer. In the event that any Customer form, purchase order or any other document submitted by Customer contains terms and conditions in addition to or different from the terms and conditions herein or from any APE invoice, Customer agrees, by so submitting its purchase order or order form, by receiving an order acknowledgment or by accepting product produced by APE, that such new or additional terms are rejected and that the language of the APE terms and conditions control. Any and all new or additional terms contained on any Customer document (whether provided to APE prior or subsequent to the delivery of these Terms and Conditions) are hereby expressly and completely rejected. Acceptance of Customer's order for product from APE is expressly limited to these terms and conditions.

1. Orders become effective only when accepted and approved by APE. There shall be a minimum order amount of \$1000.00 exclusive of freight. APE's acceptance is expressly made conditional on the Customer's assent to the terms and conditions contained herein and to the terms and conditions of any proposal issued by APE to the Customer, and APE agrees to furnish the product covered by the order only upon such terms and conditions. Any of the terms or provisions of the Customer's order which are inconsistent with the terms and provisions contained herein are not agreed to by APE and shall not be binding on APE and shall not be considered applicable to the sale or shipment of the products ordered.

2. Orders, shipments, and terms of payment are subject to the approval of APE's credit department. Invoices shall be rendered when the products are shipped. Terms of payment are net 30 days, unless otherwise agreed by APE. Any sums not paid within the specified net terms are subject to a service charge of 1.5% per month. No discount will be allowed to any Customer having an overdue balance. Any discounts previously granted to any Customer that fails to pay any APE invoice when due will be immediately forfeited and lost. Any discount forfeited or lost due to untimely payment of any invoice will be billed to Customer, which shall be immediately due and payable. Customer will pay all costs, collection agency commissions, expenses and all reasonable attorney fees incurred in the collection of any past due sums. By submitting an order or taking receipt of APE products, Customer consents to the exclusive jurisdiction of the state and federal courts located in the State of Arizona. Customer shall be deemed to have accepted the products shipped by APE within ten (10) days after delivery to Customer. After acceptance, Customer shall not be entitled to reject the products that are not in accordance with these terms and conditions. APE reserves the right to refrain from performing any work on any of Customer's orders should any of Customer's account(s) or jobs with APE be or become past due. Payments shall be made to APE at the address listed on the APE invoice.

3. All shipments are F.O.B. APE's plant or warehouse, unless otherwise agreed upon. Risk of loss of or damage to the goods shall pass to the Customer upon delivery by APE to the initial carrier, notwithstanding any right that the Customer may have to cancel or return goods. In the event APE is forced to delay delivery of goods to the initial carrier, due to any action or the Customer's request, risk of loss shall have passed upon the date APE would have otherwise delivered the goods to the initial carrier. Customer agrees to pay all reasonable storage and insurance charges specified by APE. In the event goods are returned pursuant to paragraph 5, risk of loss shall remain with Customer until the goods are delivered to the APE's plant and accepted by APE. Customer agrees to indemnify and hold APE harmless from any loss or damage to the goods or consequence thereof, sustained while the risk of such loss or damage remains upon Customer.

4. Delivery and shipment dates are estimated dates only. No allowance is made, nor shall APE be liable directly or indirectly for delays or non-performance due to delays of carriers or delays caused by labor difficulties, shortages, strikes, stoppages, fires accidents, failure or delay in obtaining materials or manufacturing facilities, acts of any government affecting APE in any way, bad weather, causes beyond APE's control, acts of God, or any other contingency that was not foreseen at the time when an order was submitted to APE. APE shall not be liable for any damages or penalties whatsoever, whether direct, indirect, special, consequential, or otherwise, resulting from APE's failure to perform or delay in performing. APE may decline to deliver, accept for cash, or stop goods, in transit, whenever for any reason doubt as to your financial responsibility develops or may arise.

5. Purchased products may be returned at Customer's request only upon the approval of APE. Products must be in re-sellable condition and in their original packaging. No cash refunds will be provided for returned products. APE will issue a credit memorandum for any authorized material return. Said credit memorandum will have no cash value and shall expire one (1) year after issuance. Authorized Returns not accompanied by a new order of greater or equal value shall be subject to a restocking fee of 25% of the original sale price.

6. APE will, to the extent permissible, pass through to you all available applicable original equipment manufacturer and additional warranties for any product sold. NO EMPLOYEE, REPRESENTATIVE OR DISTRIBUTOR IS AUTHORIZED TO CHANGE THE FOREGOING WARRANTIES IN ANY WAY OR GRANT ANY OTHER WARRANTY ON BEHALF OF APE. THE FOREGOING WARRANTIES ARE IN LIEU OF ALL OTHER WARRANTIES (INCLUDING WARRANTY OF MERCHANTABILITY AND FITNESS FOR PARTICULAR PURPOSE) AND NO REPRESENTATIONS, GUARANTEES, OR WARRANTIES, EXPRESS OR IMPLIED, ARE MADE BY APE IN CONNECTION WITH THE MANUFACTURE OR SALE OF ITS PRODUCTS. THE LIABILITY OF APE, WHETHER IN CONTRACT, TORT, UNDER ANY WARRANTY, OR OTHERWISE, SHALL NOT EXTEND BEYOND ITS OBLIGATION TO REPAIR OR REPLACE, AT ITS OPTION, ANY PRODUCT OR

PART FOUND BY APE TO BE DEFECTIVE IN MATERIAL OR WORKMANSHIP. APE SHALL NOT BE LIABLE FOR COST OF REMOVAL OR INSTALLATION AND/OR SHALL NOT BE RESPONSIBLE FOR ANY DIRECT, INDIRECT, SPECIAL OR CONSEQUENTIAL DAMAGES OF ANY NATURE.

Whether based on any Warranty claim or otherwise, APE will not, in ANY event, be liable for any loss of profit, interruption of business or any other special, consequential or incidental damages suffered or sustained by Customer. APE's total maximum liability to Customer in respect of the manufacture and sale of products is limited to the Warranty stated herein and, if any claim by Customer is based on a theory other than the Warranties, then the damages are limited to the total monies received by APE from the Customer for the particular products described in Customer's order. The total maximum liability for scheduled orders that are drawn down against each month will be the monthly total of the effected order or the total value of the items effected whichever is the lesser.

7. Any assistance, suggestions, or technical advice given the Customer by APE or any agent thereof, concerning dimensions, handling, installation, testing, storage, use or placement in service of any product is an accommodation for which APE shall have no liability unless such liability expressly assumed by APE in writing and signed by an officer of the company.

8. No employee, agent, or representative of APE has the authority or power to add, waive, or amend these terms and conditions unless first authorized in writing by an officer of APE. Any transaction with Customer shall be construed under the laws of the State of Ohio. Waiver of APE of any breach shall not thereafter be deemed a waiver of a subsequent breach of the same of any other provision hereof.

9. Use & Maintenance

This Equipment is not for use with influent water which is (a) microbiologically unsafe, or (b) of unknown quality without adequate treatment and/or disinfection.

- You must maintain the Equipment according to manufacturer instructions using manufacturer-authorized service parts, including replacement of filters and other components as recommended in the site-specific maintenance instructions.
- If your water quality, water consumption, water pressure or flow rate change, or if maintenance of the Equipment is affected by external factors such as sand, sediment, or an inadequate water supply, different or additional Equipment may be required, and this Equipment should not be used if such quality, consumption, pressure, flow rate change or external factors are outside of specified ranges in the original project scope.
- You are responsible for all maintenance of and repairs to the Equipment arising from damage due to:
 - your misuse or negligence
 - theft
 - unreasonable wear and use (including without limitation repair or alteration by unauthorized persons and relocation from the original site of installation), or
 - any other event beyond APE's control.

ATOMUS® ARSENIC TREATMENT TECHNOLOGY

APPLICATION PARAMETERS



Empty Bed Contact Time (EBCT)

Typically 3–6 min

pH Range

5.5–9.5

Surface Loading Rate

Up to 7 gpm/ft² or 5 lps/m²

Backwash Rate

7–10 gpm/ft² or 5–7 lps/m²


Water Quality Optimum Working Conditions for ATOMUS

pH	5.5–9.5
Total Arsenic	0.010–0.100 mg/L
Iron	< 0.3 mg/L
Manganese	< 0.05 mg/L
Phosphate	< 0.55 mg/L
Silica	< 35 mg/L
Sulfate	< 100 mg/L
Sulfides	< detect mg/L
Total Suspended Solids	< 5 mg/L
Vanadium	< 0.05 mg/L
Fluoride	< 1 mg/L
Turbidity	5 NTU
Hardness	< 300 mg/L

- Water with **pH > 9** may require pH adjustment for best performance.
- Economical treatment can still be achieved if ideal range is exceeded.
- Particularly for increased levels of silica and phosphate, ATOMUS will often provide the most economical treatment when compared to other adsorptive arsenic removal medias.

ATOMUS MEDIA DEPLOYMENT

Deployment



- **Support media:** Bottom layer of treatment bed
 - Any inert media will do (e.g., garnet or sand)
 - Support: 1/4"–1/8" particle sizing; 6"–12" of support is bed height
- **ATOMUS media:** Actual treatment bed
 - Height of media bed and support media should not be > 70% of vessel height to allow at least 30% freeboard for bed expansion during backwash process.



General

- Verify that electrical, pneumatic and hydraulic connections have been properly made.
- A newly constructed or rebuilt system may have debris in the supply or suction lines, such as oil, grease and dirt. In order to protect the media and underdrain from debris, all lines should be flushed prior to the system start-up.

Sand (Garnet) System Loading

- Open the upper man way to view and load the media during the start-up.
- Put the system in back-flow mode and begin to slowly fill the tank according to specifications of the distribution plate manufacturer.
 - Check specifications of the distribution plate manufacturer. Water usually loaded about 25% of system rate during this operation.
- Fill the tank with water until the distribution plate/laterals are covered with about .5 meters of water. Fill gently so the distribution plate/laterals are not broken or shifted.
- Load the sand gently on the water-covered laterals and move bag around to get an even level.
 - *Note: You will likely need to use a tool to level the sand as much as possible for the best distribution.*
- After the sand has been loaded and leveled, begin loading the ATOMUS media.

ATOMUS Media Loading

- Position the discharge spout of the bulk bag down inside the vessel through the top of the tank opening (about 0.5 meters from the surface of the media below) and untie the spout for ATOMUS media to discharge into the tank.
 - Move the bag around a bit to get a more even distribution in the tank.
 - Continue loading until the specified amount of media has been loaded.
 - *Note: Continue to move the discharge spout of the bag up to keep it 0.5 meters from the surface below to get good flow.*
- After the media has been loaded, clean the media and debris from the manway; seal surfaces and check seals to make sure they are clean.
- Close the manway.
- Continue to fill the vessel from the bottom (with water) to push out air trapped in the bed during filling. *(Cont.)*

ATOMUS Media Loading

- Continue to leave the system in reverse flow at low flow rate until the tank is full and until air bubbles are no longer visible (this can be seen in the sight glass and in the tank vent).
- Put flow in normal backwash at backwash loading rate of 7–10 gpm/ft² to remove fines from transport. This backwash will take about 15–20 minutes. Water will resemble “light tea” in color when the backwash is complete (it does not need to be clear).
 - Check backwash water to make sure no “coarse” ATOMUS particles are in the water (coarse particles can be felt while rubbing fingers together under flowing water).
 - Water will initially be very dark brown due to fines (~70 mesh / < 0.2 mm).
 - *Note: If a screen is installed on the backwash line to ensure media is not “blown” from the vessel, check the pressure drop to make sure screen is not blinded with the fines that are being removed.*
 - If after 15–20 minutes backwash water is not a “light tea” color, run the process for longer.

- After backwash, reverse flow to operational down flow, but still in closed loop for rinse and bed-repacking.
- Water should clear in 2–10 minutes (typically less than 5 minutes). Clear time varies based on how many fines were left in the bed.
- Check pressure drop across the vessel. It should be less than 10 psi (0.7 bar). More than 10 psi (0.7 bar) would indicate backwash was not adequate and should be repeated.
- When water clears, open valves and send water to the distribution system.
- Backwash process should be run periodically to prevent bed compaction and channeling, thus ensuring the system remains in good condition.
 - *Note: Backwash water can be recovered and fed back into the influent to the system at ratio not to exceed 10% after it has settled in the backwash tank.*

- Discharge ATOMUS media in tank by moving the bag around a bit to get a more even distribution in the tank.
- Continue to fill the vessel from the bottom (with water) to push out air trapped in the bed during filling.
- Put flow in normal backwash at a backwash loading rate of 7–10 gpm/ft² (5–7 lps/m²) to remove fines from transport—backwash might take 15–20 minutes.
- Water will resemble “light tea” in color when the backwash is complete (it does not need to be fully clear).
- Check backwash to make sure no “coarse” ATOMUS media is in the backwash tank (no actual media flushed out).
- Water might initially be dark brown due to fines (70 mesh / <0.2 mm).
 - *Note: If a screen is installed on the backwash line to ensure media is not “blown” from the vessel, check the pressure drop to make sure screen is not blinded with the fines that are being removed.*
- If after 15–20 minutes the backwash water is not “light tea”, please run the backwash little longer.
- After backwash, reverse flow to operational down flow, but still in closed loop for rinse and bed-repacking.
- Water should clear in 2–10 minutes (typically less than 5 minutes).
- Check pressure drop at vessel. It should be less than 10 psi (0.7 bar). More than 10 psi (0.7 bar) would indicate backwash was not enough.
- When water clears, open valves and send water to distribution system.
- Backwash should be run periodically to prevent compaction and channeling, thus ensuring the system remains in good condition.

QUESTIONS?

Applied Process Equipment, Inc. // 9332 N. 95th Way, Suite B106, Scottsdale, AZ 85258
// Phone: 480.998.4097 // sales@apewater.com // Apewater.com



City of Bay City WTP
Arsenic Removal with Ion Exchange – Preliminary Proposal

ITEM #2.




Vision Equipment

TEXAS • NEW MEXICO • OKLAHOMA

PRESENTED TO:

Zahra Anwar
Garver USA

Vision Equipment Contact:
 Keisha Antoine, PhD, PE
 PH: 832-356-3903




Technologies for Municipal and Industrial Wastewater Treatment

- Water Treatment Membranes
- Headworks Course Screening
- Headworks Fine Screening
- Indexed Tray De-Gritting
- Vortex De-Gritting
- Septage Receiving Stations
- In-Line Grinding
- Manhole Grinders
- Grit Classifiers
- Clarifiers
- Oxidation Ditch Systems
- Fine Bubble Aeration
- Course Bubble Aeration
- Lagoon Aeration
- Retractable Aeration
- Oxidation Ditch Conversions
- Biosolids Thickening
- Biosolids Dewatering
- PD Blowers
- Turbo Blowers
- Horizontal UV Disinfection
- SBR
- MBR
- Packaged WWTPs
- Sludge Holding Tank Aeration
- Digester Mixers
- Trickling Filters
- SS Mesh Filters
- Washer/Compactors

SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	CORPUS CHRISTI TEXAS	NORTH TEXAS & OKLAHOMA
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net
VISION EQUIPMENT	SOUTHEAST TEXAS	WEST TEXAS	TEXAS
Home Office Vision Equipment 6 Falls View Fair Oaks Ranch, TX 78015	Keisha Antoine, PhD, PE Houston O: 832-356-3903 Keisha@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net	Chris Hanley Office Manager C: 970-708-2669 Chris@visionequipment.net



TEXAS • NEW MEXICO • OKLAHOMA



Thank You Texas and Oklahoma!


- AET** - Hybrid Settlers for WTP and WWTP Applications
- APG Neuros** - Turbo Blowers and Aeration Systems
- AquaTec, Inc.** - Submersible Aeration Mixers (SAM)
- C.E. Shepherd** - Trickling Filter Media, Under Drains
- CECO Environmental** - Odor Control, Bioscrubbers, Carbon Systems
- CleanTek** - Roto-Sieve Fine Drum Screens
- Duperon** - FlexRake® Multi-Rake Headworks Screens, Storm Screens, Trash Rakes, Rag Removal Systems
- Dynamic Water Control Gates** - SS Slide, Flap, Weir Gates
- Envirodyne Systems, Inc.** - Indexed Tray De-gritting, Disk Aerators, Brush Aerators, Mixer Aeration, Clarifiers, DHV-Approved Surface Aerators, Thickeners, Anaerobic Digester Covers, Rotary Distributors, Sludge Baggers, Brush Type Weir Cleaners, Belt Filter Presses, Gravity Belt Thickeners
- Franklin Miller** - Twin Shafted Grinders, Septage Receiving Systems, Screenings Washer, Headworks Screening, In-Line Grinders, Bulk Water Fill Stations
- Guardian Environmental** - Chain and Flight Sludge Collectors
- H2O Innovation** - MBR, UF, IFAS Systems

- Industrial Service Solutions** - SBR, Extended Aeration, BNR
- Invent Filtration Technologies** - Tertiary SS Disk Filter
- Ishigaki** - Screw Press Dewatering, Sludge Thickening
- Jaeger-Aeration** - Least Cost Extended Aeration Designs, Disk, Strip and Tube Diffusers, SBR and BNR Biological Processes
- KWS** - Materials Handling Systems
- Marmac Water** - WTP Chemical Dosing and Metering Systems
- Midwest Fabricators** - FRP Weirs, Baffles, and Troughs
- Mixing Systems, Inc.** - Hydraulic Tank Mixing
- Neotec UV** - Ultraviolet Disinfection
- Prime Solution** - Rotary Press Dewatering
- Scinor** - Replacement UF Membrane Filters
- United Blower, Inc.** - PD, Multistage, Hybrid Blowers
- Vapex Environmental** - Vapor Phase Odor Control for Lift Stations and WWTPs, FOG Mitigation
- WTP Equipment Corp.** - Material Handling Shafted and Shaftless Screw Conveyors, Vertical Screw Conveyors, Screw Feeders, Hoppers, Blenders, Silos, Bins


SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	NORTH TEXAS & OKLAHOMA	CORPUS CHRISTI TEXAS
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net	Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net
TEXAS	SOUTHEAST TEXAS	NORTH TEXAS & OKLAHOMA	WEST TEXAS
Chris Hanley Office Manager C: 970-368-2265 Chris@visionequipment.net	Keisha Antoine, PhD, PE Houston O: 832-356-3903 Keisha@visionequipment.net	John Belton Dallas C: 972-922-3126 John@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net



TEXAS • NEW MEXICO • OKLAHOMA




Envirodyne Systems Inc.
TX and OK Reference Sites



Turbo Blower APG - Neuros
TX and OK Reference Sites




Texas Duperon Waste Water FlexRake
References
(2003 to Present)




United Blower Texas
References

Installed In Texas Since 1993



Duperon Storm Water Screening
References
(2003 to Present)



H2O Texas

\$14,000,000 Sales
60 MGD Treated Water
2008 First Install

MBR
References

SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	NORTH TEXAS & OKLAHOMA	CORPUS CHRISTI TEXAS
<p>David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net</p>	<p>Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net</p>	<p>Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net</p>	<p>Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net</p>
TEXAS	SOUTHEAST TEXAS	NORTH TEXAS & OKLAHOMA	WEST TEXAS
<p>Chris Hanley Office Manager C: 970-368-2265 Chris@visionequipment.net</p>	<p>Keisha Antoine, Ph.D., P.E. Houston O: 832-356-3903 Keisha@visionequipment.net</p>	<p>John Belton Dallas C: 972-922-3126 John@visionequipment.net</p>	<p>Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net</p>



TEXAS • NEW MEXICO • OKLAHOMA

November 11, 2022

Zahra Anwar
 12141 Wickchester Lane
 Suite 640
 Houston, TX 77079

Subject: Preliminary proposal for arsenic removal with ion exchange

Reference: City of Bay City WTP Arsenic Removal

Dear Zahra,

I trust this message finds you well. We thank you for your inquiry and updated inputs regarding requirements. Please find below H2O Innovation's recommendation for an ion exchange option for arsenic removal based on your inputs. We previously provided you with H2O's recommendation for iron adsorption in conjunction with chlorination and enhanced greensand media filtration and RO dated October 22nd and November 9th, 2022, respectively.

Feed properties:

- Feed Flow: 330gpm & 660 gpm
- Feed As Concentration: 0.01 mg/L
- Target As Concentration: <0.01 ug/L
- Empty Bed Contact Time (EBCT): 4 min

Item No	Equipment	Price
1	Well A - 1540 gpm TWO (2) 330 gpm trains	\$1,005,000
2	Well B - 1160 gpm ONE (1) 330 gpm train	\$675,000

Taxes are not included. Allowance(s) should be made to budget for future increases.

Each budgetary price includes the following:

- Configuration
 - 660gpm Six (6) FRP vessels in 5+1 configuration
 - 330gpm Three (3) FRP vessels in 2+1 configuration
- Arsenic removal filter media
- Piping, valves, instruments
- Frame(s)
- Automation and PLC
- Regeneration non included

Notes:

- Ex-Works (EXW) H2O Production Facility
- Excludes taxes, shipping, startup/commissioning, spares, installation
- H2O standard design and scope of supply
- H2O Standard Terms and Conditions

SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	CORPUS CHRISTI TEXAS	NORTH TEXAS & OKLAHOMA
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Randall Eulendorf Corpus Christi C: 361-319-2286 Randall@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net
VISION EQUIPMENT	SOUTHEAST TEXAS	WEST TEXAS	TEXAS
Home Office Vision Equipment 6 Falls View Fair Oaks Ranch, TX 78015	Keisha Antoine, PhD, P.E. Houston O: 832-356-3903 Keisha@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net	Chris Hanley Office Manager C: 970-708-2669 Chris@visionequipment.net



TEXAS • NEW MEXICO • OKLAHOMA

- Feedwater supplied by others

Please note this information is preliminary subject to engineering review. The final scopes will dictate the final and complete scope of supply of the vendor. The vendor-supplied scope of materials and services will be the sole basis for the final prices offered by Vision Equipment. If questions arise, please feel free to call my cell number at 832-356-3903. We remain at your service.

Thank you for your consideration.

Kind regards,

Keisha Antoine

Keisha Antoine, PhD, PE
Vision Equipment – Houston

cc: Hershel Ezzell, P.E. – Vision Equipment – Houston

SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	CORPUS CHRISTI TEXAS	NORTH TEXAS & OKLAHOMA
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net
VISION EQUIPMENT	SOUTHEAST TEXAS	WEST TEXAS	TEXAS
Home Office Vision Equipment 6 Falls View Fair Oaks Ranch, TX 78015	Keisha Antoine, PhD, PE Houston O: 832-356-3903 Keisha@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net	Chris Hanley Office Manager C: 970-708-2669 Chris@visionequipment.net

City of Bay City WTP
Arsenic Removal with RO – Preliminary Proposal

ITEM #2.




Vision Equipment

TEXAS • NEW MEXICO • OKLAHOMA

PRESENTED TO:

Zahra Anwar
Garver USA

Vision Equipment Contact:
 Keisha Antoine, PhD, PE
 PH: 832-356-3903




Technologies for Municipal and Industrial Wastewater Treatment

- Water Treatment Membranes
- Headworks Course Screening
- Headworks Fine Screening
- Indexed Tray De-Gritting
- Vortex De-Gritting
- Septage Receiving Stations
- In-Line Grinding
- Manhole Grinders
- Grit Classifiers
- Clarifiers
- Oxidation Ditch Systems
- Fine Bubble Aeration
- Course Bubble Aeration
- Lagoon Aeration
- Retractable Aeration
- Oxidation Ditch Conversions
- Biosolids Thickening
- Biosolids Dewatering
- PD Blowers
- Turbo Blowers
- Horizontal UV Disinfection
- SBR
- MBR
- Packaged WWTPs
- Sludge Holding Tank Aeration
- Digester Mixers
- Trickling Filters
- SS Mesh Filters
- Washer/Compactors

SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	CORPUS CHRISTI TEXAS	NORTH TEXAS & OKLAHOMA
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net
VISION EQUIPMENT	SOUTHEAST TEXAS	WEST TEXAS	TEXAS
Home Office Vision Equipment 6 Falls View Fair Oaks Ranch, TX 78015	Keisha Antoine, PhD, PE Houston O: 832-356-3903 Keisha@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net	Chris Hanley Office Manager C: 970-708-2669 Chris@visionequipment.net



TEXAS • NEW MEXICO • OKLAHOMA



Thank You Texas and Oklahoma!


- AET** - Hybrid Settlers for WTP and WWTP Applications
- APG Neuros** - Turbo Blowers and Aeration Systems
- AquaTec, Inc.** - Submersible Aeration Mixers (SAM)
- C.E. Shepherd** - Trickling Filter Media, Under Drains
- CECO Environmental** - Odor Control, Bioscrubbers, Carbon Systems
- CleanTek** - Roto-Sieve Fine Drum Screens
- Duperon** - FlexRake® Multi-Rake Headworks Screens, Storm Screens, Trash Rakes, Rag Removal Systems
- Dynamic Water Control Gates** - SS Slide, Flap, Weir Gates
- Envirodyne Systems, Inc.** - Indexed Tray De-gritting, Disk Aerators, Brush Aerators, Mixer Aeration, Clarifiers, DHV-Approved Surface Aerators, Thickeners, Anaerobic Digester Covers, Rotary Distributors, Sludge Baggers, Brush Type Weir Cleaners, Belt Filter Presses, Gravity Belt Thickeners
- Franklin Miller** - Twin Shafted Grinders, Septage Receiving Systems, Screenings Washer, Headworks Screening, In-Line Grinders, Bulk Water Fill Stations
- Guardian Environmental** - Chain and Flight Sludge Collectors
- H2O Innovation** - MBR, UF, IFAS Systems

- Industrial Service Solutions** - SBR, Extended Aeration, BNR
- Invent Filtration Technologies** - Tertiary SS Disk Filter
- Ishigaki** - Screw Press Dewatering, Sludge Thickening
- Jaeger-Aeration** - Least Cost Extended Aeration Designs, Disk, Strip and Tube Diffusers, SBR and BNR Biological Processes
- KWS** - Materials Handling Systems
- Marmac Water** - WTP Chemical Dosing and Metering Systems
- Midwest Fabricators** - FRP Weirs, Baffles, and Troughs
- Mixing Systems, Inc.** - Hydraulic Tank Mixing
- Neotec UV** - Ultraviolet Disinfection
- Prime Solution** - Rotary Press Dewatering
- Scinor** - Replacement UF Membrane Filters
- United Blower, Inc.** - PD, Multistage, Hybrid Blowers
- Vapex Environmental** - Vapor Phase Odor Control for Lift Stations and WWTPs, FOG Mitigation
- WTP Equipment Corp.** - Material Handling Shafted and Shaftless Screw Conveyors, Vertical Screw Conveyors, Screw Feeders, Hoppers, Blenders, Silos, Bins


SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	NORTH TEXAS & OKLAHOMA	CORPUS CHRISTI TEXAS
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net	Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net
TEXAS	SOUTHEAST TEXAS	NORTH TEXAS & OKLAHOMA	WEST TEXAS
Chris Hanley Office Manager C: 970-368-2265 Chris@visionequipment.net	Keisha Antoine, PhD, P.E. Houston O: 832-356-3903 Keisha@visionequipment.net	John Belton Dallas C: 972-922-3126 John@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net



TEXAS • NEW MEXICO • OKLAHOMA




Envirodyne Systems Inc.
TX and OK Reference Sites



Turbo Blower APG - Neuros
TX and OK Reference Sites




Texas Duperon Waste Water FlexRake
References
(2003 to Present)




United Blower
Texas References

Installed In Texas Since 1993



Duperon Storm Water Screening
References
(2003 to Present)



H2O Texas

\$14,000,000 Sales
60 MGD Treated Water
2008 First Install

MBR
References

SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	NORTH TEXAS & OKLAHOMA	CORPUS CHRISTI TEXAS
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net	Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net
TEXAS	SOUTHEAST TEXAS	NORTH TEXAS & OKLAHOMA	WEST TEXAS
Chris Hanley Office Manager C: 970-368-2265 Chris@visionequipment.net	Keisha Antoine, Ph.D., P.E. Houston O: 832-356-3903 Keisha@visionequipment.net	John Belton Dallas C: 972-922-3126 John@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net



TEXAS • NEW MEXICO • OKLAHOMA

November 9, 2022

Zahra Anwar
 12141 Wickchester Lane
 Suite 640
 Houston, TX 77079

Subject: Preliminary proposal for arsenic removal with RO

Reference: City of Bay City WTP Arsenic Removal

Dear Zahra,

I trust this message finds you well. We thank you for your inquiry and updated inputs regarding requirements. Please find below H2O Innovation's recommendation for a reverse osmosis (RO) option for arsenic removal based on your inputs. We previously provided you with H2O's recommendation for iron adsorption in conjunction with chlorination and enhanced greensand media filtration dated October 22, 2022.

Well A

	1540gpm	660gpm	1320gpm
	Arsenic 0.010mg/1		Arsenic 0.005015mg/1
	TDS 336mg/1		TDS 168.94mg/1
	pH 8.28		pH 8.00
Well A	→		
880gpm RO Feed	2 x 330GPM RO	660gpm RO Permeate	
	220gpm reject (to waste)		Arsenic 0.00003mg/1
	Arsenic 0.04mg/1		TDS 1.92mg/1
	TDS 1340.83mg/1		pH 6.39
	pH 8.83		@ 22.3C


SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	CORPUS CHRISTI TEXAS	NORTH TEXAS & OKLAHOMA
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net
VISION EQUIPMENT	SOUTHEAST TEXAS	WEST TEXAS	TEXAS
Home Office Vision Equipment 6 Falls View Fair Oaks Ranch, TX 78015	Keisha Antoine, PhD, PE Houston O: 832-356-3903 Keisha@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net	Chris Hanley Office Manager C: 970-708-2669 Chris@visionequipment.net



ITEM #2.

TEXAS • NEW MEXICO • OKLAHOMA

Well B



Item No	Equipment	Price
1	Well A - 1540 gpm TWO (2) 330 gpm RO trains	\$980,000
2	Well B - 1160 gpm ONE (1) 330 gpm RO train	\$645,000

Taxes are not included. Allowance(s) should be made to budget for future increases.

Each budgetary price includes the following:

- Membranes
- Pressure Vessels
- Cleaning in Place (CIP) Skid
- Duplex dosing sets
- Automatic CIP flush
- Instruments and Controls
 - Remote Input/Output w/ Intelogx
 - One Remote IO Panel to MCP (CompactLogx)
 - Variable frequency drives
 - Conductivity Probe - Train Feed
 - pH/ORP Probe - Train Feed
 - Pressure Transmitter/Gauge - Train Permeate
 - pH/ORP Probe - Train Permeate
 - Pressure Transmitter/Gauge - 1st Stage Permeate
 - Pressure Switch - 1st Stage Permeate
 - Flow Meter - 2nd Stage Permeate
 - Pressure Transmitter - 2nd Stage Feed
- Valving
 - Automated Concentrate Flow Control Valve

SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	CORPUS CHRISTI TEXAS	NORTH TEXAS & OKLAHOMA
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net
VISION EQUIPMENT	SOUTHEAST TEXAS	WEST TEXAS	TEXAS
Home Office Vision Equipment 6 Falls View Fair Oaks Ranch, TX 78015	Keisha Antoine, PhD, PE Houston O: 832-356-3903 Keisha@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net	Chris Hanley Office Manager C: 970-708-2669 Chris@visionequipment.net



TEXAS • NEW MEXICO • OKLAHOMA

- Limit Switches for Automatic Valves

Notes:

- Ex-Works (EXW) H2O Production Facility
- Excludes taxes, shipping, startup/commissioning, spares, installation
- Excludes chemicals/consumables
 - A PWT antiscalant projection is included for reference
 - Based on the provided data, barium sulfate and iron scaling are potential risks.
- H2O standard design and scope of supply
- H2O Standard Terms and Conditions
- Feedwater supplied by others

Please note this information is preliminary subject to engineering review. The final scopes will dictate the final and complete scope of supply of the vendor. The vendor-supplied scope of materials and services will be the sole basis for the final prices offered by Vision Equipment. If questions arise, please feel free to call my cell number at 832-356-3903. We remain at your service.

Thank you for your consideration.

Kind regards,

Keisha Antoine

Keisha Antoine, PhD, PE
Vision Equipment – Houston

cc: Hershel Ezzell, P.E. – Vision Equipment – Houston

SOUTH & CENTRAL TEXAS	SOUTHEAST TEXAS	CORPUS CHRISTI TEXAS	NORTH TEXAS & OKLAHOMA
David Bartlett San Antonio C: 210-381-4030 David@visionequipment.net	Hershel Ezzell, Jr., P.E. Houston C: 281-850-5414 Hershel@visionequipment.net	Randall Eulenfeld Corpus Christi C: 361-319-2286 Randall@visionequipment.net	Jodie Marbut Weatherford C: 817-229-0411 Jodie@visionequipment.net
VISION EQUIPMENT	SOUTHEAST TEXAS	WEST TEXAS	TEXAS
Home Office Vision Equipment 6 Falls View Fair Oaks Ranch, TX 78015	Keisha Antoine, PhD, PE Houston O: 832-356-3903 Keisha@visionequipment.net	Mike Neill Amarillo C: 806-336-5913 Mike@visionequipment.net	Chris Hanley Office Manager C: 970-708-2669 Chris@visionequipment.net

Created on 10/28/2022

Permeate Blending

Project name	Bay City, Texas			1/3
Client Name	Garver	Permeate flow/train		330.00 gpm
Calculated by	Michael Gisclair	Total plant product flow		1320.00 gpm
HP pump flow	440.00 gpm	Number of trains		2.00
Feed pressure	228.0 psi	Raw water flow/train		770.00 gpm
Feed temperature	22.3 °C	Permeate recovery		75.00 %
Feed Water pH	8.28	Blended flow		660.00 gpm
Chemical dose, mg/l	None	Membrane age		5.0 years
Pumping specific energy	2.74 kWh/kgal	Flux decline, per year		7.0 %
Pass NDP	210.6 psi	Fouling factor		0.70
Average flux	11.9 gfd	SP increase, per year		7.0 %
		Feed type		Brackish Well High-Fouling
		Pretreatment		Conventional

Pass-Stage	Perm. Flow	Flow / Vessel Feed	Flow / Vessel Conc	Flux	DP	Flux	Beta	Perm.	Stagewise Pressure Boost	Stagewise Pressure Exhaust	Conc	Perm. TDS	Membrane Type	Membrane Quantity	PV# x Elem #
1-1	237.1	44.0	20.3	12.2	13.6	12.7	1.05	0.0	0.0	0	214.3	1.4	CPA6-LD	70	10 x 7M
1-2	93.2	40.6	22.0	11.2	11.1	11.6	1.05	0.0	0.0	0	203.2	3.2	CPA6-LD	30	5 x 6M

Ion (mg/l)	Raw Water	Feed Water	Permeate Water	Concentrate 1	Concentrate 2	Blended Water
Hardness, as CaCO3	56.91	56.91	0.007	123.4	228.1	28.46
Ca	13.70	13.70	0.002	29.7	54.9	6.85
Mg	5.53	5.53	0.001	12.0	22.2	2.77
Na	98.20	98.20	0.656	212.4	391.6	49.43
K	2.67	2.67	0.020	5.8	10.6	1.35
NH4	0.05	0.05	0.001	0.1	0.2	0.03
Ba	0.259	0.259	0.000	0.6	1.0	0.13
As+5	0.010	0.010	0.00003	0.022	0.04	0.01
Fe+2	0.028	0.028	0.000	0.1	0.1	0.01
Mn+2	0.008	0.008	0.000	0.0	0.0	0.00
CO3	0.01	0.01	0.000	0.0	0.1	0.00
HCO3	0.50	0.50	0.006	1.1	1.9	0.25
SO4	14.00	14.00	0.019	30.3	56.1	7.01
Cl	182.97	182.97	1.009	395.9	730.3	91.99
F	0.42	0.42	0.005	0.9	1.7	0.21
NO3	0.05	0.05	0.001	0.1	0.2	0.03
OH	0.03	0.03	0.000	0.1	0.1	0.01
SiO2	17.30	17.30	0.073	37.4	69.1	8.69
B	0.27	0.27	0.122	0.5	0.7	0.20
CO2	0.00	0.00	0.00	0.00	0.00	0.00
NH3	0.00	0.00	0.00	0.00	0.00	0.00
TDS	335.97	335.97	1.92	726.81	1340.83	168.94
pH	8.28	8.28	6.39	8.59	8.83	8.00

Saturations	Raw Water	Feed Water	Permeate Water	Concentrate	Limits
CaSO4 / Ksp * 100, %	0	0	0	1	400
SrSO4 / Ksp * 100, %	0	0	0	0	1200
BaSO4 / Ksp * 100, %	305	305	0	1487	10000
SiO2 Saturation, %	12	12	0	37	140
CaF2 / Ksp * 100, %	0	0	0	17	50000
Ca3(PO4)2	0.0	0.0	0.0	0.0	2.4
CCPP, mg/l	0.08	0.08	-0.15	0.58	850
Langelier index	-2.57	-2.57	-10.05	-0.89	2.8
Ionic strength	0.01	0.01	0.00	0.03	
Osmotic pressure, psi	3.4	3.4	0.0	13.5	
TDS / Osmotic pressure, mg/l.psi	98.3	98.3	97.6	98.3	

Product performance calculations are based on nominal element performance when operated on a feed water of acceptable quality. The results shown on the printouts produced by this program are estimates of product performance. No guarantee of product or system performance is expressed or implied unless provided in a separate warranty statement signed by an authorized Hydranautics representative. Calculations for chemical consumption are provided for convenience and are based on various assumptions concerning water quality and composition. As the actual amount of chemical needed for pH adjustment is feedwater dependent and not membrane dependent, Hydranautics does not warrant chemical consumption. If a product or system warranty is required, please contact your Hydranautics representative. Standard or extended warranties may result in different pricing than previously quoted.

Created on 10/28/2022

Permeate Blending


Project name	Bay City, Texas	Permeate flow/train	330.00 gpm	2/3
Client Name	Garver	Total plant product flow	1320.00 gpm	
Calculated by	Michael Gisclair	Number of trains	2.00	
HP pump flow	440.00 gpm	Raw water flow/train	770.00 gpm	
Feed pressure	228.0 psi	Permeate recovery	75.00 %	
Feed temperature	22.3 °C	Blended flow	660.00 gpm	
Feed Water pH	8.28	Membrane age	5.0 years	
Chemical dose, mg/l	None	Flux decline, per year	7.0 %	
Pumping specific energy	2.74 kWh/kgal	Fouling factor	0.70	
Pass NDP	210.6 psi	SP increase, per year	7.0 %	
Average flux	11.9 gfd	Feed type	Brackish Well High-Fouling	
		Pretreatment	Conventional	

Pass-Stage	Perm. Flow	Flow / Vessel		Flux	DP	Flux	Beta	Stagewise Pressure			Perm.	Membrane	Membrane	PV# x	
	gpm	gpm	gpm	gfd	psi	gfd		psi	psi	psi	mg/l	Type	Quantity	Elem #	
1-1	237.1	44.0	20.3	12.2	13.6	12.7	1.05	0.0	0.0	0	214.3	1.4	CPA6-LD	70	10 x 7M
1-2	93.2	40.6	22.0	11.2	11.1	11.6	1.05	0.0	0.0	0	203.2	3.2	CPA6-LD	30	5 x 6M

Pass-Stage	membrane no.	Feed Pressure	Pressure Drop	Conc Osmotic pressure	NDP	Permeate Water		Recovery	Beta	TDS	Permeate (Stagewise cumulative)			
						Flow	Flux				Econd (@ 25.0 °C)	Ca	Na	Cl
1-1	1	228.0	2.84	3.7	223.0	3.5	12.7	8.0	1.03	1.1	2.1	0.001	0.376	0.577
1-1	2	225.1	2.52	4.0	220.0	3.5	12.5	8.6	1.03	1.1	2.2	0.001	0.389	0.598
1-1	3	222.6	2.21	4.4	217.3	3.4	12.3	9.2	1.03	1.2	2.3	0.001	0.404	0.620
1-1	4	220.4	1.92	4.9	214.8	3.4	12.2	10.1	1.04	1.2	2.4	0.001	0.419	0.643
1-1	5	218.5	1.64	5.5	212.4	3.3	12.0	11.1	1.04	1.3	2.5	0.001	0.434	0.667
1-1	6	216.8	1.38	6.3	210.2	3.3	11.9	12.3	1.05	1.3	2.5	0.001	0.449	0.691
1-1	7	215.5	1.13	7.3	208.1	3.3	11.8	13.9	1.05	1.4	2.7	0.001	0.478	0.734
1-2	1	214.3	2.53	8.0	205.4	3.2	11.6	7.9	1.03	2.3	4.4	0.002	0.772	1.187
1-2	2	211.8	2.24	8.7	202.4	3.2	11.4	8.5	1.03	2.4	4.7	0.002	0.821	1.263
1-2	3	209.5	1.97	9.6	199.5	3.1	11.3	9.1	1.03	2.6	5.0	0.002	0.877	1.349
1-2	4	207.6	1.71	10.6	196.7	3.1	11.1	9.9	1.04	2.7	5.3	0.002	0.942	1.449
1-2	5	205.9	1.46	11.9	193.9	3.0	10.9	10.8	1.04	3.0	5.8	0.003	1.018	1.566
1-2	6	204.4	1.23	13.5	191.1	3.0	10.8	12.0	1.05	3.2	6.3	0.003	1.110	1.706

Product performance calculations are based on nominal element performance when operated on a feed water of acceptable quality. The results shown on the printouts produced by this program are estimates of product performance. No guarantee of product or system performance is expressed or implied unless provided in a separate warranty statement signed by an authorized Hydranautics representative. Calculations for chemical consumption are provided for convenience and are based on various assumptions concerning water quality and composition. As the actual amount of chemical needed for pH adjustment is feedwater dependent and not membrane dependent, Hydranautics does not warrant chemical consumption. If a product or system warranty is required, please contact your Hydranautics representative. Standard or extended warranties may result in different pricing than previously quoted.

Permeate Blending



Stream No.	Flow (gpm)	Pressure (psi)	TDS (mg/l)	pH	Econd (µS/cm) (@ 25.0 °C)
1	770	0	336	8.28	711
2	330	0	336	8.28	711
3	440	0	336	8.28	711
4	440	228	336	8.28	711
5	203	214	727	8.59	1531
6	110	203	1341	8.83	2618
7	237	0	1.41	6.25	3.00
8	93.2	0	3.21	6.61	6.50
9	330	0	1.92	6.39	3.90
10	660	0	169	8.00	358

Product performance calculations are based on nominal element performance when operated on a feed water of acceptable quality. The results shown on the printouts produced by this program are estimates of product performance. No guarantee of product or system performance is expressed or implied unless provided in a separate warranty statement signed by an authorized Hydranautics representative. Calculations for chemical consumption are provided for convenience and are based on various assumptions concerning water quality and composition. As the actual amount of chemical needed for pH adjustment is feedwater dependent and not membrane dependent, Hydranautics does not warrant chemical consumption. If a product or system warranty is required, please contact your Hydranautics representative. Standard or extended warranties may result in different pricing than previously quoted.

Created on 10/28/2022

Permeate Blending


Project name	Bay City, Texas		2/3
Client Name	Garver	Permeate flow/train	330.00 gpm
Calculated by	Michael Gisclair	Raw water flow/train	1160.00 gpm
HP pump flow	440.00 gpm	Permeate recovery	75.00 %
Feed pressure	228.0 psi	Blended flow	1050.00 gpm
Feed temperature	22.3 °C	Membrane age	5.0 years
Feed Water pH	8.28	Flux decline, per year	7.0 %
Chemical dose, mg/l	None	Fouling factor	0.70
Pumping specific energy	2.74 kWh/kgal	SP increase, per year	7.0 %
Pass NDP	210.6 psi	Feed type	Brackish Well High-Fouling
Average flux	11.9 gfd	Pretreatment	Conventional

Pass-Stage	Perm. Flow	Flow / Vessel		Flux	DP	Flux	Beta	Stagewise Pressure			Perm. TDS	Membrane Type	Membrane Quantity	PV# x Elem #	
	gpm	Feed	Conc	gfd	psi	Max		Boost	Exhaust	Conc	mg/l				
1-1	237.1	44.0	20.3	12.2	13.6	12.7	1.05	0.0	0.0	0	214.3	1.4	CPA6-LD	70	10 x 7M
1-2	93.2	40.6	22.0	11.2	11.1	11.6	1.05	0.0	0.0	0	203.2	3.2	CPA6-LD	30	5 x 6M

Pass-Stage	membrane no.	Feed Pressure	Pressure Drop	Conc Osmotic pressure	NDP	Permeate Water		Recovery (%)	Beta	TDS	Permeate (Stagewise cumulative)			
						Flow	Flux				Econd (@ 25.0 °C)	Ca	Na	Cl
		psi	psi	psi	psi	gpm	gfd		mg/l	µS/cm	mg/l	mg/l	mg/l	
1-1	1	228.0	2.84	3.7	223.0	3.5	12.7	8.0	1.03	1.1	2.1	0.001	0.376	0.577
1-1	2	225.1	2.52	4.0	220.0	3.5	12.5	8.6	1.03	1.1	2.2	0.001	0.389	0.598
1-1	3	222.6	2.21	4.4	217.3	3.4	12.3	9.2	1.03	1.2	2.3	0.001	0.404	0.620
1-1	4	220.4	1.92	4.9	214.8	3.4	12.2	10.1	1.04	1.2	2.4	0.001	0.419	0.643
1-1	5	218.5	1.64	5.5	212.4	3.3	12.0	11.1	1.04	1.3	2.5	0.001	0.434	0.667
1-1	6	216.8	1.38	6.3	210.2	3.3	11.9	12.3	1.05	1.3	2.5	0.001	0.449	0.691
1-1	7	215.5	1.13	7.3	208.1	3.3	11.8	13.9	1.05	1.4	2.7	0.001	0.478	0.734
1-2	1	214.3	2.53	8.0	205.4	3.2	11.6	7.9	1.03	2.3	4.4	0.002	0.772	1.187
1-2	2	211.8	2.24	8.7	202.4	3.2	11.4	8.5	1.03	2.4	4.7	0.002	0.821	1.263
1-2	3	209.5	1.97	9.6	199.5	3.1	11.3	9.1	1.03	2.6	5.0	0.002	0.877	1.349
1-2	4	207.6	1.71	10.6	196.7	3.1	11.1	9.9	1.04	2.7	5.3	0.002	0.942	1.449
1-2	5	205.9	1.46	11.9	193.9	3.0	10.9	10.8	1.04	3.0	5.8	0.003	1.018	1.566
1-2	6	204.4	1.23	13.5	191.1	3.0	10.8	12.0	1.05	3.2	6.3	0.003	1.110	1.706

Product performance calculations are based on nominal element performance when operated on a feed water of acceptable quality. The results shown on the printouts produced by this program are estimates of product performance. No guarantee of product or system performance is expressed or implied unless provided in a separate warranty statement signed by an authorized Hydranautics representative. Calculations for chemical consumption are provided for convenience and are based on various assumptions concerning water quality and composition. As the actual amount of chemical needed for pH adjustment is feedwater dependent and not membrane dependent, Hydranautics does not warrant chemical consumption. If a product or system warranty is required, please contact your Hydranautics representative. Standard or extended warranties may result in different pricing than previously quoted.

Permeate Blending



Stream No.	Flow (gpm)	Pressure (psi)	TDS (mg/l)	pH	Econd (μS/cm) (@ 25.0 °C)
1	1160	0	336	8.28	711
2	720	0	336	8.28	711
3	440	0	336	8.28	711
4	440	228	336	8.28	711
5	203	214	727	8.59	1531
6	110	203	1341	8.83	2618
7	237	0	1.41	6.25	3.00
8	93.2	0	3.21	6.61	6.50
9	330	0	1.92	6.39	3.90
10	1050	0	231	8.13	489

Product performance calculations are based on nominal element performance when operated on a feed water of acceptable quality. The results shown on the printouts produced by this program are estimates of product performance. No guarantee of product or system performance is expressed or implied unless provided in a separate warranty statement signed by an authorized Hydranautics representative. Calculations for chemical consumption are provided for convenience and are based on various assumptions concerning water quality and composition. As the actual amount of chemical needed for pH adjustment is feedwater dependent and not membrane dependent, Hydranautics does not warrant chemical consumption. If a product or system warranty is required, please contact your Hydranautics representative. Standard or extended warranties may result in different pricing than previously quoted.

Project Information

Client:	Garver	Print Date:	11/2/2022 9:05:25 PM
Project:	Bay City	Comments:	
Location:	Bay City, TX	Case Number:	1
Prepared By:	M Gisclair	Case Description:	

System Information

Feed Water Type:	Well Water	Flow Units:	Gal/min
Feed Water Flow:	440.0	Concentrate Flow:	110.0
Permeate Flow:	330.0	Recycle Flow:	0.0
System Recovery (%):	75.00%	RO Recovery:	75.00%
Feed Temperature:	22.3 Deg C	Membrane Rejection:	99.3%

Product Selection


Antiscalant Dose Rate: **0.25 mg/l Feed** **0.98 mg/l in Concentrate**
 Estimated Usage (100%): **1.30 lbs/day** **474.43 lbs/yr, 215.20 kg/yr**

SpectraGuard 111

Pretreatment: **No acid/base dose**
 Estimated Usage (100%): **0.00 kg/day**

Concentrate Solubilities

■ - NO CHEM ■ - WITH PWT



Saturation %	Raw Feed	Feed	Concentrate	With PWT	Saturation %	Raw Feed	Feed	Concentrate	With PWT
LSI	-2.2	-2.2	-0.6	-	SiO2	12.1	12.1	44.8	19.5
CCPP-ppm	-6	-6	-2	-	Ca5(PO4)3-SI	0.0	0.0	0.0	0.0
CaCO3	0	0	14	0.0	Ca3(PO4)2-SI	0.0	0.0	0.0	0.0
CaSO4	0.1	0.1	0.5	0.1	Fe	30.3	30.3	119.4	4.6
SrSO4	0.0	0.0	0.0	0.0	Al	0.0	0.0	0.0	0.0
BaSO4	93.3	93.3	868.8	7.9	Mn	19.0	19.0	51.5	2.6
CaF2	0.2	0.2	10.6	0.0	Mg(OH)2	0	0	0	0

Water Analysis

Ions (mg/l)	Sys Feed	Pretreatment	Net Feed	Permeate	Concentrate
Ca	13.70	13.70	13.70	0.06	54.61
Mg	5.53	5.53	5.53	0.03	22.04
Na	104.77	104.77	104.77	1.45	414.72
K	2.67	2.67	2.67	0.04	10.57
NH4	0.05	0.05	0.05	0.00	0.19
Ba	0.26	0.26	0.26	0.00	1.03
Sr	0.00	0.00	0.00	0.00	0.00
Fe	0.03	0.03	0.03	0.00	0.12
Mn	0.01	0.01	0.01	0.00	0.04
Al	0.00	0.00	0.00	0.00	0.00
HCO3	0.50	0.50	0.50	0.03	1.83
Cl	182.97	182.97	182.97	2.54	724.27
SO4	14.00	14.00	14.00	0.06	55.81
F	0.42	0.42	0.42	0.01	1.66
NO3	0.05	0.05	0.05	0.00	0.20
PO4	0.00	0.00	0.00	0.00	0.00
SiO2	17.30	17.30	17.30	0.24	68.48
TDS	342	342	342	4	1,356
pH	8.28	8.28	8.28	7.11	8.89

PRODOSE™ is provided on an "as is" basis, without warranties of any kind, either expressed or implied, including, without limitation, the warranties of merchantability, fitness for a particular purpose and noninfringement. While every effort has been made to ensure its accuracy, licensee assumes the entire risk as to the quality and performance of this software, including the accuracy of the data obtained by its use.

Appendix E: Rapid Small-Scale Column Test

Rapid Small-Scale Column Tests: Arsenic Removal by E33 and GFH for Bay City, TX

Report Prepared by
Paul Westerhoff, Professor
Chao Zheng, Assistant Professor
Emily Briese, PhD student

School of Sustainable Engineering & The Built Environment
Arizona State University
Tempe, Arizona 85287-5306

National Science Foundation
Nanosystems Engineering Research Center for Nanotechnology Enabled Water Treatment

September 2022

Purpose of Tests

Using a rapid small-scale column test (RSSCT), ASU simulated a full-scale packed bed system of 2.5 min EBCT and a loading rate of 9.36 and 9.61 for E33 and GFH, respectively. Water was shipped to ASU from Bay City, TX. The duration of the test was 96,000 bed volumes to obtain the breakthrough curves of Arsenic species.

Methodology

RSSCT Methodology

RSSCT bench-scale testing is a method where dimensionless mathematical methods are used to scale down a full-scale packed-bed adsorption system based upon similitude between solute transport mechanisms. The advantages of RSSCTs are that breakthrough curves can be obtained in a fraction of the time and water that would be required for pilot tests. Theoretically, RSSCTs and full-scale systems would have identical breakthrough curves, but in reality, they differ based upon water quality, biological processes, and RSSCT scaling assumptions. In the development of scaling equations three conditions are required in order for similarity to be maintained (Crittenden et al. 1986; Crittenden et al. 1987; Crittenden et al. 1991). First, boundary conditions for the large-scale and small-scale process must occur at the same dimensionless coordinate values in the dimensionless differential equations. Second, dimensionless parameters in the dimensionless differential equations must be equal for the large-scale and small-scale process. Finally, no change in mechanism can occur when reducing the size of the process. RSSCTs can be designed using equations 1 and 2 (**Eq. 1, 2**), if the effective surface diffusivity is independent of particle size, the system is identical between the full-scale and RSSCT columns (Table 1). If the surface diffusivities are not identical between the large-scale and RSSCT columns, perfect similarity cannot be guaranteed. However, if it is assumed that surface diffusivity is linearly proportional to the particle radius and that surface diffusion is the controlling mechanism, an RSSCT can be designed using equations 3 and 4 (**Eq. 3, 4**) that would produce an RSSCT that would perform very similar to the full-scale adsorber. The Reynolds number is a dimensionless ratio of the inertial forces over the viscous forces in a fluid. The Schmidt number is a dimensionless ratio of the diffusion of momentum over the diffusion of mass. The product of the Reynolds number and the Schmidt number can be used to determine the minimum Reynolds for the RSSCT such that the effects of dispersion are not important. Dispersion is not important if the product of the Reynolds number and the Schmidt number is in the mechanical dispersion region from 200,000-200. a value of 1000 is used in all proposed work. The following equations were used:

$$\frac{EBCT_{SC}}{EBCT_{LC}} = \left[\frac{d_{p,SC}}{d_{p,LC}} \right] = \frac{t_{SC}}{t_{LC}} \dots \mathbf{Eq. 1}$$

$$\frac{V_{SC}}{V_{LC}} = \left[\frac{d_{p,SC}}{d_{p,LC}} \right] \times \frac{Re_{SC} \times Sc}{Re_{LC} \times Sc} \dots \mathbf{Eq. 2}$$

$$Re = \frac{V \times \rho_L \times d_p}{\mu} \dots \mathbf{Eq. 3}$$

$$Sc = \frac{\mu}{D_L \times \rho_L} \dots \mathbf{Eq. 4}$$

where the parameters are defined as follows: Empty bed contact time (EBCT), media diameter (dp), run duration (t), loading rate (V), effective surface diffusivity (D), Reynolds number (Re), Schmidt number (Sc), liquid density (ρ_L), viscosity (μ), and liquid diffusivity of arsenic (DL). Subscript “SC” indicates small column (i.e., RSSCT column) and “LC” indicates large column. Figure 1 shows a schematic of the RSSCT set-up.




Figure 1: RSSCT configuration with pre-column glass wool filter.

RSSCT columns are 0.43 cm diameter tubes. Piston pumps (QG150) with stainless steel heads (Q2CSC) are used (Fluid Metering Inc. Syosset, NY). Glass wool packed into the bottom of the column supports the adsorbent. The sieved adsorbent (140x170 mesh) is added to the column using a funnel and ultra-pure water to flush the material down into the column. The precise amount of adsorbent media in the columns will be calculated based upon proportional diffusivity scaling approaches to a representative demonstration scale packed bed system (Badruzzaman 2002; Badruzzaman et al. 2004; Westerhoff et al. 2005). Columns are backwashed to remove fines, by operating the column in upflow mode (bed expansion of approximately 40%) with distilled water until the effluent water visually ran clear. The typical flow rate for backwashing the mini columns are in the 5-25 ml/min range and resulted in bed expansion of approximately 40%.

RSSCTs were set up to treat at least 75,000 bed volumes of water. The RSSCT simulate a full-scale system with an empty bed contact time (EBCT) of 2.5 min EBCT and a loading rate of 6 gpm/ft². The RSSCT used 140x170 mesh material and proportional diffusivity scaling parameters. The RSSCT column length was 3.75 cm and 3.85 cm for E33 and GFH. The columns were operated at a flowrate of 2.26 and 2.32 mL/min, respectively.

Material Preparation and Column Setup Methodology

Sample bottles and testing equipment were cleaned to ensure no organic or inorganic contamination, following techniques used by Badruzzaman, et al. 2004. Sample bottles and equipment were placed into a 0.1% Alconox solution overnight, triple-rinsed with deionized water, dried, placed into 10% nitric acid overnight, triple-rinsed with deionized water, and dried. Media preparation included grinding and sieving both sorbents (E33 and GFH) to an approximate crushed media diameter size of 0.096 mm. Sorbents were placed in a mortar with deionized water and grinded using a pestle. Grounded sorbents were then sieved through a sieve stack of 140x170 (No. 140 on top of No. 170), using deionized water. Sorbents collected on the No. 170 sieve were stored in centrifuged tubes, with the remaining volume filled with deionized water. This was done to ensure the sorbents stayed moist, avoiding oxidation.

The RSSCT setup followed the schematic shown in the Figure 1. The influent was first passed through a pre-filtration column using glass wool to avoid fouling and clogging within the sorbent column. Water is then passed through the pump and enters through the top of the sorbent column.

The sorbent column is positioned vertically, where sorbents are placed on top of glass wool. Glass wool was used to prevent sorbent leaching into the effluent.

Sample Collection and Analysis

Samples from 2 locations (influent and effluent from each RSSCT) were collected periodically for around 17 days. Samples were filtered and acidified 2% with trace-metal grade nitric acid (HNO₃). A detailed account of the obtained data and associated bed volumes is available in the Appendix (Table A2 and A3). Samples of approximately 45 mL were taken and immediately stored in the dark at a 4 °C. ASU conducted analysis on the samples for general water characteristics (pH and conductivity) and through induced coupled plasma-mass spectrometry (ICP-MS). The ICP-MS measured concentrations of species (V, Cr, Cu, Se, As, Si, U, and W) by atomizing any molecules to their atomistic constituents. RSSCT's were run to approximately 96,000 bed volumes.

RSSCT Results

The average influent conditions for the waters during each test are summarized below in **Table 1**.

Table 1: Summary of average influent concentrations. Note, BDL indicates below detection limit.

Parameter	Bay City, TX
Influent pH	8.5
Influent Total Alkalinity (mg/L CaCO ₃)	260
Influent Conductivity (μS/cm)	605
Phosphate (ppm)	0.9
Sulfate (ppm)	14
As	8.7 ± 0.3
V	BDL
Cr	BDL
Cu	BDL
Cd	BDL
Se	BDL
U	BDL
W	BDL
Si (ppm)	8.6

E33 Bayoxide and Granular Ferric Hydroxide RSSCT Performance

A RSSCT was performed using the sorbent E33 Bayoxide, produced by AdEdge Media. This column was run to 95,820 bed volumes treated (BVT) and breakthrough of chemicals were monitored through the effluent. The fastest breakthrough (lowest adsorption) was observed for Si, followed by As.

A RSSCT was conducted using Granular Ferric Hydroxide (GFH). This column was run to 96,030 bed volumes treated (BVT) and breakthrough profiles were monitored through the effluent for both As and Si. Breakthrough profiles for both media, including influent As concentration, can be seen in **Figure 1**.

Figure 1 compares arsenic breakthrough curves for E33 and GFH. We conclude there is little difference in the arsenic breakthrough curves between the E33 and GFH column for arsenic. This means the capacity, lifetime and replacement frequency of the media based upon arsenic removal under the conditions tested would not differ. Both adsorbents achieved between 10,000 to 14,000 bed volumes treated before exceeding the 1 ug/L detection limit for arsenic. Approximately 80% arsenic breakthrough occurred around 100,000 bed volumes treated.




Figure 1: Arsenic Breakthrough curve for E33, up to 95,820 bed volumes treated.

Findings

- E33 and GFH. We conclude there is little difference in the arsenic breakthrough curves between the E33 and GFH column for arsenic. This means the capacity, lifetime and replacement frequency of the media based upon arsenic removal under the conditions tested would not differ. Both adsorbents achieved between 10,000 to 14,000 bed volumes treated before exceeding the 1 ug/L detection limit for arsenic. Approximately 80% arsenic breakthrough occurred around 100,000 bed volumes treated.
- E33 and GFH show similar performance for the breakthrough profiles of silica.
- The water had non-detectable concentrations of other metals (vanadate, tungstate, uranate) that are often considered competing species for arsenate removal. This is potentially one reason why both E33 and GFH media resulted in similar performance in removing arsenic.
- Other operational factors (e.g., pressure fluctuations, turbidity, backwashing, etc.) affected by on-site conditions may influence replacement frequency of arsenic adsorption media.

References

- [1] M. Vahter, "Health effects of early life exposure to arsenic," *Basic Clin. Pharmacol. Toxicol.*, vol. 102, no. 2, pp. 204–211, 2008.
- [2] K. M. Zierold, L. Knobeloch, and H. Anderson, "Prevalence of chronic diseases in adults exposed to arsenic-contaminated drinking water," *Am. J. Public Health*, vol. 94, no. 11, pp. 1936–1937, 2004.
- [3] M. Badruzzaman, P. Westerhoff, and D. R. U. Knappe, "Intraparticle diffusion and adsorption of arsenate onto granular ferric hydroxide (GFH)," *Water Res.*, vol. 38, no. 18, pp. 4002–4012, 2004.
- [4] P. K. Westerhoff, "RSSCT Training Protocol," 2015.

APPENDICES

Rapid Small-Scale Column Tests: Arsenic Removal by E33 and GFH for Bay City, TX

Report Prepared by

Paul Westerhoff, Professor

Chao Zheng, Assistant Professor

Emily Briese, PhD student

School of Sustainable Engineering & The Built Environment

Arizona State University

Tempe, Arizona 85287-5306

National Science Foundation

Nanosystems Engineering Research Center for Nanotechnology Enabled Water Treatment

September 2022

Table A1: Metal Concentrations detected by ICP-MS for E33

Sample ID	ICP-MS Bay City E33 (ppb)											
	Date	Time	Bed Volume Treated	V	Cr	Cu	Cd	Se	As	Si (ppm)	U	W
1 E33		11:45 AM	125	BDL	2.1	BDL	BDL	BDL	0.0	2.5	BDL	BDL
2 E33	8/29/22	2:06 PM	713	BDL	2.1	BDL	BDL	BDL	0.0	6.7	BDL	BDL
3 E33		7:04 PM	1950	BDL	BDL	BDL	BDL	BDL	0.0	7.8	BDL	BDL
4 E33		8:43 AM	5350	BDL	BDL	BDL	BDL	BDL	0.0	8.1	BDL	BDL
5 E33	8/30/22	11:20 AM	6000	BDL	BDL	BDL	BDL	BDL	0.0	8.1	BDL	BDL
6 E33		2:56 PM	6900	BDL	BDL	BDL	BDL	BDL	0.0	8.0	BDL	BDL
7 E33	8/31/22	8:24 AM	11250	BDL	BDL	BDL	BDL	BDL	0.0	8.2	BDL	BDL
8 E33		3:25 PM	13000	BDL	BDL	BDL	BDL	BDL	0.0	8.2	BDL	BDL
9 E33	9/1/22	8:53 AM	17350	BDL	BDL	BDL	BDL	BDL	0.0	8.2	BDL	BDL
10 E33		4:43 PM	19300	BDL	BDL	BDL	BDL	BDL	0.0	8.3	BDL	BDL
11 E33	9/2/22	11:35 AM	24000	BDL	BDL	BDL	BDL	BDL	0.0	8.4	BDL	BDL
12 E33		1:23 PM	24450	BDL	BDL	BDL	BDL	BDL	0.0	8.3	BDL	BDL
13 E33	9/3/22	2:16 PM	30650	BDL	BDL	BDL	BDL	BDL	0.0	8.4	BDL	BDL
14 E33	9/4/22	1:33 PM	36450	BDL	BDL	BDL	BDL	BDL	0.0	8.3	BDL	BDL
15 E33	9/5/22	3:47 PM	42985	BDL	BDL	BDL	BDL	BDL	0.8	8.5	BDL	BDL
16 E33	9/6/22	10:55 AM	47750	BDL	BDL	BDL	BDL	BDL	1.6	8.6	BDL	BDL
17 E33	9/7/22	11:06 AM	53775	BDL	BDL	BDL	BDL	BDL	2.7	8.5	BDL	BDL
18 E33	9/8/22	8:43 AM	59160	BDL	BDL	BDL	BDL	BDL	3.2	8.5	BDL	BDL
19 E33	9/9/22	4:40 PM	67120	BDL	BDL	BDL	BDL	BDL	3.8	8.4	BDL	BDL
20 E33	9/10/22	11:24 AM	71790	BDL	BDL	BDL	BDL	BDL	4.1	8.5	BDL	BDL
21 E33	9/11/22	4:09 PM	78950	BDL	BDL	BDL	BDL	BDL	5.4	8.5	BDL	BDL
22 E33	9/12/22	12:25 PM	84000	BDL	BDL	BDL	BDL	BDL	6.0	8.7	BDL	BDL
23 E33	9/13/22	10:54 AM	89600	BDL	BDL	BDL	BDL	BDL	6.3	8.7	BDL	BDL
24 E33	9/14/22	11:52 AM	95820	BDL	BDL	BDL	BDL	BDL	6.8	8.7	BDL	BDL

Table A2: Metal Concentrations detected by ICP-MS for GFH

Sample ID	ICP-MS Bay City GFH (ppb)											
	Date	Time	Bed Volume Treated	V	Cr	Cu	Cd	Se	As	Si (ppm)	U	W
1 GFH	8/29/22	11:25 AM	125	BDL	BDL	BDL	BDL	BDL	0.0	4.6	BDL	BDL
2 GFH		1:46 PM	713	BDL	BDL	BDL	BDL	BDL	0.0	7.9	BDL	BDL
3 GFH		6:43 PM	1950	BDL	BDL	BDL	BDL	BDL	0.0	8.9	BDL	BDL
4 GFH	8/30/22	8:20 AM	5350	BDL	BDL	BDL	BDL	BDL	0.0	8.9	BDL	BDL
5 GFH		10:57 AM	6000	BDL	BDL	BDL	BDL	BDL	0.0	8.8	BDL	BDL
6 GFH		2:33 PM	6900	BDL	BDL	BDL	BDL	BDL	0.0	8.9	BDL	BDL
7 GFH	8/31/22	7:58 AM	11250	BDL	BDL	BDL	BDL	BDL	0.0	8.8	BDL	BDL
8 GFH		2:59 PM	13000	BDL	BDL	BDL	BDL	BDL	0.0	9.0	BDL	BDL
9 GFH	9/1/22	8:24 AM	17350	BDL	BDL	BDL	BDL	BDL	0.0	9.0	BDL	BDL
10 GFH		4:13 PM	19300	BDL	BDL	BDL	BDL	BDL	0.0	9.0	BDL	BDL
11 GFH	9/2/22	11:02 AM	24000	BDL	BDL	BDL	BDL	BDL	0.0	9.1	BDL	BDL
12 GFH		12:50 PM	24450	BDL	BDL	BDL	BDL	BDL	0.0	8.9	BDL	BDL
13 GFH	9/3/22	1:40 PM	30650	BDL	BDL	BDL	BDL	BDL	0.0	9.3	BDL	BDL
14 GFH	9/4/22	12:54 PM	36450	BDL	BDL	BDL	BDL	BDL	0.0	9.1	BDL	BDL
15 GFH	9/5/22	3:26 PM	43075	BDL	BDL	BDL	BDL	BDL	0.5	9.2	BDL	BDL
16 GFH	9/6/22	10:34 AM	47850	BDL	BDL	BDL	BDL	BDL	1.4	9.2	BDL	BDL
17 GFH	9/7/22	10:45 AM	53890	BDL	BDL	BDL	BDL	BDL	2.3	9.2	BDL	BDL
18 GFH	9/8/22	8:27 AM	59308	BDL	BDL	BDL	BDL	BDL	3.0	9.2	BDL	BDL
19 GFH	9/9/22	4:37 PM	67340	BDL	BDL	BDL	BDL	BDL	3.8	9.2	BDL	BDL
20 GFH	9/10/22	11:05 AM	71950	BDL	BDL	BDL	BDL	BDL	4.4	9.3	BDL	BDL
21 GFH	9/11/22	3:50 PM	79125	BDL	BDL	BDL	BDL	BDL	5.1	9.0	BDL	BDL
22 GFH	9/12/22	12:04 PM	84180	BDL	BDL	BDL	BDL	BDL	5.4	9.1	BDL	BDL
23 GFH	9/13/22	10:35 AM	89800	BDL	BDL	BDL	BDL	BDL	6.5	9.5	BDL	BDL
24 GFH	9/14/22	11:32 AM	96030	BDL	BDL	BDL	BDL	BDL	6.6	9.3	BDL	BDL

Arsenic Treatment Proposals

Mike O'Day – O'Day Drilling

- Local well driller with extensive knowledge of water wells and water quality
- Reviewed the drillers logs for each of our water wells, sampling results for arsenic and total dissolved solids (2005 to current)
- Explained that arsenic lies within zones within the aquifer – rather than treating it after it is pumped, recommend a strategy to minimize arsenic level within the well
- Proposal: downhole camera survey, cleaning and conduct water quality study to identify the zone where arsenic is located
- Once the zone is determined the well can be blocked to minimize the arsenic level in the groundwater pumped
- Mr. O'Day is consulting with his colleagues to gather information on what company could conduct the water quality study (9/14/2022)
- Not on EPA's list of best available technologies – would have to verify with TCEQ

Update as of 11/29/2022

- Texas Commission on Environmental Quality did respond to my inquiry regarding Mr. O'Day's proposal. The Plan and Technical Review Team advised they would consider the approach. However, it would require a plans and specification submittal which must be prepared and submitted by a licensed engineer before any work is started.
- Points to consider:
 - Finding an engineer to prepare plans may be difficult since this is an atypical approach and not considered a best available technology
 - There is a possibility TCEQ may not approve the plans once submitted
- Gathering quotes for pulling the well, downhole camera survey and cleaning.
- Searching for a company that would conduct the water quality study to determine arsenic zone within the aquifer.

Arsenic Treatment Proposals

David Burnett

- David Burnett – retired TAMU Engineer, wastewater treatment in oil/gas industry
- Greg Reymeke - Crusader Water Systems of Utah
- Keith McLeroy (College Station) - Retegeo Labs & Les Merrill
- Proposal: pilot water treatment using Crusader adsorbent technology
- Designed based on well configuration, water flow & quality data
- Mr. Burnett and Mr. Keith McLeroy would be local engineers assisting in monitoring and assessment of pilot
- Likely no cost for the proposal
- Will need to conduct a site visit – waiting for proposal and a confirmed date from Mr. Burnett to schedule the site visit
- This treatment is similar to Garver’s proposal
- Will require TCEQ approval to ensure it meets approved treatment technologies

Update as of 11/29/2022

- No proposal received from Retegeo Labs/Crusader Water Systems of Utah
- Mr. Burnett recently recommended DeNora Water Services; office located in Sugarland. He has reached out to their office to arrange a meeting.
- In reviewing the information on their website, www.denora.com, their recommended treatment for arsenic is also adsorption.
 - Excerpts from their website:
 - The easiest way to remove arsenic is to use iron to adsorb it from the water. The iron is then removed and disposed of to a sanitary landfill.
 - If your groundwater already has iron present, by simply precipitating and filtering it out of the water, you can also remove the arsenic via co-precipitation/adsorption followed by filtration.