

ELECTRICAL SAFETY INSPECTOR ADVISORY COMMITTEE REQUEST FOR RECOMMENDATIONS

DATE:DECEMBER 10, 2021TIME:12:00 PMLOCATION:NO MEETING THIS MONTH

#### **Call to Order**

P-1

#### **Personnel Certification Applications**

Farmer, Michael - ESI Cert ID: 8726 Current Certifications: None Staff Notes: Appears to meet requirements for certification ESIAC Recommendations: Committee Recommendation:

#### **Continuing Education Applications for Review**

- ER-1 Generators and the 2020 NEC (Matthews Electrical Services) All certifications except PI, NRIUI, RMI, and RIUI (4 hours) Staff Notes: ESIAC Recommendation: Committee Recommendation:
- <u>ER-2</u> Grounding and Bonding Part 2: Beyond the Basics (Matthews Electrical Services) BO, MPE, EPE, FPPE, BI, ESI, RBO, RPE, RBI (4 hours) Staff Notes:
   ESIAC Recommendation: Committee Recommendation:
- ER-3 Health Care Facilities, Fault Currents, Common Defects (IAEI) All certifications except IU and plumbing (6 hours) Staff Notes: ESIAC Recommendation: Committee Recommendation:

#### **Old Business**

#### **New Business**

#### Adjourn

#### File Attachments for Item:

P-1 Farmer, Michael - ESI Cert ID: 8726 Current Certifications: None Staff Notes: Appears to meet requirements for certification ESIAC Recommendations: Committee Recommendation:

Application for Interim Certification, Building Department Personnel

Farmer

First Name

Michael

**BBS** Certification ID

## SECTION 1: CHECK INTERIM CERTIFICATION(S) BEING REQUESTED

| Building Official | Master Plans   | Building       | Electrical Safety | Fire Protection |
|-------------------|----------------|----------------|-------------------|-----------------|
|                   | Examiner       | Inspector      | Inspector         | Inspector       |
| Building Plans    | Plumbing Plans | Mechanical     | Electrical Plans  | Fire Protection |
| Examiner          | Examiner       | Plans Examiner | Examiner          | Plans Examiner  |
|                   | Plumbing       | Mechanical     | Non-Residential   |                 |
|                   | Inspector      | Inspector      | Industrial Unit   |                 |
|                   |                |                | Inspector         |                 |

# SECTION 2: LIST ANY OHIO LICENSE, CERTIFICATE, OR REGISTRATION HELD

(Mark "T" If Trainee)

| Description                                   |              |                                       | Certificate Number | Date Received |
|---|--------------|---------------------------------------|--------------------|---------------|
| Architectu                                    | iral Registi | ration                                |                    |               |
| P.E. Regi                                     | stration     |                                       |                    |               |
| Res   | Non-Res      |                                       |                    |               |
|   |              | Building Official Certification       |                    |               |
|   |              | Plans Examiner Certification          |                    |               |
|   |              | Building Inspector Certification      |                    |               |
|   |              | Mechanical Inspector<br>Certification |                    |               |
| Building F                                    | lans Exan    | niner Certification                   |                    |               |
| Mechanic                                      | al Plans E   | xaminer Certification                 |                    |               |
| Fire Prote                                    | ction Plan   | s Examiner Certification              |                    |               |
| Electrical Plans Examiner Certification       |              | miner Certification                   |                    |               |
| Plumbing Plans Examiner Certification         |              | miner Certification                   |                    |               |
| Fire Prote                                    | ction Inspe  | ector Certification                   |                    |               |
| Electrical Safety Inspector Certification     |              | pector Certification                  |                    |               |
| Plumbing Inspector Certification              |              | Certification                         |                    |               |
| Fire Safety Inspector Certification           |              | r Certification                       |                    |               |
| Fire Protection System Designer Certification |              | em Designer Certification             |                    |               |
| Medical Gas Piping Inspector Certification    |              | Inspector Certification               |                    |               |

Application for Interim Certification, Building Department Personnel

Farmer

First Name

Michael

**BBS** Certification ID

#### SECTION 3: EMPLOYMENT/EDUCATION

| Formal Education   | Date Graduated    |
|--|-------------------|
| Avon High School   | 1986              |
|  |                   |
| Related Vocational or Technical Training                                 | Years' Experience |
| International Brotherhood of Electrical Workers Local 129 Apprenticeship | 4                 |
| U.S. Military construction experience (MOS or other designation):        | Years' Experience |
|  |                   |
|  | Years' Employed   |
| IBEW Local 129   | 26                |

#### SECTION 4: APPLICANTS REQUESTING MEDICAL GAS INSPECTOR CERTIFICATION

Attach proof of certification by an ASSE recognized third-party certifier in accordance with ASSE standard 6020.

# SECTION 5: OBC BUILDING INSPECTION EXPERIENCE PERFORMED FOR A BBS CERTIFIED BUILDING DEPARTMENT

| BBS Certified Building<br>Department | BBS Certified<br>Position/Title | Duties | Date of Service,<br>Length of Time<br>(MM/DD/YY) |
|--------------------------------------|---------------------------------|--------|--|
|                                      |                                 |        |  |
|                                      |                                 |        |  |
|                                      |                                 |        |  |
|                                      |                                 |        |  |
|                                      |                                 |        |  |
|                                      |                                 |        |  |

Farmer Last Name

First Name

Michael

**BBS** Certification ID

### SECTION 6: ELECTRICAL SAFETY INSPECTOR (ESI) - SPECIFIC EXPERIENCE QUALIFICATIONS Applicants for Electrical Safety Inspector <u>Only</u> Must Complete This Item

Section 3783 of the Ohio Revised Code specifies that an applicant for a Certificate of Competency as an Electrical Safety Inspector must meet on of the following to qualify to take required examination. Please check the qualification that applies:

- 1. Have been a journeyman electrician or equivalent for four years, two of which were as an electrician foreman, and have had two years' experience as a building department electrical inspector trainee;
- 2. Have been a journeyman electrician or equivalent for four years and have had three years' experience as a building department electrical inspector trainee;
- 3. Have had for four years' experience as a building department electrical inspector trainee;
- 4. Have been a journeyman electrician or equivalent for six years;
- 5. Am a graduate electrical engineer and registered in the State of Ohio. Registration number:
- 6. Applicant authorizes all testing organizations including ICC to provide test results to the BBS.

#### SECTION 7: EXPERIENCE (DO NOT SUBSTITUTE WITH OTHER RESUMES).

Refer to Experience Requirements Listed in O.A.C. 4101:7-3-01 and O.R.C. 3783

Below, list the specific projects you worked on, and the specific work you performed, your typical duties for each project, and dates of this work. You **must** demonstrate that you have the required number of months (years) of actual, practical experience for the certification requested (see matrix).

Provide letters from certified inspectors, employers, or contractors verifying your experience. Submit copies of any certificates, diplomas, or licenses. Remove all personal information.

| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed | Name of Employer, Contact, Address,<br>Telephone Number | Project Time: From_ To<br>(MM/YY) |  |
|--|---|-----------------------------------|--|
| Example:   | Homer Steel and Trade                                   | July 2013-May 2014                |  |
| Children's Hospital, Toledo  | 125 Anytown Street                                      | (10 months)                       |  |
| Structural steel work on addition  | My City, OH, 45454<br>(419)555-1212                     |                                   |  |
|  |   |                                   |  |
|  |   |                                   |  |
|  | 10  |                                   |  |
|  |   |                                   |  |
|  |   |                                   |  |
|  |   |                                   |  |
| otal Experience on This Page (In Months):                                    |   |                                   |  |

#### SECTION 7 CONT.: EXPERIENCE

Board of Building Standards Application for Interim Certification, Building Department Personnel

| Farmer   | Michael   |                                     |
|--|---|-------------------------------------|
| Last Name  | First Name  | BBS Certification ID                |
| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed   | Name of Employer, Contact, Address,<br>Telephone Number | Project Time: From_ To _<br>(MM/YY) |
| Republic Steel, Lorain, Ohio<br># 3 Blast Furnace Rebuild<br>Installed and terminated13.8 KV<br>Feeder from WQC to new<br>substation. Construct new<br>substation with step down<br>transformers and motor control<br>centers to operate blast furnace<br>equipment. Perform all grounding<br>(mechanical & exothermic) and<br>bonding required by code.<br>Installed PVC coated rigid<br>galvanized conduit and fiberglass<br>cable tray for power and control<br>wiring. Conduits and tray fill were<br>calculated per code requirements.<br>Installed and terminated 250 Volt<br>DC Feeders to operate Skip Car<br>motors. Performed standby for<br>start up of the Blast Furance | Henry J Kaiser<br>Pittsburgh, PA.                       | 04/92 to 11/92                      |

Application for Interim Certification, Building Department Personnel

Michael

Farmer Last Name

First Name

| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed   | Name of Employer, Contact, Address,<br>Telephone Number  | Project Time: From_ To _<br>(MM/YY) |
|--|--|-------------------------------------|
| Industrial Plastics New 800A 480V 3<br>Phase 4 Wire Distribution Panel and<br>Equipment - ForemanCoordinate work<br>with other trades to install parallel 4"<br>EMT Conduits, supports and properly<br>sized junction boxes from 4000A 480V<br>main service in back of building to a<br>location in the front of the building to<br>service new equipment. Install 4 - 500<br>MCM and 1/0 Ground per conduit and<br>terminate. Install new perimeter<br>grounding and connect to new<br>equipment and building steel. Install<br>Schedule 40 PVC conduits sized per<br>wire fill for new equipment and<br>transition to GRC conduit above<br>finished floor. | Higgins Electric<br>620 Sugar Lane<br>Elyria, Ohio 44035 | 06/93 to 08/93                      |
| BF Goodrich Building 471 New Estane<br>Line - Foreman<br>Responsible for the installation and<br>coordination of a new line in a Class 1<br>Division 1 environment. Responsible<br>for the ordering of proper explosion<br>proof materials and over seeing the<br>installation of GRC conduit, fittings,<br>seal-offs, junction boxes, explosion<br>proof flex, and wiring from MCC to new<br>equipment and motors in the field.<br>Installed control wiring from operator<br>booth to locations in the field.   |  | 09/93 to 02/94                      |
| EMH Hospital 2nd Floor Surgery<br>Remodel Work included installing a<br>new 800A 480V 3 Phase 4 Wire<br>Emergency Power Feed for a new<br>distribution panel to supply 277V<br>lighting and emergency power via a<br>step down transformer for 208/120V<br>power. Install branch circuits for normal<br>and emergency power. Install 277V<br>lighting and emergency lighting. Install<br>new operating lights and equipment in<br>each room.   |  | 03/94 to 09/94                      |
|  | Total Experience on This Page (In Months):               | 14                                  |

Last Name

Application for Interim Certification, Building Department Personnel

Farmer

Michael

First Name

| North Ridgeville High School<br>Addition<br>Install Sch 40 PVC underground<br>for new service, distribution<br>panels and branch circuits in<br>various spots of building. Work<br>with masons to install panel tubs<br>and conduit stubs in block walls<br>using EMT and compression<br>couplings. Relocate framing to<br>accommodate electrical panel and<br>equipment. Install ground system<br>and bond at the main service.<br>Install service entrance<br>conductors and terminate. Install<br>wire for branch circuits following<br>code for conduit fill and derating<br>of conductors as required.<br>Installed conduit and wire for<br>277V indoor, outdoor and<br>emergency lighting. Install<br>switches and outlets. Install<br>wire and mounting devices and<br>panels. Test Fire Alarm for proper<br>operation. Work with other trades<br>to coordinate all this work. | List Each Construction Project <u>AND</u><br>Specific Type of Work Performed  | Name of Employer, Contact, Address,<br>Telephone Number  | Project Time: From_ To(MM/YY) |
|---|---|--|-------------------------------|
| Total Experience on This Page (In Months): 16   | North Ridgeville High School<br>Addition<br>Install Sch 40 PVC underground<br>for new service, distribution<br>panels and branch circuits in<br>various spots of building. Work<br>with masons to install panel tubs<br>and conduit stubs in block walls<br>using EMT and compression<br>couplings. Relocate framing to<br>accommodate electrical panel and<br>equipment. Install ground system<br>and bond at the main service.<br>Install service entrance<br>conductors and terminate. Install<br>wire for branch circuits following<br>code for conduit fill and derating<br>of conductors as required.<br>Installed conduit and wire for<br>277V indoor, outdoor and<br>emergency lighting. Install<br>switches and outlets. Install Fire<br>Alarm System including conduit,<br>wire and mounting devices and<br>panels. Test Fire Alarm for proper<br>operation. Work with other trades<br>to coordinate all this work. | Higgins Electric<br>620 Sugar Lane<br>Elyria, Ohio 44035 | 09/94 to 12/95                |

#### B £ n 20.00

| board of building Standards A   | pplication for Interim Certification, Building De                                  | partment Personnel     |
|---|--|------------------------|
| Farmer  | Vichael  |                        |
| Last Name   | First Name   | BBS Certification ID   |
| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed  | Name of Employer, Contact, Address,<br>Telephone Number                            | Project Time: From_ To |
| Lorain Ford Plant Expansion<br>Fabricated structural supports for<br>electrical equipment and conduits<br>mounted in the field. Installed<br>cable tray, grounding jumpers and<br>480V armored cable feeds for<br>buss duct. Install buss duct, buss<br>plugs and armored cable to<br>various Motor Control Centers to<br>feed conveyors and equipment.<br>Promoted to Foreman to oversee<br>the electrical installation of the<br>finish conveyor system. This<br>included coordinating work with<br>multiple trades, ordering the<br>proper materials and attending<br>progress meetings. The electrical<br>portion of this project was a<br>combination of cable tray, GRC<br>conduit, fittings, junction boxes,<br>disconnects, SO and SJO Cords<br>used for proximity switches and<br>solenoids. The motors for the<br>conveyor were all 480V 3 phase<br>and controlled by the motor<br>starters located in the MCC with<br>properly sized overloads.The<br>control wiring was all 120V and<br>feed from the inputs inside the<br>MCC. | Lake Erie Electric<br>25730 First Street<br>Westlake, Ohio 44145<br>(440) 835-5688 | 01/96 to 02/97         |

Total Experience on This Page (In Months):

14

Application for Interim Certification, Building Department Personnel

Farmer

Michael

Last Name First Name **BBS** Certification ID List Each Construction Project AND Name of Employer, Contact, Address, Project Time: From\_To\_ Specific Type of Work Performed **Telephone Number** (MM/YY) Owens Corning Medina Lake Erie Electric 03/97 to 07/97 New Shingle Production Line 25730 First Street Westlake, Ohio 44145 Installed GRC conduit and all the (440) 835-5688 necessary supports, fittings and junction boxes to complete a pathway for the wiring needed to power and control the system including safety stops. Install PVC coated flexible conduit and fittings to motors. Fabricated supports for electrical equipment and conduit supports. Worked with Iron Workers to set electrical structures on roof and wire them up. The voltages for this project consisted of 277/480V 3 phase 4 wire for equipment and 120/208V 3 phase 4 wire for control and general duty power. **Total Experience on This Page (In Months):** 5

Application for Interim Certification, Building Department Personnel

Farmer

Michael

First Name

| BBS | Certification | ID |
|-----|---------------|----|
|-----|---------------|----|

| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed | Name of Employer, Contact, Address,<br>Telephone Number | Project Time: From_ To<br>(MM/YY) |
|--|---|-----------------------------------|
| Offices & Distribution Warehouse   | South Shore Electric                                    | 08/97 to 05/98                    |
| Cleveland, Ohio  | 589 Ternes Avenue                                       | 1                                 |
| Foreman  | Elvria, Ohio 44035                                      |                                   |
|  | (440) 366-6289  |                                   |
| Responsible for the coordination and   |   |                                   |
| installation of the complete electrical                                      |   |                                   |
| system for this project including the  |   | 1                                 |
| fire alarm system and  |   |                                   |
| communications. Review drawings  |   |                                   |
| and order materials to ensure proper   |   |                                   |
| conduit sizes, supports and junction   |   |                                   |
| boxes based off circuit groupings  |   |                                   |
| and wire fill. Attend weekly project   |   |                                   |
| meetings and coordinate work with  |   |                                   |
| the other trades. Contact building   |   |                                   |
| department to discuss local  |   |                                   |
| requirements and inspections for the   |   |                                   |
| project. The project included the  |   |                                   |
| installation of Schedule 40 PVC  |   |                                   |
| conduit for the underground, EMT   |   |                                   |
| conduit for the office area, and   |   | 1                                 |
| Galvanized Rigid Conduit for the   |   |                                   |
| warehouse area. Flexible metallic  |   |                                   |
| conduit and liquid tight were used for                                       |   |                                   |
| the proper equipment pathways. The   |   |                                   |
| wiring included service entrance   |   |                                   |
| conductors, sub panel feeds, branch  |   |                                   |
| circuits and lighting feeds. The   |   |                                   |
| lighting for this project was 277V.  |   |                                   |
| Light fixtures in office were installed                                      |   |                                   |
| in drop ceiling using hurricane clips  |   |                                   |
| and tying the 4 corners of each  |   |                                   |
| fixture to building steel. The light   |   |                                   |
| fixtures in the warehouse where  |   |                                   |
| 400W Metal Halide with a cord cap  |   |                                   |
| for disconnecting means and a cable  |   |                                   |
| attached to the bar joist for safety.  |   |                                   |
| This building required a fire pump   |   |                                   |
| that was fed directly from the   |   |                                   |
| transformer to a disconnect.   |   |                                   |
|  |   |                                   |
|  | Total Experience on This Base (In Market                |                                   |
|  | Total Experience on This Page (In Months):              | 10                                |

Application for Interim Certification, Building Department Personnel

Michael

Farmer

First Name

| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed   | Name of Employer, Contact, Address,<br>Telephone Number   | Project Time: From_ To<br>(MM/YY)                         |
|--|---|---|
| List Each Construction Project AND<br>Specific Type of Work Performed<br>US Steel - Lorain, Ohio<br>#3 Bar Mill 13.8KV Re-Conductor<br>Project<br>I was temporarily removed from<br>South Shore Electric by our<br>Business Manager to perform<br>structural fabrication and<br>installation for this project<br>because I had certification in<br>structural welding (vertical up &<br>overhead).<br>Project consisted of the<br>installation of new structural<br>towers and foundations, including<br>grounding, addition of structural<br>supports to existing towers and<br>buildings to provide an over head<br>pathway from Clinton Sub Station<br>addition to the new electrical | Name of Employer, Contact, Address,<br>Telephone Number<br>Higgins Electric<br>620 Sugar Lane<br>Elyria, Ohio 44035 | Project Time: From_ To _ (MM/YY)           06/98 to 02/99 |
| equipment located in #3 Bar Mill.<br>Install switchgear and connect via<br>buss tie in for all conductors and<br>grounds inside Clinton Sub. Install<br>ground wire, lighting arrestors,<br>messenger, hang rollers and rig<br>corners to install ungrounded<br>Hendrix Cable. Remove rollers<br>and replace with Hendrix Cable<br>supports. Complete 15KV<br>terminations, perform Megger test<br>to check insulation and Hipot test<br>to check for leakage before<br>energizing equipment.  |   |   |
|  | Total Experience on This Page (In Months):  | 8   |

Farmer

Application for Interim Certification, Building Department Personnel

| Last Name  | First Name  | BBS Certification ID              |
|--|---|-----------------------------------|
| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed   | Name of Employer, Contact, Address,<br>Telephone Number                           | Project Time: From_ To<br>(MM/YY) |
| Church on The Rise - New<br>Westlake, Ohio<br>Foreman  | South Shore Electric<br>589 Ternes Avenue<br>Elyria, Ohio 44035<br>(440) 366-6289 | 02/99 to 01/00                    |
| installation of the temporary<br>power, electrical system, fire<br>alarm system and sound system.<br>Responsible for scheduling<br>inspections, weekly job meetings,           |   |                                   |
| and trade coordination. Sch 40<br>PVC conduit and fittings were<br>used for underground<br>applications. EMT and set screw<br>fittings were used for all work                  |   |                                   |
| necessary junction boxes and<br>provided grounding as required by<br>code. Installed service equipment<br>and sub panels as shown on<br>plans. Grounding was completed         |   |                                   |
| by the use of the copper water<br>main and a supplemental ground<br>rod. bonding was provided at<br>main service. Installed all branch<br>wiring for power and lighting.       |   |                                   |
| Lighting was installed as required<br>by the Authority having<br>jurisdiction. Install all electrical<br>devices and check for operation.<br>Install wiring in conduit pathway |   |                                   |
| for FA System. Terminate and<br>mount pull stations, horn -<br>strobes, smoke detectors, duct<br>detectors, and heat detectors.<br>Provided pull strings in conduit            |   |                                   |
| pathway for sound system.  |   |                                   |

Michael

Ohio Board of Building Standards

Total Experience on This Page (In Months):

11

Application for Interim Certification, Building Department Personnel

Michael

Farmer

First Name

| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed  | Name of Employer, Contact, Address,<br>Telephone Number     | Project Time: From_ To<br>(MM/YY) |
|---|---|-----------------------------------|
| Firelands Hospital, Sandusky, OH<br>4 Story Addition<br>Responsible for the installation of<br>the conduit system and wire for a<br>new 800A 480V 3 phase 4 wire<br>distribution panel to supply power<br>to the new chillers for this<br>addition. The conduit was routed<br>from the penthouse to the first<br>floor of the addition. Completed<br>floor and wall penetrations where<br>needed and provided fire stop or<br>caulk for each. The conduit<br>system was EMT with<br>compression fittings. Junction<br>boxes were sized and install as<br>needed per code. Install new<br>Chiller Panel and terminate.<br>Installed conduit and wire from<br>new panel to chillers. Installed<br>temperature control system and<br>worked with company for start up<br>of the complete system. | Brady Electric<br>1721 Hancock Street<br>Sandusky, OH 44870 | 01/00 to 08/00                    |
|   | Total Experience on This Page (in Months):                  | / /                               |

Application for Interim Certification, Building Department Personnel

Farmer Michael

| Last Name  | First Name  | BBS Certification ID              |
|--|---|-----------------------------------|
| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed   | Name of Employer, Contact, Address,<br>Telephone Number                           | Project Time: From_ To<br>(MM/YY) |
| Business Agent / Assistant<br>NJATC Training Coordinator<br>Responsible for assisting the<br>Business Manager in providing<br>training for our apprentices and<br>continuing education for our<br>journeymen. Classes included<br>NEC code updates, conduit<br>bending, fiber optic, solar, PLC<br>Logic, high voltage terminations<br>and splices. Meet with local<br>building departments to discuss<br>issues or deficiencies they were<br>experiencing with inspections so<br>we could provide additional<br>training. Job site visits were<br>performed, as well surveys to help<br>us develop our training programs. | IBEW Local 129<br>6100 S Broadway Suite 201<br>Lorain, OH 44053<br>(440) 233-7156 | 07/00 to 01/05                    |
|  | Total Experience on This Page (In Months):  | 53                                |

Application for Interim Certification, Building Department Personnel

Farmer

Michael

First Name

| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed   | Name of Employer, Contact, Address,<br>Telephone Number                    | Project Time: From_ To<br>(MM/YY) |
|--|--|-----------------------------------|
| Project Manager / Partner<br>Responsible for the commercial<br>and residential bidding, project<br>management, service work,<br>ordering of materials and securing<br>proper permits and inspections for<br>all projects. Work included Avon<br>Lake Animal Clinic addition, EMH<br>Hospital (Office remodels, New<br>Generator, New Computer Room,<br>and service work), CenturyLink<br>Main Office remodel and<br>generator replacement, Old Navy,<br>Manco Duck Tape office remodel<br>and many service clients. Our<br>residential work included wiring<br>new homes and additions, service<br>changes and service work. All<br>work was performed to current<br>codes at that time. | Custom Electric<br>8185 Pyle South Amherst Road<br>South Amherst, OH 44001 | 01/05 to 03/07                    |
|  | · Experience en rina rage (in montina).                                    |                                   |

Application for Interim Certification, Building Department Personnel

Michael

Farmer

First Name

| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed  | Name of Employer, Contact, Address,<br>Telephone Number | Project Time: From_ To(MM/YY) |
|---|---|-------------------------------|
| Vice President of Operations.<br>Responsible for the day to day<br>operations of the company during<br>this time period as well as<br>securing all required permits. The<br>projects during this time period<br>where Certain Teed Shingle<br>Factory in Sandusky, Ohio. We<br>were responsible for the<br>installation of a new 480V feeder<br>from existing switchgear to a<br>location approximately 2000'<br>away. The work included<br>fabricating supports, junction<br>boxes, fittings and expansion<br>fittings for the new GRC conduits.<br>Cables and grounding bushings<br>were installed and terminated for<br>a finished product.<br>Tri-County Medical Offices in<br>Elyria, Ohio. We were awarded<br>the contract to provide complete<br>electrical service, fire alarm and<br>sound system pathway for this<br>project. This project incuded 277V<br>lighting and emergency lighting,<br>120V general power and 120V<br>emergency power. The electrical<br>system was a mixture of EMT<br>conduits and applicable fittings<br>and MC Cable and fittings for<br>small branch circuit drops and<br>lighting whips. All work was<br>installed according to code and<br>passed all inspections. | Higgins Electric<br>620 Sugar Lane<br>Elyria, OH 44035  | 04/07 to 10/07                |
|   | Total Experience on This Page (In Months):              | 6                             |

Farmer

Application for Interim Certification, Building Department Personnel

| Farmer   | Michael   |                                     |
|--|---|-------------------------------------|
| Last Name  | First Name  | BBS Certification ID                |
| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed   | Name of Employer, Contact, Address,<br>Telephone Number                             | Project Time: From_ To _<br>(MM/YY) |
| Purchased Higgins Electric 03/07.<br>Project Manger<br>Perry Middle School, Perry, OH<br>Carry over project from Higgins<br>Electric that was handed to me to<br>finish. We had subcontracted the<br>Tele / Data work for this project to<br>Andy Dever. This work included<br>installing all the data cabling, from<br>various IT rooms not exceeding<br>320'. We were responsible for the<br>the IT equipment installation and<br>testing of it along with all the<br>cabling. We installed the<br>equipment ladder racks but all<br>cable tray was installed by others.<br>First Merit Bank, Avon, OH.<br>Was the responsible person for<br>bidding and securing this project.<br>Applying and receiving all required<br>permits. Attend weekly project<br>meetings and coordinate work with<br>all trades. Support the electricians<br>by providing current information<br>and suppling needed materials.<br>The project included a new<br>electrical service, lighting, branch<br>circuits, fire alarm and security<br>system. The conduit system<br>consisted of SCH 40 PVC and<br>fittings for underground work. EMT<br>and MC Cable were used for<br>above ground work. All fittings and<br>junction boxes were UL approved. | Lake Erie Electric<br>7495 Industrial Parkway<br>Lorain, OH 44053<br>(440) 989-8200 | 03/07 to 10/08                      |
|  | Total Experience on This Page (In Months):  | 19                                  |

Application for Interim Certification, Building Department Personnel

Farmer

Michael

First Name

| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed  | Name of Employer, Contact, Address,<br>Telephone Number                           | Project Time: From_ To<br>(MM/YY) |
|---|---|-----------------------------------|
| Walmart - Lorain, Ohio<br>Responsible for the installation of<br>the automotive center in this<br>store. Coordinated work and<br>scheduled inspections as<br>required. Worked included 480V<br>sub panel feed, step down<br>transformer and 120/208V general<br>duty power panel. All service work<br>was installed per code including<br>bonding the transformer to<br>building steel. The lighting was<br>277V and the equipment was<br>120/208V, 3 phase 4 wire. We<br>installed the conduits, wire and<br>terminations for this project.                                    | South Shore Electric<br>589 Ternes Avenue<br>Elyria, Ohio 44035<br>(440) 366-6289 | 06/10 to 01/11                    |
| Flavorseal - Avon, Ohio<br>New Electric Heat Printer<br>Installed new equipment from<br>Germany that prints labels on the<br>food package bags. Installed a<br>new 800A feed from existing<br>switch gear. Install feds and<br>terminate on both ends. Ground<br>equipment via rebar and building<br>steel. Translate and install wiring<br>from MCC to equipment and<br>terminate. Check for operation.<br>Use the 10' tap rule to install<br>outlets per owner on equipment<br>by installing fuse blocks and<br>transformers in MCC to operate<br>needed auxiliary equipment. |   | 01/011 to 04/11                   |
|   | Total Experience on This Page (In Months):  | 9                                 |

Application for Interim Certification, Building Department Personnel

| Farmer   | Michael  |   |
|--|--|---|
| Last Name  | First Name   | BBS Certification ID                                |
| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed   | Name of Employer, Contact, Address,<br>Telephone Number  | Project Time: From_ To(MM/YY)                       |
| List Each Construction Project AND<br>Specific Type of Work Performed<br>Freeman Manufacturing<br>Avon, Ohio<br>Miscellaneous Projects<br>Customer purchased used tank<br>heater to melt wax for different<br>applications. Equipment had no<br>drawings and was installed per<br>customers specifications. I had to<br>mount equipment and control<br>panel, provide new 480V service<br>and size the control transformer to<br>operate the new controls. Install<br>GRC conduits on conveyor and<br>mount control devices for<br>operation. Bond conveyor at<br>splice points. Install all new wiring<br>and terminate for operation.<br>Installed 3 new sub panels in<br>various areas of the plant<br>provided by the owner for new<br>equipment. Installed new conduits<br>sized according to wire size<br>determined by over-current<br>protection. Installed all supports,<br>fittings and junction boxes as<br>required. The installation of<br>bonded expansion fittings was<br>required on all 3 runs. Install<br>cables and terminate as required<br>by code. | Name of Employer, Contact, Address,<br>Telephone Number<br>South Shore Electric<br>589 Ternes Avenue<br>Elyria, Ohio 44035<br>(440) 366-6289 | Project Time: From_To_<br>(MM/YY)<br>04/11 to 10/11 |
|  |  |   |
|  |  |   |
|  | Total Experience on This Page (In Months)  | : 7   |

Application for Interim Certification, Building Department Personnel

Farmer

Michael

First Name

| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed | Name of Employer, Contact, Address,<br>Telephone Number | Project Time: From_ To<br>(MM/YY) |
|--|---|-----------------------------------|
| Flavorseal - Avon, OH  | South Shore Electric                                    | 10/11 to 9/12                     |
| Spice Room Addition Foreman  | 589 Ternes Avenue                                       |                                   |
|  | Elyria, Ohio 44035                                      |                                   |
| Coordinate interior build out which  | (440) 366-6289  |                                   |
| included the addition of a new   |   |                                   |
| 480V Sub Panel from existing   |   |                                   |
| MDP, step-down transformer, and  |   |                                   |
| 120/208V 3 phase 4 wire sub  |   |                                   |
| panel for miscellaneous  |   |                                   |
| equipment drops. The new area  |   |                                   |
| was completed using freezer  |   |                                   |
| panels. All electric and fire alarm  |   |                                   |
| work was installed above this area   |   |                                   |
| In EMI and set screw fittings. All   |   |                                   |
| penetrations through the ceiling   |   |                                   |
| required the use of stainless steel  |   |                                   |
| conduit, coupling, cord grip   |   |                                   |
| twist look connectors and pluge  |   |                                   |
| that mot the feed industry   |   |                                   |
| requirements. All penetrations   |   |                                   |
| were fire caulked and scaled   |   |                                   |
| New 277V LED vapor-tight   |   |                                   |
| lighting was installed throughout  |   |                                   |
| the project  |   |                                   |
| Lalso coordinated the  |   |                                   |
| replacement of the existing  |   |                                   |
| 300KW generator with a 750 KW  |   |                                   |
| generator to provide enough  |   |                                   |
| power to support the entire  |   |                                   |
| building. We installed additional  |   |                                   |
| conduits and changed out the   |   |                                   |
| service entrance rated transfer  |   |                                   |
| switch to accommodate the new  |   |                                   |
| future service for this building. All  |   |                                   |
| conduits, junction boxes and   |   |                                   |
| fittings were installed to code and  |   |                                   |
| inspected.   |   |                                   |
|  |   |                                   |
|  | Total Experience on This Page (In Months):              | 12                                |

Farmer

Application for Interim Certification, Building Department Personnel

Michael

| Last Name   | First Name   | BBS Certification ID              |
|---|--|-----------------------------------|
| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed  | Name of Employer, Contact, Address,<br>Telephone Number                  | Project Time: From_ To<br>(MM/YY) |
| Director of Public Service<br>Plans for and directs the<br>engineering, construction,<br>inspection, and maintenance of<br>City streets, sidewalks, bridges,<br>water systems, buildings,<br>cemetery, and other municipal<br>infrastructures, facilities or<br>property. Attend meetings to<br>discuss issues and solve<br>problems. Inspect and approve all<br>facilities with in the right of way,<br>including traffic signals. Develop<br>and maintain effective working<br>relationships with other public<br>utilities. Understand, interpret, and<br>apply laws and regulations to<br>specific situations and<br>communicate clearly. | City of Avon<br>36080 Chester Road<br>Avon, Ohio 44011<br>(440) 937-7800 | 09.12 to present                  |
|   | I otal Experience on This Page (In Months):                              | 108                               |

Application for Interim Certification, Building Department Personnel

| Farmer  | Michael   |                               |
|---|---|-------------------------------|
| Last Name   | First Name  | BBS Certification ID          |
| List Each Construction Project <u>AND</u><br>Specific Type of Work Performed  | Name of Employer, Contact, Address,<br>Telephone Number                 | Project Time: From_ To(MM/YY) |
| NJATC Instructor<br>I was the 3rd year apprenticeship<br>instructor for nine years. Classes<br>were held after work on Tuesdays<br>and Thursday from October until<br>the beginning of April for 4 hours.<br>The 3rd year class consisted of<br>the fundamentals of electronics<br>and how they operate different<br>from AC , Article 250 Grounding<br>& Bonding, Transformers, Motors<br>Impedance calculations and<br>Ohms Law. This was a five year<br>apprenticeship program. I also<br>attended the week long training<br>program provided by our NJATC<br>in Nashville, Tennessee. School<br>requirements were 160 hours of<br>classroom instruction per year. | IBEW Local 129<br>6100 S Broadway<br>Lorain, OH 44053<br>(440) 233-7156 | 10/96 to 01/05                |

Total Experience on This Page (In Months):

9 months

Application for Interim Certification, Building Department Personnel

Farmer Last Name

First Name

Michael

**BBS Certification ID** 

Yes M No

🗌 Yes 🔳 No

□ Yes □ No

#### SECTION 8: PERSONAL HISTORY

1. Have you ever been convicted of any felony, or any crime involving moral turpitude?

If you answered "Yes" please explain below:

- 2. Have you served in the U.S. armed services? (If No, skip question 3)
- 3. If YES, were you discharged under honorable conditions?

If you answered "No" please explain below:

#### **SECTION 9: CERTIFICATION**

I certify the information contained in this application is true and complete, and I understand that providing false information may be grounds for not granting certification or for immediate termination of certification at any point in the future, if granted. I authorize the investigation of all statements contained herein and release all parties from all liability for any damage that may result from furnishing the same to Ohio Board of Building Standards. Falsification is a violation of section 2921.13 of the Ohio Revised Code and is punishable as a misdemeanor of the first degree.

Signature of Applicant: Much U.

Subscribed and duly sworn before me according to law, by the above named applicant this

of <u>Mumber</u> in the year 20\_2/ at \_\_\_\_\_\_, County of day 22 Notary Public: Rose Frances Sughman urain and State of Ohio



**Rose Frances Seighman** 

NOTARY PUBLIC STATE OF OHIO

My Commission Expires August 2, 2025

| of ANOUSY OF                          | 2019   | <b>CITY OF SANDUSKY, OHIO</b><br>Department of Community Development<br>Division of Building Inspection                |
|---------------------------------------|--|--|
| ADUNDED VIN                           | This license or registration she<br>and end                            | all be in force for the period beginning on January 02, 2019<br>ing on the last day of December 2019.                  |
| This license or re<br>City of Sandusl | gistration has been issued and sh<br>ky, Ohio. Failure to comply shall | nall be renewable in accordance with the Ordinances of the constitute a forteiture or suspension of this registration. |
| MICHAEL W FARME                       | R  | CT001651   |
| 3400 WILLIAMS CT                      |  | Registration Number  |
| AVON OH 44011                         |  | Trade  |
| No Ap<br>Daron H<br>Director of P     | ublic Works 01/0   | ractor shall lend his Registration to others.<br>2/2019 Chief Building Official  |

| City of Sandusky<br>Department of Community Development |                       |          |  |  |  |
|---|-----------------------|----------|--|--|--|
| Division of Building Inspection                         |                       |          |  |  |  |
| License/Re  | 2019<br>gistration #: | CT001651 |  |  |  |
| JOURNEYMAN ELECTRICIAN                                  |                       |          |  |  |  |
| Issued to:  | MICHAEL               | W FARMER |  |  |  |

Renewal notices are sent out as a courtesy at the end of each year.

# It is the license/registration holder's responsibility to renew their license at the end of each year.

If you have any changes to your name, address, phone or company, please notify the office listed below:

Division of Building Inspection 222 Meigs Street Sandusky, OH 44870 Office: 419-627-5940 E-Mail: dleslie@ci.sandusky.oh.us www.ci.sandusky.oh.us

| Fee Receipt License/Registration #: CT001651 | City of Sandusky<br>Department of Community Development<br>Division of Building Inspection |  |  |
|--|--|--|--|
| JOURNEYMAN                                   | Date Paid 01/02/2019   |  |  |
| Received from:                               | How Paid Check   |  |  |
| MICHAEL W FARMER                             | Ck # 1467  |  |  |
|  | Fee \$25.00  |  |  |
|  | Receipt # RN-0193272   |  |  |
|  | Account 110-4090-46411 Received by: DSL  |  |  |

Any changes in information must be submitted within 30 days to:

Bureau of Testing & Registration PO BOX 529 Reynoldsburg, Ohio 43068 614-752-7126 614-995-4206 (fax) webfmtr@com.state.oh.us

This license shall be carried on your person while performing the listed activities.

State of Ohio Department of Commerce Division of State Fire Marshal

FIRE PROTECTION LICENSE MICHAEL W FARMER

54.47.1207

Expiration Date: 01/02/2022

Mulw. F Signature

This card shall be on your person while performing listed activities.



Ohio Department of Commerce Division of State Fire Marshal Bureau of Testing & Registration 8895 E Main Street, PO Box 529 Reynoldsburg, Ohio 43068

MICHAEL W FARMER

#### **MICHAEL W FARMER**

is duly registered and is entitled to the practice in the State of Ohio. License categories are for Servicing, Testing, Repairing, and Installing. Fire Alarms / Detection

| The of the other states of the           |  |                |
|--|--|----------------|
| OSHA                                     | 600208279  |                |
| J.S. Department of<br>Occupational Safet | Labor<br>y and Health Administration   |                |
| Mi                                       | chael W. Farmer  |                |
| has successfully o<br>Fraining Course in | ompleted a 30-hour Occupational Sat  | ety and Health |
|  | Construction Safety & Health   |                |
| Joyce                                    | Sublena  | 11/28/07       |
| (Technor)                                | and the second | (Date)         |



### File Attachments for Item:

ER-1 Generators and the 2020 NEC (Matthews Electrical Services) All certifications except PI, NRIUI, RMI, and RIUI (4 hours) Staff Notes: ESIAC Recommendation:

Committee Recommendation:

#### **Course Description and Objectives**

Generators are a critical part of our lives. We depend on them to keep the lights on and for other important operations when the utility power goes down. However, improper design and use of generator systems can lead to disastrous and even fatal results.

The objective of this 4-hour course is to provide the end-user with the NEC and other requirements to install a safe and code-compliant generator installation.

This course will cover generator safety requirements, portable and standby generators, transfer switches, separately derived systems, grounding and bonding of generator systems and more.

As part of this course, the differences between Emergency Systems, Legally Required Standby Systems and Optional Standby Systems will be covered.

A design example of a home standby generator installation will be included to reinforce the main topics covered.

# **Generator Course Outline**

- 1. Generator Code References
  - a. Article 100 Definitions
    - i. Separately Derived System
    - ii. Switch, Transfer
  - b. Article 445 Generators
  - c. Article 250
    - i. Section 250.30 information note 1
    - ii. Section 250.34 (A) Portable Generators
    - iii. Section 250.34(B) Vehicle-Mounted and Trailer-Mounted Generators
    - iv. Section 250.34(C) Grounded Conductor Bonding
    - v. Section 250.35 Permanently Installed Generators
  - d. Article 685 Interconnected Electrical Systems
  - e. Article 700 Emergency Systems
  - f. Article 701 Legally Required Standby Systems
  - g. Article 702 Optional Standby Systems
  - h. Article 705 Interconnection Electrical Power Production
  - i. Article 708 Critical Operations Power Systems (COPS)

Other references:

- a. NEMA Motors and Generators MG-1
- b. UL 2200 Standard for Stationary Engine Generator Assemblies
- c. NFPA 37 Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines
- 2. Generator Safety
  - a. Proper location
  - b. Fuel concerns
  - c. Shock, arc flash, GFCIs etc.
- 3. Types of Generators and Generator systems
- 4. Grounding and Bonding of Generators
  - a. Separately Derived Systems
- 5. Exercise: Sizing, Specifying and Designing a Code-Compliant Home Standby Generation Installation
- 6. Wrap-up
  - a. Questions and Answers
  - b. Code credit applicability and certificates



## CRITERIA FOR SUBMITTING CONTINUING EDUCATION COURSES FOR BOARD OF BUILDING STANDARDS CERTIFICATIONS

The Ohio Board of Building Standards approves Continuing Education Courses for building department personnel. The courses may be used for the attainment of goals that are connected with technical and professional development as they relate to enforcing and interpreting the Ohio State Building Codes. Board approval is granted only on course instruction pertaining to OBC, OMC, OPC, and RCO requirements and such other content areas directly related to the responsibilities of the certification for which credit is being requested.

**Instructors**: Anyone or any organization promoting an approved course, is required to make full and accurate disclosure regarding course title, course approval number, number of credit hours, certifications for which the BBS has approved the class, and fees in promotion materials and advertising. *The Board does not grant retroactive approval. It is recommended that courses be submitted for approval well in advance of any scheduling of classes and advertising.* Advertising shall not disclose improper approval information to the public.

**Course sponsors/co-sponsors:** provide participants a certificate of completion containing the following information: name of participant, title of approved courses, BBS approval #, BBS approved certifications, date of the continuing education program, number of approved credit hours awarded and signature of authorized sponsor or instructor.

Anyone or any organization administering an approved course shall provide the Board with advanced written information on scheduling of the course(s) (date and place) and provide to the Board a legible list of participants who completed the course with the name of course, date, and location.

**Participants**: Must attend the complete course as presented by the instructor to receive credit hours approved by the Board. No partial credit shall be given to any participant who failed to complete the entire course as approved. The sponsor/co-sponsor or instructor shall formulate a method to verify the individual's attendance and completion of the course.

**Board approval**: Remains in effect through the calendar year of approval. The course may be renewed administratively by sponsor application in subsequent years so long as it references current codes and standards Upon the Board's adoption of a new edition of the codes, course sponsors must update their course and submit to the Board for approval. The Board does not grant retroactive approval for courses presented prior to approval date.

**Facility/training area**: Shall be capable of comfortably and safely seating at least the number of attendees with writing surfaces for each attendee; accessible to/and usable for people with disabilities; sized and provided with audio/visual equipment adequate so that each attendee can see the instructor(s) and overhead screen and hear the content of the training programs; illuminated for writing and that the content on an overhead screen can be seen easily by all attendees; non-smoking in the training room; sound controlled so that outside noise will not interfere with the training.

614 | 644 2613 Fax 614 | 644 3147 TTY/TDD 800 | 750 0750 www.com.ohio.gov

|   |   | <b>Board of Building Standards</b><br>6606 Tussing Road, P.O. Box 4009<br>Reynoldsburg, Ohio 43068-9009                |              |  |
|---|---|--|--------------|--|
| APPLI   | FOR   | (614) 644-2613 Fax: (614) 644-3147<br>dic.bbs@com.state.oh.us<br>www.com.state.oh.us/dic/dicbbs.htm                    |              |  |
| Continuing Education<br>Course Approval   |   | COURSE SUBMITTER:  |              |  |
|   |   | Course Submitter: Henry Matthews   |              |  |
| Continuing education programs approved for<br>education credit by the Ohio Board of<br>Building Standards may be used for |   | Organization: Matthews Electrical Services   |              |  |
|   |   | Address: 1203 McKinley Place   |              |  |
| compliance with cer   | tification requirements   | City: Fostoria State: Ohio Zip: 44830  |              |  |
| inspection responsibili   | ties. The credit is to be   | E-Mail: hpmatthews66@att.net   |              |  |
| used to renew the cert<br>Ohio Board of Buildin   | tifications issued by the standards pursuant to   | Telephone: <u>419-575-3488</u> Fax:  |              |  |
| section 3781.10(E) ORC.   |   | Course Sponsor:  |              |  |
| COURSE INFORMATION:   |   |  |              |  |
| Course Title: Generat   | ors and the NEC - Webi  | nar  | _            |  |
| New Cour  | rse Submittal: 🔲 Upo  | late Course: Prior Approval Number:  | _            |  |
| Purpose and Objectiv  | ve: This course will review th  | ne contents and requirements of article 445 in the NEC - Generators. It will cove                                      | r            |  |
| topics such as definition   | s, grounding and bonding of g   | enerators, overcurrent protection, GFCI requirements, generator safety, paralleling o                                  | †<br>        |  |
| and how to ground   | and bond the system as  | conding. The role of the transfer switch will also be discussed  | <u>~</u>     |  |
| and now to ground   |   |  | -            |  |
| Number of Instruction   | al Contact Hours that can   | be obtained upon completion: 4   | -            |  |
| If Multi Sossion Num  | har of Instructional Canta  | at Hours Dar Sossian.  | _            |  |
| n wun-session, wun  |   |  |              |  |
| Program Applicable fo   | or the Following Participa  | nts:   |              |  |
| Building Official   | Master Plans Examiner   | Building Inspector E Fire Protection Inspector E Mechanical Inspector  |              |  |
|   | Building Plans Exam.  | Plumbing Inspector   |              |  |
| -   | Plumbing Plans Exam.  | Non-Res IU Inspector   |              |  |
|   | Electrical Plans Exam.  |  |              |  |
|   | Fire Protect Plans Exam.  |  |              |  |
| Res Building Official   | Res Plans Examiner  | Res Building Inspector Res Mechanical Inspector Res III Inspector  |              |  |
|   |   | Kes bunding inspector inspector inspector inspector  |              |  |
| Electrical Safety Inspector   | s X   | $\mathbf{D}$ ( ) $\mathbf{C}$  |              |  |
| Location of ESI Course: w   |   | www.zoom.com Date(s) of ESI Course(s): 12-11-21 and others   |              |  |
| SUBMITTAL CHECKLIST:  | Make Sure all of the Following I  | nformation is <b>Submitted</b> :   | Check<br>Off |  |
| Course Submitter:   | Name of contact person and their certification numbers, organization, address, fax, phone |  |              |  |
| Course Titler   | Organization sponsoring or re   | equesting the program (if any)   | V            |  |
| Course 110e:  | Ivame of course (related to co  | uncen will improve competency of certification(s) listed   | ^<br>X       |  |
| Contact Hours   | Describe purpose and how course will improve competency of certification(s) listed        |  |              |  |
| Participants:   | Check off each certification f  | For which credit is requested (for which course relates to certification)  | X            |  |
| Content of Program:   | Include collated agenda, time   | Include collated agenda, time schedule, course outline: list specific sections of code, references, and topics covered |              |  |
| Course Materials:   | Collated workbooks, handout   | ts, hard copy or electronic versions of program is available   | Х            |  |
| Instructor(s) Info.:  | Resume of professional/educ   | ational qualifications & teaching/training experience/BBS certifications   | Х            |  |
| Test Materials:   |   | National Electrical Code   | Х            |  |
| Completed Application   |   |  | X            |  |

NOTE: The Board does NOT grant retroactive approval for courses presented prior to approval date.

BBS 8102














### Course Description and Objectives

- Generators are a critical part of our lives. We depend on them to keep the lights on and for other important operations when the utility power goes down. However, improper design and use of generator systems can lead to disastrous and even fatal results.
- The objective of this 4-hour course is to provide the end-user with the NEC and other requirements to install a safe and code-compliant generator installation.
- This course will cover generator safety requirements, portable and standby generators, transfer switches, separately derived systems, grounding and bonding of generator systems and more.
- A design example of a home standby generator installation will be included to reinforce the main topics covered



### Agenda

- Generator types
  - PortableStandby
  - Vehicle mounted
- Definitions
  - Separately derived system
- Applicable standards and codes
- Generator Safety
- NEC applicable articles:
- Overcurrent and overvoltage protection
- Conductor sizing
- Grounding and bonding
- Transfer switches
- Other considerations
  - Layout, placement, ventilationGenerators in parallel
- Generator
- Maintenance
- Residential design and installation example
  - Load estimate and generator sizing
  - Surge loads

9













# Definitions NEC 700.2 <u>Emergency systems</u> – Emergency Power shall automatically supply power within the required application (illumination, exit signs, smoke ventilation systems, fire alarms, elevators, fire pumps, PA systems, critical industrial processes etc.) in no less than 10 seconds Legally Required Systems – required to automatically supply power to selected loads, other than those classified as emergency, during an event of loss of normal power. Power shall be restoring in no less than 60 seconds Examples: heating and refrigeration, communications systems, sewage disposal, smoke ventilation systems and industrial processes that could create hazards or interfere with fire rescue operations if normal power was interrupted.

### Definitions

- NEC 700.2
  - <u>Emergency systems</u>
  - Those systems legally required and classed as emergency by the municipal, state, federal, or other codes, or by any governmental agency having jurisdiction.
  - These systems are intended to automatically supply illumination, power, or both, to designated areas and equipment in the event of failure of the normal supply or in the event of accident to elements of a system intended to supply, distribute, and control power and illumination essential for safety to human life.

### Definitions (Emergency Systems - continued)

- NEC 700.2
  - Informational note:
  - Emergency systems are generally installed in places of assembly where artificial illumination is required for safe exiting and for panic control in buildings subject to occupancy by large numbers of persons, such as hotels, theaters, sports arenas, health care facilities, and similar institutions.
  - Emergency systems may also provide power for such functions as ventilation where essential to maintain life, fire detection and alarm systems, elevators, fire pumps, public safety communications systems, industrial processes where current interruption would produce serious life safety or health hazards, and similar functions.

### Definitions

• IBC:

- Emergency Power A power system that automatically provides secondary power within 10 seconds after primary power is lost
- Standby Power A power system that supplies secondary power within 60 seconds once primary power is lost

19

### Definitions

- NEC 701.2
  - Legally Required Standby Systems:
  - Those systems required and so classed as legally required standby systems by municipal, state, federal, or other codes or by any governmental agency having jurisdiction.
  - These systems are intended to automatically supply power to the selected loads (other than those classed as emergency systems) in the event of failure of the normal source.
  - Informational note: Legally required standby systems are typically installed to serve loads, such as heating and refrigeration systems, sewage disposal, lighting systems, and industrial processes, that when stopped during any interruption of the normal electrical supply, could create hazards or hamper rescue or fire-fighting operations.

### Definitions

• NEC 702.2

### • Optional Standby Systems:

- Those systems intended to supply power to public or private facilities or property where life safety does not depend on the performance of the system.
- These systems are intended to supply on-site generated or stored power to selected loads either automatically or manually.
- Informational note: Optional standby systems are typically installed to provide an alternate source of electric power for such facilities as industrial and commercial buildings, farms, and residences and to serve loads such as heating and refrigeration systems, data processing and communication systems, industrial processes that, when stopped during any power outage, could cause discomfort, serious interruption of the process, damage to the product or process, or the like.



# <section-header> Second State Second State Overloading Engine speed drops and voltage and frequency become unstable Causes amperage to surge Generator trips offline or shuts down to prevent damage to itself Underloading Wet stacking: unburned fuel escapes into the exhaust side of the engine Engine performance decreases and damage can occur Ideal: 70-85% of the machine's rated capacity (Generac)

23

### Types of Loads

- Continuous loads
- Surge loads: motors, pumps, compressors etc.
- Intermittent loads
- Drills, power tools, blenders

## Types of Loads Resistive Inductive Motors Pumps Refrigerators Furnace Non-linear loads: create harmonics that can damage generators May require harmonic filters or upsizing generator Variable Frequency Drives (VFDs) UPS

• Switching power supplies





### 445.11 Marking

- Each generator shall be provided with a nameplate giving the
  - manufacturer's name
  - the rated frequency,
  - the number of phases if ac,
  - the rating in kilowatts or kilovolt-amperes,
  - the power factor,
  - the normal volts and amperes corresponding to the rating,
  - · and the rated ambient temperature

### 445.11 Marking

- Marking shall be provided by the manufacturer to indicate whether or not the generator neutral is bonded to its frame.
- Where the bonding is modified in the field, additional marking shall be required to indicate whether the neutral is bonded to the frame.

29

### 445.12 Overcurrent Protection

• (A) Constant Voltage Generators shall be protected from overload by inherent design, circuit breakers, fuses, protective relays, or other identified overcurrent protective means suitable for the conditions of use.

### 445.13 Ampacity of Conductors (A) General: The ampacity of the conductors from the generato

- (A) General: The ampacity of the conductors from the generator output terminals to the first distribution device(s) containing overcurrent protection shall not be les than 115 percent of the nameplate current rating of the generator.
- It shall be permitted to size the neutral conductors in accordance with 220.61.
- Conductors that must carry ground fault currents shall not be smaller than the minimum required size of the largest conductor.
  - Henry's note: This is the equipment grounding conductor (EGC) which is usually sized per NEC table 250.122

Exception: Where the design and operation of the generator prevent overloading, the ampacity of the conductors shall not be less than 100 percent of the nameplate current rating of the generator.

31

IEEE 142 – 2007 Grounding of Industrial and Commercial Power Systems

































### Other Labeling Requirements

For Portable Generators

- 702.7(C) Signs for Generator Power Inlet
- Where a power inlet is used for a temporary connection to a portable generator, a warning sign shall be placed near the inlet to indicate the type of derived system that the system is capable of based on the wiring of the transfer equipment. The sign shall display one of the following warnings:











### Small Portable Generator Grounding/Bonding NEC 250.34(A)

- The frame of a portable generator shall not be required to be connected to a grounding electrode as defined in 250.52 for a system supplied by the generator under both of the following conditions
- 1. The generator supplies only equipment mounted on the generator, cord-and-plug-connected equipment through receptacles mounted on the generator, or both
- 2. The normally non-current-carrying metal parts of equipment and the equipment grounding conductor terminals of the receptacles are connected to the generator frame.

55





Portable Generator with fault in equipment and someone touches equipment frame Generator GFCI senses leakage current through person and trips! Fault current through EGC may not be enough to trip normal (non-GFCI) breaker Heater Extension cord GFC G Wheels isolated From ground Grounded but not Note: Generator does not rely on grounding (ground rod) to Effectively grounded prevent shock. This is done through bonding!





### Sizing Example Standby generator 16 kW Continuous Power 120/240V split phase output Transfer switch has solid neutral connection for generator No neutral switch Not a separately derived system



# Calculations Wire type: THWN Conductor Sizing: Generator Full Load Amps (FLA): 58.3 Multiply FLA x 1.15 per 445.13: 58.3 x 1.15 = 67 A Use Table 310.16 using 75 deg C column # 6 good for 65 amps # 4 good for 85 amps Check: Will 60 amp circuit breaker on the generator protect the #4 wire? Yes!

63

## Calculations Overcurrent Protection: 60 Amp circuit breaker included in generator 0k per 445.12(A) "Constant-voltage generators, except ac generator exciters, shall be protected from overload by inherent design, circuit breakers, fuses, protective relays, or other identified overcurrent protective means suitable for the conditions of use."





 This emergency shutdown device was deemed necessary for fire service and other first responders to secure on-site power sources during emergencies such as a house fire.

FOR INFORMATIONAL PURPOSES ONLY. NOT CURRENT CODE IN OHIO



### Design Example

- House prone to power outages in summer due to storms
- Summer temps can exceed 90 degrees F on most days
- Duration of outages usually last from 2 to 24 hours
- Homeowner only wants to back up certain loads, not whole house
- Electrical service is 120/240V, 200 amps
- Backup to loads shall be automatic
- Not all appliances and lights will be on during outage, only those necessary
- Homeowner does not plan to cook anything during outage
- Homeowner does not plan to do any clothes washing/drying during outage
- Homeowner wants air conditioner to run during outages
- Natural gas is supplied to the house for heating

| Appliance                      | Watts            | Appliance                      | Watts | Appliance             | Watts |
|--------------------------------|------------------|--------------------------------|-------|-----------------------|-------|
| Kitchen                        |                  | Living Room                    |       | Tools                 |       |
| Blender                        | 500              | Bluray Player                  | 15    | Band Saw – 14″        | 1100  |
| Can Opener                     | 150              | Cable Box                      | 35    | Belt Sander – 3″      | 1000  |
| Coffee Machine                 | 1000             | DVD Player                     | 15    | Chain Saw – 12″       | 1100  |
| Dishwasher                     | 1200-1500        | TV – LCD                       | 150   | Circular Saw – 7-1/4″ | 900   |
| Espresso Machine               | 800              | TV – Plasma                    | 200   | Circular Saw 8-1/4"   | 1400  |
| Freezer – Upright – 15 cu. ft. | 1240<br>Wh/Day** | Satellite Dish                 | 25    | Disc Sander – 9″      | 1200  |
| Freezer – Chest – 15 cu. ft.   | 1080<br>Wh/Day** | Stereo Receiver                | 450   | Drill – 1/4"          | 250   |
| Fridge – 20 cu. ft. (AC)       | 1411<br>Wh/day** | Video Game Console             | 150   | Drill – 1/2"          | 750   |
| Fridge -16 cu. ft. (AC)        | 1200<br>Wh/day** | Lights                         |       | Drill – 1″            | 1000  |
| Garbage Disposal               | 450              | CFL Bulb – 40 Watt Equivalent  | 11    | Hedge Trimmer         | 450   |
| Kettle – Electric              | 1200             | CFL Bulb – 60 Watt Equivalent  | 18    | Weed Eater            | 500   |
| Microwave                      | 1000             | CFL Bulb – 75 Watt Equivalent  | 20    | Misc.                 |       |
| Oven – Electric                | 1200             | CFL Bulb – 100 Watt Equivalent | 30    | Clock Radio           | 7     |

| Appliance                                  | Watts | Appliance                      | Watts | Appliance  | Watts                  |
|--|-------|--------------------------------|-------|--|------------------------|
| Toaster                                    | 850   | Compact Fluorescent 20 Watt    | 22    | Curling Iron   | 150                    |
| Toaster Oven                               | 1200  | Compact Fluorescent 25 Watt    | 28    | Dehumidifier   | 280                    |
| Stand Mixer                                | 300   | Halogen – 40 Watt              | 40    | Electric Shaver  | 15                     |
| Heating/Cooling                            |       | Incandescent 50 Watt           | 50    | Electric Blanket   | 200                    |
| Box Fan                                    | 200   | Incandescent 100 Watt          | 100   | Hair Dryer   | 1500                   |
| Ceiling Fan                                | 120   | LED Bulb – 40 Watt Equivalent  | 10    | Humidifier   | 200                    |
| Central Air Conditioner – 24,000<br>BTU NA | 3800  | LED Bulb – 60 Watt Equivalent  | 13    | Radiotelephone – Receive   | 5                      |
| Central Air Conditioner – 10,000<br>BTU NA | 3250  | LED Bulb – 75 watt equivalent  | 18    | Radiotelephone – Transmit  | 75                     |
| Furnace Fan Blower                         | 800   | LED Bulb – 100 Watt Equivalent | 23    | Sewing Machine   | 100                    |
| Space Heater NA                            | 1500  | Office                         |       | Vacuum   | 1000                   |
| Tankless Water Heater – Electric           | 18000 | Desktop Computer (Standard)    | 200   | Note: TVs, Computers, and other dev  | vices left             |
| Water Heater – Electric                    | 4500  | Desktop Computer (Gaming)      | 500   | plugged in but not turned on still drav  | w power.               |
| Window Air Conditioner 10,000<br>BTU NA    | 900   | Laptop                         | 100   | **To estimate the number of hours th<br>refrigerator actually operates at its ma   | at a<br>aximum         |
| Window Air Conditioner 12,000<br>BTU NA    | 3250  | LCD Monitor                    | 100   | wattage, divide the total time the refr<br>plugged in by three. Refrigerators, all | igerator is<br>though  |
| Well Pump – 1/3 1HP                        | 750   | Modem                          | 7     | turned "on" all the time, actually cycle<br>off as needed to maintain interior tem | e on and<br>peratures. |

| Appliance                | Watts | Appliance              | Watts |
|--------------------------|-------|------------------------|-------|
| Laundry                  |       | Paper Shredder         | 150   |
| Clothes Dryer – Electric | 3000  | Printer                | 100   |
| Clothes Dryer – Gas      | 1800  | Router                 | 7     |
| Clothes Washer           | 800   | Smart Phone – Recharge | 6     |
| Iron                     | 1200  | Tablet – Recharge      | 8     |
|                          |       |                        |       |



| FEATURES SPEC             | S REQUIRED CO   | OMPONENTS                                | ACCESSORIES   |
|---------------------------|-----------------|--|---|
| Model                     |                 | 14RCAL                                   |   |
| Rated kW LP               |                 | 14 kW                                    |   |
| Rated kW NG               |                 | 12 kW                                    |   |
| Amps LP                   |                 | 58 amps                                  | -   |
| Amps NG                   |                 | 50 amps                                  |   |
| Peak Motor Starting kVA   | 240 V           | 33 kVa                                   |   |
| Alternator Note           |                 | All information sh<br>with the largest a | hown is for 1 Phase 60 Hz generator<br>alternator option available. |
| Displacement              |                 | 725 cm³ (44 cu. i                        | in.)  |
| Horsepower                |                 | NG 20.5 HP, LP 2                         | 23.6 HP   |
| Enclosure Material        |                 | Aluminum                                 |   |
| Sound Output During Wee   | kly Exercise    | 63 dB(A)                                 |   |
| Sound Output During Full- | speed Operation | 67 dB(A)                                 |   |
| Response Time             |                 | 10 seconds                               |   |
| Warranty                  |                 | Premium five-yea                         | ar limited warranty   |
| Country of Origin         |                 | US                                       |   |
| Certifications/Listings   |                 | UL 2200,CSA,EP                           | PA,cUL  |
| Automatic Transfer Switch | Included        | Included                                 |   |
| Remote Monitoring Availa  | ble             | Included                                 |   |
| Off Grid / Utility Backup |                 | Off Grid, Utility Ba                     | ackup   |

### Henry Peter Matthews, PE, CPE, CESCP, PVA

Home Address 1203 McKinley Place Fostoria, Ohio 44830 Email: hpmatthews@matthewselectrical.net Home Phone: 419-701-7707 Cell Phone: 419-575-3488

### Work Address

Marathon Petroleum Company 539 South Main Street Findlay, Ohio 45840 Email: hpmatthews@marathonpetroleum.com Office phone: 419-421-3423 Cell phone: 419-957-2110

| Work Experience |  |                       |
|-----------------|--|-----------------------|
|                 | <ul> <li>Marathon Petroleum Company, LP; Findlay, Ohio</li> <li>Advanced Senior Engineer/Electrical Specialist</li> <li>Electrical Engineering Supervisor – Terminal Engineering</li> <li>Project Engineer – Major Projects</li> <li>Electrical Designer – Retail Division</li> </ul>                      | June 2006 – Present   |
|                 | <ul> <li>Cooper Standard Automotive, Bowling Green, Ohio</li> <li>Plant Engineering Manager</li> <li>Plant Electrical Engineer</li> </ul>  | July 1993 – June 2006 |
|                 | <ul> <li>Toledo Engineering Company (consultant); Toledo, Ohio</li> <li>Electrical Drafter</li> </ul>  | June 1989 – July 1993 |
| Education       |  |                       |
|                 | <b>Bowling Green State University</b> ; Bowling Green, Ohio<br>Masters of Business Administration  | Aug 2003              |
|                 | Pennsylvania State University; University Park, PA<br>BS Electrical Engineering  | Dec 1989              |
|                 | <b>Solar Energy International</b> , Paonia, Colorado<br>Solar PV Training  | Sept 2021             |
|                 | <b>Owens Community College; Findlay, Ohio</b><br>Certificate: Introductory Welding   | April 2017            |
|                 | Penn Foster Career School<br>Certificate: Plumbing   | July 2010             |
|                 | Penn Foster Career School<br>Certificate: Electrician  | October 2004          |
| Certifications  | Professional Engineer (PE): OH, MI, IN, KY, IL, WI<br>Photovoltaic Associate (PVA) by NABCEP<br>Certified Electrical Safety Compliance Professional (CESCP), NFP<br>Certified Plant Engineer (CPE): Association for Facility Engineers<br>Building Operator Certification (BOC): Northwest Energy Efficier | A<br>ncy Council      |

| Licenses              | Ohio Electrical Contractor, Ohio Department of Commerce, License # 46972<br>Ohio Training Agency, Ohio Construction Industry Licensing Board, Agency #48714<br>Ohio Training Agency, Ohio Board of Building Standards   |  |  |  |  |  |
|-----------------------|---|--|--|--|--|--|
| Special Training      | <ul> <li>Solar Energy International (SEI), Paonia, Colorado</li> <li>Solar Electric and Design and Installation Course, April 2021, 60 hours</li> <li>PV Systems Fundamentals (Battery-Based), June 2021, 40 hours</li> <li>Advanced PV System Design and the NEC, June-July 2021, 60 hours</li> <li>Comparing Battery Technologies, July 2021, 10 hours</li> <li>Tools and Techniques for Operations and Maintenance of PV Systems, 9/21, 40 HR</li> </ul> |  |  |  |  |  |
| Affiliations          | Institute of Electrical and Electronics Engineers (IEEE) – Senior Member<br>International Association of Electrical Inspectors (IAEI)<br>NFPA Section Member for Architects, Engineers and Building Officials<br>Illumination Engineering Society of North America (IESNA)<br>API RP 545 former Co-Chair, American Petroleum Institute, Lightning Protection for<br>Above Ground Storage Tanks (2017- 2018)   |  |  |  |  |  |
| Business<br>Ownership | Matthews Electrical Services, Owner<br>Designer Cuts Hair Salon, LLC; Co-owner  |  |  |  |  |  |

### Biography

Henry has worked in the electrical, power, electronics, instrumentation, controls and communication fields for over 30 years. He earned his Bachelor of Science degree in Electrical Engineering from Penn State University in 1989. Henry worked as a consultant for Toledo Engineering Company in Toledo, Ohio as a drafter and field technician.

In 1993 he started working for Cooper Standard Automotive Company in Bowling Green, Ohio in 1993 as a Plant Electrical Engineer. He was then promoted to Plant Engineering Manager in 2000. During this time, he earned his Professional Engineering License in Ohio.

In 2003, Henry earned his MBA at Bowling Green State University.

In 2006, Henry joined Marathon Petroleum Company in Findlay, Ohio. He then went on to obtain his Professional Engineers license in Electrical Engineering for Michigan, Indiana, Illinois, West Virginia, Kentucky, Minnesota and Wisconsin. During his tenure at Marathon, Henry has had several roles including Electrical Design Engineer, Project Engineer and Electrical Supervisor. He is currently an Advanced Senior Engineer where he writes electrical standards for the company and conducts a community of practice for all the company's electrical engineers and safety professionals.
During his time at Cooper Standard Automotive and Marathon Petroleum, Henry developed a passion for teaching, learning and applying Electrical Construction Codes. At Cooper, he trained the entire non-electrical maintenance staff to perform basic electrical tasks.

At Marathon, Henry works with the Learning and Development Department to conduct multiple training sessions for new hires and seasoned engineers on various topics including Electrical Safety, Grounding and Bonding, Hazardous Area Location, Electrical Inspection, Motors, Lightning protection Static Electricity Mitigation, Reading and Understanding Electrical Diagrams, Programmable Logic Controllers and more.

Henry also works very closely with the Talent Acquisition Teams and visits numerous college campuses to deliver presentations on Engineering, Career Development, Networking and other topics.

Henry recently served as the Co-chair of the API Recommended Practice 545 Task Group for Lightning Mitigation for Above Ground Storage Tanks. In this role, he works with engineers, scientists and manufacturers from all over the world to evaluate the impacts of lightning and static electricity on metal above ground storage tanks.

His passion for teaching and Electrical Safety has motivated him to earn the Certified Electrical Safety Compliance Professional Certification (CESCP) from NFPA. He also regularly attends numerous electrical and safety conferences and training sessions conducted by NFPA, IEEE, API.

Previously, Henry was the President of the Fostoria, Ohio area Toastmasters team.

Henry is also a member of the International Association of Electrical Inspectors.

Henry also owns two small businesses:

**Matthews Electrical Services** - that performs mainly limited residential and small commercial electrical services and conducts training for licensed electricians in the state of Ohio.

Designer Cuts Hair Salon, LLC – Henry co-owns the beauty salon with his wife.

#### File Attachments for Item:

ER-2 Grounding and Bonding Part 2: Beyond the Basics (Matthews Electrical Services) BO, MPE, EPE, FPPE, BI, ESI, RBO, RPE, RBI (4 hours) Staff Notes: ESIAC Recommendation:

Committee Recommendation:

#### Grounding and Bonding Part II Webinar – Beyond the Basics

#### **Course Outline**

- 1. Objective: To cover more advanced Grounding and Bonding applications and relating them to applicable NEC grounding and bonding requirements.
- 2. Structure
  - a. Duration: 4 hour
  - b. Format
    - i. Webinar
      - 1. Register at <u>www.matthewselectrical.net</u>
      - 2. Webinar conducted at <u>www.zoom.com</u>
  - c. Resources
    - i. 2020 National Electrical Code
      - 1. Article 250 Grounding and Bonding
      - 2. Article 445 Generators
      - 3. Article 690 Solar Photovoltaic Systems
      - 4. Other applicable NEC sections
    - ii. 2021 NFPA 70E Electrical Safety in the Workplace
    - iii. NFPA 77
    - iv. NFPA 780
    - v. IEEE 80 and IEEE 142
    - vi. PowerPoint Slides Developed by Matthews Electrical Services
    - vii. Solar Energy International material
    - viii. IAEI.org website and publications including Soares Book on Grounding and Bonding
    - ix. NFPA website
    - x. Electrical Safety Foundation International website and publications
    - xi. Various equipment manufacturers published material
- 3. Curriculum: Grounding and Bonding
  - a. Review of Grounding and Bonding basic concepts
  - b. Proper grounding and bonding for personnel safety and equipment reliability
  - c. Review of GFCI and GFPE operating principles
  - d. System grounding: Utility vs. Separately Derived Systems
  - e. Preventing objectionable current flow
  - f. Resistance Grounding Systems
  - g. Grounding and Bonding of Remote Buildings
  - h. Grounding and Bonding of Generator systems and the role of the transfer switch
  - i. Grounding and Bonding of Solar PV systems
  - j. Lightning protection basics
  - k. Static Electricity Mitigation



#### CRITERIA FOR SUBMITTING CONTINUING EDUCATION COURSES FOR BOARD OF BUILDING STANDARDS CERTIFICATIONS

The Ohio Board of Building Standards approves Continuing Education Courses for building department personnel. The courses may be used for the attainment of goals that are connected with technical and professional development as they relate to enforcing and interpreting the Ohio State Building Codes. Board approval is granted only on course instruction pertaining to OBC, OMC, OPC, and RCO requirements and such other content areas directly related to the responsibilities of the certification for which credit is being requested.

**Instructors**: Anyone or any organization promoting an approved course, is required to make full and accurate disclosure regarding course title, course approval number, number of credit hours, certifications for which the BBS has approved the class, and fees in promotion materials and advertising. *The Board does not grant retroactive approval. It is recommended that courses be submitted for approval well in advance of any scheduling of classes and advertising.* Advertising shall not disclose improper approval information to the public.

**Course sponsors/co-sponsors:** provide participants a certificate of completion containing the following information: name of participant, title of approved courses, BBS approval #, BBS approved certifications, date of the continuing education program, number of approved credit hours awarded and signature of authorized sponsor or instructor.

Anyone or any organization administering an approved course shall provide the Board with advanced written information on scheduling of the course(s) (date and place) and provide to the Board a legible list of participants who completed the course with the name of course, date, and location.

**Participants**: Must attend the complete course as presented by the instructor to receive credit hours approved by the Board. No partial credit shall be given to any participant who failed to complete the entire course as approved. The sponsor/co-sponsor or instructor shall formulate a method to verify the individual's attendance and completion of the course.

**Board approval**: Remains in effect through the calendar year of approval. The course may be renewed administratively by sponsor application in subsequent years so long as it references current codes and standards Upon the Board's adoption of a new edition of the codes, course sponsors must update their course and submit to the Board for approval. The Board does not grant retroactive approval for courses presented prior to approval date.

**Facility/training area**: Shall be capable of comfortably and safely seating at least the number of attendees with writing surfaces for each attendee; accessible to/and usable for people with disabilities; sized and provided with audio/visual equipment adequate so that each attendee can see the instructor(s) and overhead screen and hear the content of the training programs; illuminated for writing and that the content on an overhead screen can be seen easily by all attendees; non-smoking in the training room; sound controlled so that outside noise will not interfere with the training.

614 | 644 2613 Fax 614 | 644 3147 TTY/TDD 800 | 750 0750 www.com.ohio.gov

|   | CATION   | <b>Board of Building Standards</b><br>6606 Tussing Road, P.O. Box 4009<br>Revnoldsburg. Ohio 43068-9009 |           |
|---|--|---|-----------|
| FOR   |  | (614) 644-2613 Fax: (614) 644-3147<br>dic.bbs@com.state.oh.us<br>www.com.state.oh.us                    |           |
| Continuing Education<br>Course Approval   |  | COURSE SUBMITTER:   |           |
|   |  | Course Submitter: Henry Matthews  |           |
| Continuing education programs approved for<br>education credit by the Ohio Board of<br>Building Standards may be used for<br>compliance with certification requirements<br>related to code enforcement, plan review, and<br>inspection responsibilities. The credit is to be<br>used to renew the certifications issued by the<br>Ohio Board of Building Standards pursuant to<br>section 3781.10(E) ORC. |  | Organization: Matthews Electrical Services  |           |
|   |  | Address: 1203 McKinley Place  |           |
|   |  | City: Fostoria State: Ohio Zip: 44830   |           |
|   |  | E-Mail: hpmatthews66@att.net  |           |
|   |  | Telephone:419-575-3488Fax:  |           |
|   |  | Course Sponsor:   |           |
| COURSE INFORMATION:   |  |   |           |
| Course Title. Ground  | ing and Bonding Part II V  | Vebinar - Beyond the Basics   |           |
| New Course Submittal: Update Course: Prior Approval Number:   |  |   |           |
| Purpose and Objective: This course will expand upon the basic grounding and bonding principles and requirements covered in Grounding and Bonding (Part 1).  |  |   |           |
| This course will cover more in-depth grounding and bonding topics such as system grounding, resistance grounding, separately derived systems,   |  |   |           |
| grounding and bonding of generator systems, Solar PV systems and remote buildings. We will also discuss how grounding and bonding   |  |   |           |
| helps mitigate static electricity and is a key component of lightning protection systems.   |  |   |           |
|   |  |   |           |
| Number of Instructional Contact Hours that can be obtained upon completion: 4   |  |   |           |
| If Multi-Session, Number of Instructional Contact Hours Per Session:  |  |   |           |
| Program Applicable f  | or the Following Participa   | nts:  |           |
| Building Official   | Master Plans Examiner  | Building Inspector Fire Protection Inspector Mechanical Inspector                                       |           |
|   | Building Plans Exam  | Plumbing Inspector  | H         |
|   | Plumbing Plans Exam  | Non Des III Inspector   | $\square$ |
|   | Electrical Plans Exam.   | Non-Res TO hispector  |           |
| Mechanical Plans Exam   |  |   |           |
|   | Fire Protect. Plans Exam.  |   |           |
| Res Building Official   | Res Plans Examiner   | Res Building Inspector 🔲 Res Mechanical Inspector 🗌 Res IU Inspector                                    |           |
| Electrical Safety Inspector   | rs X   |   |           |
| Location of ESI Course: V   | www.matthewselectrical.net via   | www.zoom.com Date(s) of ESI Course(s): 12-18-21   |           |
| SUDMITTAL CUECKLIST.  | Make Same all afthe Fallening I  |   | Check     |
| SUDMITTAL CHECKLIST.  | Name of contact person and their certification numbers, crossization, address, fay, phone                              |   |           |
| Course Submitter:   | Organization sponsoring or requesting the program (if any)   |   | ^         |
| Course Title:   | Name of course (related to content)  |   | X         |
| Purpose/Objective:  | Describe purpose and how course will improve competency of certification(s) listed                                     |   | X         |
| Contact Hours:  | Indicate instructional time and credit requested in hours (e.g.: 0.5 hr. 1 hr. 3.5 hrs)                                |   |           |
| Participants:   | Check off each certification for which credit is requested (for which course relates to certification)                 |   | Х         |
| Content of Program:   | Include collated agenda, time schedule, course outline; list specific sections of code, references, and topics covered |   | Х         |
| Course Materials:   | Collated workbooks, handout  | ts, hard copy or electronic versions of program is available  | Х         |
| Instructor(s) Info.:  | Resume of professional/educ  | ational qualifications & teaching/training experience/BBS certifications                                | Х         |
| Test Materials:   | · •  | Qizzes will be conducted inside the Zoom Webinar  | Х         |
| <b>Completed Application:</b>   |  |   | Х         |

NOTE: The Board does NOT grant retroactive approval for courses presented prior to approval date.

BBS 8102



#### MATTHEWS ELECTRICAL SERVICE.



## Grounding and Bonding Webinar Part II

78

Matthews Electrical Services *Ohio Training Agency #48714* Henry Matthews, PE, CPE, CESCP



# WELCOME!

- Goals
  - Promote learning
  - Make session engaging
    - Discussion
    - Videos
    - Case Studies
    - Polls
  - Make 4 hours as productive as possible!















## Keys to Understanding Grounding and Bonding

- Grounding and Bonding is one of the most confusing topics in the NEC
- Simplified by understanding:
  - Grounding
  - Bonding
  - Theory of current flow
  - Effective Ground Fault Current Path



# Why Do We Ground and Bond? Review

## Rule #1

- Electric current always wants to return to its **<u>source</u>** not ground
  - Exception: Lightning

## Rule #2

- Electric current will take <u>any</u> and <u>all</u> available paths to get back to its source
  - Includes:
    - Earth
    - Water
    - People
    - Metallic objects
    - Airs
    - Concrete
    - Wood
    - Pets
    - You get the picture...

## Rule #3

• Most of the current (returning back to its source) will take the path of least resistance (impedance)

## Goal #1

- **Bonding** creates an intentional low impedance (resistance) path for current to return to the source
- AKA: Low Impedance Effective Ground Fault Path

## Three Methods

- The Neutral (Grounding Conductor): Normal Current Return Path
- Equipment Grounding Conductor: <u>Intentional</u> Abnormal Current (Ground Fault) Return Path
- The Earth: <u>Unintentional</u> Current (Ground Fault) Path aka stray currents

## Why Do We Ground and Bond?

- Grounding
  - Divert lightning to ground
  - Establish voltage reference
  - Minimize elevated voltages
  - Stabilize voltages
  - Relax static charges
  - Noise reduction (electronics)



### • Bonding

- Equalize voltages (no current flow)
- Create equipotential plans
- Create effective ground fault path
- Prevent static electricity buildup
- Help minimize step and touch potential







- Both objects are at same voltage (equi-potential), but not necessarily 0 volts
- No current flow between bonded objects

#### GROUNDING















#### Things that are inherently grounded\*

- \*perform ground resistance tests to be certain
- Some codes require additional grounding

#### **BONDING AND GROUNDING**



## Types of Grounding

- System Grounding [250.4(A)(1)]
  - ...shall be connected to the earth in a manner that will limit the voltage imposed by lightning, line surges, or unintentional contact with higher-voltage lines and that will stabilize the voltage to earth during normal operation
- Electrical Equipment Grounding [250.4(A)(2)]
  - Normally non-current-carrying conductive materials enclosing electrical conductors or equipment, or forming part of such equipment, shall be connected to earth so as to limit the voltage to ground on these materials
  - Examples: conduit, electrical enclosures, electrical devices and fittings, equipment enclosures, transformer cases, motor cases etc.

## Bonding

- Bonding of electrical equipment [250.4(A)(3)]
  - Normally non-current carrying conductive materials enclosing electrical conductors or equipment, or forming part of such equipment, shall be connected together and to the electrical supply source in a manner that establishes an effective ground fault path.
- Bonding of Electrically Conductive Materials and Other Equipment [250.4(A)(4)]
  - Normally non-current-carrying electrically conductive materials that are likely to become energized shall be connected together and to the electrical supply source in a manner that establishes an effective ground-fault current path

# **Effective Ground-Fault Current Path!** [250.4(A)(5)]



# **Effective Ground-Fault Current Path!** [250.4(A)(5)]

- Electrical equipment and wiring and other electrically conductive material likely to become energized shall be installed in a manner that creates a low-impedance circuit facilitating the operation of the overcurrent device (circuit breaker, fuse e.g.) or ground detector for high-impedance grounded systems.
- It shall be capable of safely carrying the maximum ground fault current likely to be imposed on it from any point on the wiring system where a ground fault may occur to the electrical supply source.
- The earth shall not be considered as an effective ground fault current path.





Abnormal Return Path (fault return)

Normal Current Return Path (Neutral)

Abnormal Current (fault) Return Path (Equipment Grounding Conductor)

https://www.youtube.com/watch?v=BAcprdE\_YdQ

## Utility Service vs. Separately Derived System





The performance requirements of the fault-current paths for each system are provided in each part

## The Conductors of the Grounding System

- Main Bonding Jumper (MBJ)
- Grounded Conductor (neutral)
- Grounding Electrode Conductor (GEC)
- Supply Side Bonding Jumper (SSBJ)
- System Bonding Jumper (SBJ): for separately derived systems
- Equipment Grounding Conductor (EGC)
- Bonding Conductors (Jumpers)

## What is the Sphere of Influence?



https://www.youtube.com/watch?v=IqQStcKz-eY

#### **Functions of Grounding Electrode**





**IAEI 2014** 

Copyright ©

**Grounding Electrode** - A conducting object through which a direct connection to earth is established.

- 1. Connects the electrical system to earth
- 2. Connects electrical equipment to earth
- 3. Attempts to maintain equipment at the earth voltage potential

Little effect in clearing ground faults (not its function)

Grounding electrode conductor

Grounding electrode system

102



## Why Do We Put Ground Rods in Parallel?

#### **Resistor Combinations**

The combination rules for any number of <u>resistors</u> in series or parallel can be derived with the use of <u>Ohm's Law</u>, the <u>voltage law</u>, and the <u>current law</u>.





To lower resistance, add ground rods (electrodes) in parallel

## Ground Rods and Electrical Resistance

Example:



## Equipotential Bonding

- Also known as:
  - Chassis grounding, equipment grounding, instrumentation ground and safety ground
- Used for:
  - In-ground swimming pools, data-communication centers, electrical substations, dairy farms, anti-corrosion systems etc.
- Objective: To create a grounding plane that minimizes step and touch potential where regardless of where a person steps or what he/she touches, the voltage is the same. Shock mitigation.

## Equipotential Grounding Grid

- Primarily bare, solid #8 copper wire
- 1-ft grid, Must extend at least 3 ft past the water's edge
- All other objects within 5 ft of the pool shall have a grounding conductor bonded to the grid
- All metallic objects shall be bonded together, to the grid and to the concrete rebar
- Entire area where people are engaged in swimming or could be wet shall have all metallic objects bonded together regardless of distance.
- Recommended to extend equipotential grid to all concrete areas regardless of distance.




# Pool Equipment and Items Requiring Grounding

- Lighting assemblies, including in-water lighting
- The pool water itself! At least 9 in<sup>2</sup> must be in contact with conductive surface
- All electrical equipment within 5 ft horizontally of the pool
- Conductive equipment within 12' vertically of the pool including diving boards
- Motors, filters and other electrical recirculation equipment
- Metallic fittings
- Junction boxes, transformers, power supply enclosures
- GFCIs
- Panelboards
- Note: some low-voltage, <u>listed</u>, in-pool luminaires may not require a grounding conductor. VERIFY PROPER INSTALLATION WITH MANUFACTURER INSTRUCTIONS, THE AHJ AND THE NEC!

# Hot tubs, Hydromassage Tubs (680.40)

- Equipotential bonding isn't required if
  - The spa or hot tub is listed, labeled and identified as a self-contained spa or hot tub for aboveground use
  - The spa or hot tub isn't identified as suitable for indoor use
  - The spa or hot tub is located on or above grade
  - The top rim of the spa or hot tub is at least 28 in. above a perimeter surface located within 30 in. from the spa or hot tub.

# Grounding Between Multiple Buildings Fed from Single Building Panel



Metallic path can be conduit, water pipe, gas pipes, rebar in concrete, grounding conductor, communications wiring.

# Grounding Between Multiple Buildings Fed from Single Building Panel

- All buildings must have a grounding electrode installed, whether they are isolated or not.
- Exception: If the remote building has only one circuit breaker or fuse, then a grounding electrode is not required.
- However, an equipment grounding conductor run in conduit from the main panel is required
- A ground rod is still a good idea in this case

# Grounding Electrode Required

- For each building(s) or structure(s) served by one or more feeders or branch circuits, a grounding electrode system meeting the requirements of Part III of Article 250 must be used or installed
- The grounding electrode(s) must be connected in a manner specified in 250.32(B) or (C)
- Where no grounding electrode(s) are present from the construction of the building or structure, a grounding electrode system as specified in Part III of Article 250 (specifically 250.50) must be installed and used
- See 250.32(A)

# Grounding Electrode Requirements

- Grounding electrodes at additional buildings or structures must be bonded together to form a grounding electrode system
- Where no grounding electrodes are present at the building or structure, one or more of the grounding electrodes specified in 250.52(A)(4) through (A)(8) must be installed and used
- Rod, pipe, and plate electrodes to comply with 250.53(A)(1) through (A)(3)
- See 250.50

# Grounding Electrode Requirements (cont.)

250.32(A) Exception:

• A grounding electrode shall not be required where only a <u>single</u> <u>branch circuit</u>, including a multiwire branch circuit, supplies the building or structure and the branch circuit includes an equipment grounding conductor for grounding the normally non-current-carrying metal parts of equipment.



Grounding at separate building or structure using the required equipment grounding conductor [250.32(B)(1)]



Copyright © IAEI 2014



117

Grounding and bonding at separate building or structure using required equipment grounding conductor [250.32(B)(1)]





Grounding at separate building or structure using the grounded circuit conductor [250.32(B)(1) Exception No. 1]



Copyright © IAEI 2014



119

Grounding and bonding at separate building or structure using grounded circuit conductor [250.32(B)(1) Exception No. 1]



IAEI 2014

Disconnecting Means for Separate Building or Structure on the Same Premises

- Special rules have been provided for large capacity, multibuilding industrial installations under single management [see 250.32(D)]
- These occupancies have trained and qualified personnel and have established procedures for safe switching of electrical feeders or branch circuits
- As a result, the disconnecting means are permitted to be at other locations on the premises rather than at the building served as generally required by 225.32

# **Remote Disconnect Permitted**







#### Henry Peter Matthews, PE, CPE, CESCP, PVA

Home Address 1203 McKinley Place Fostoria, Ohio 44830 Email: hpmatthews@matthewselectrical.net Home Phone: 419-701-7707 Cell Phone: 419-575-3488

#### Work Address

Marathon Petroleum Company 539 South Main Street Findlay, Ohio 45840 Email: hpmatthews@marathonpetroleum.com Office phone: 419-421-3423 Cell phone: 419-957-2110

| Work Experience |   |                       |
|-----------------|---|-----------------------|
|                 | <ul> <li>Marathon Petroleum Company, LP; Findlay, Ohio</li> <li>Advanced Senior Engineer/Electrical Specialist</li> <li>Electrical Engineering Supervisor – Terminal Engineering</li> <li>Project Engineer – Major Projects</li> <li>Electrical Designer – Retail Division</li> </ul>                                 | June 2006 – Present   |
|                 | <ul> <li>Cooper Standard Automotive, Bowling Green, Ohio</li> <li>Plant Engineering Manager</li> <li>Plant Electrical Engineer</li> </ul>   | July 1993 – June 2006 |
|                 | <ul> <li>Toledo Engineering Company (consultant); Toledo, Ohio</li> <li>Electrical Drafter</li> </ul>   | June 1989 – July 1993 |
| Education       |   |                       |
|                 | <b>Bowling Green State University</b> ; Bowling Green, Ohio<br>Masters of Business Administration   | Aug 2003              |
|                 | Pennsylvania State University; University Park, PA<br>BS Electrical Engineering   | Dec 1989              |
|                 | <b>Solar Energy International</b> , Paonia, Colorado<br>Solar PV Training   | Sept 2021             |
|                 | <b>Owens Community College; Findlay, Ohio</b><br>Certificate: Introductory Welding  | April 2017            |
|                 | Penn Foster Career School<br>Certificate: Plumbing  | July 2010             |
|                 | Penn Foster Career School<br>Certificate: Electrician   | October 2004          |
| Certifications  | Professional Engineer (PE): OH, MI, IN, KY, IL, WI<br>Photovoltaic Associate (PVA) by NABCEP<br>Certified Electrical Safety Compliance Professional (CESCP), NFPA<br>Certified Plant Engineer (CPE): Association for Facility Engineers<br>Building Operator Certification (BOC): Northwest Energy Efficiency Council |                       |

| Licenses              | Ohio Electrical Contractor, Ohio Department of Commerce, License # 46972<br>Ohio Training Agency, Ohio Construction Industry Licensing Board, Agency #48714<br>Ohio Training Agency, Ohio Board of Building Standards   |  |
|-----------------------|---|--|
| Special Training      | <ul> <li>Solar Energy International (SEI), Paonia, Colorado</li> <li>Solar Electric and Design and Installation Course, April 2021, 60 hours</li> <li>PV Systems Fundamentals (Battery-Based), June 2021, 40 hours</li> <li>Advanced PV System Design and the NEC, June-July 2021, 60 hours</li> <li>Comparing Battery Technologies, July 2021, 10 hours</li> <li>Tools and Techniques for Operations and Maintenance of PV Systems, 9/21, 40 HR</li> </ul> |  |
| Affiliations          | Institute of Electrical and Electronics Engineers (IEEE) – Senior Member<br>International Association of Electrical Inspectors (IAEI)<br>NFPA Section Member for Architects, Engineers and Building Officials<br>Illumination Engineering Society of North America (IESNA)<br>API RP 545 former Co-Chair, American Petroleum Institute, Lightning Protection for<br>Above Ground Storage Tanks (2017- 2018)   |  |
| Business<br>Ownership | Matthews Electrical Services, Owner<br>Designer Cuts Hair Salon, LLC; Co-owner  |  |

#### Biography

Henry has worked in the electrical, power, electronics, instrumentation, controls and communication fields for over 30 years. He earned his Bachelor of Science degree in Electrical Engineering from Penn State University in 1989. Henry worked as a consultant for Toledo Engineering Company in Toledo, Ohio as a drafter and field technician.

In 1993 he started working for Cooper Standard Automotive Company in Bowling Green, Ohio in 1993 as a Plant Electrical Engineer. He was then promoted to Plant Engineering Manager in 2000. During this time, he earned his Professional Engineering License in Ohio.

In 2003, Henry earned his MBA at Bowling Green State University.

In 2006, Henry joined Marathon Petroleum Company in Findlay, Ohio. He then went on to obtain his Professional Engineers license in Electrical Engineering for Michigan, Indiana, Illinois, West Virginia, Kentucky, Minnesota and Wisconsin. During his tenure at Marathon, Henry has had several roles including Electrical Design Engineer, Project Engineer and Electrical Supervisor. He is currently an Advanced Senior Engineer where he writes electrical standards for the company and conducts a community of practice for all the company's electrical engineers and safety professionals. During his time at Cooper Standard Automotive and Marathon Petroleum, Henry developed a passion for teaching, learning and applying Electrical Construction Codes. At Cooper, he trained the entire non-electrical maintenance staff to perform basic electrical tasks.

At Marathon, Henry works with the Learning and Development Department to conduct multiple training sessions for new hires and seasoned engineers on various topics including Electrical Safety, Grounding and Bonding, Hazardous Area Location, Electrical Inspection, Motors, Lightning protection Static Electricity Mitigation, Reading and Understanding Electrical Diagrams, Programmable Logic Controllers and more.

Henry also works very closely with the Talent Acquisition Teams and visits numerous college campuses to deliver presentations on Engineering, Career Development, Networking and other topics.

Henry recently served as the Co-chair of the API Recommended Practice 545 Task Group for Lightning Mitigation for Above Ground Storage Tanks. In this role, he works with engineers, scientists and manufacturers from all over the world to evaluate the impacts of lightning and static electricity on metal above ground storage tanks.

His passion for teaching and Electrical Safety has motivated him to earn the Certified Electrical Safety Compliance Professional Certification (CESCP) from NFPA. He also regularly attends numerous electrical and safety conferences and training sessions conducted by NFPA, IEEE, API.

Previously, Henry was the President of the Fostoria, Ohio area Toastmasters team.

Henry is also a member of the International Association of Electrical Inspectors.

Henry also owns two small businesses:

**Matthews Electrical Services** - that performs mainly limited residential and small commercial electrical services and conducts training for licensed electricians in the state of Ohio.

Designer Cuts Hair Salon, LLC – Henry co-owns the beauty salon with his wife.

#### File Attachments for Item:

ER-3 Health Care Facilities, Fault Currents, Common Defects (IAEI) All certifications except IU and plumbing (6 hours) Staff Notes: ESIAC Recommendation:

Committee Recommendation:

| APPLI  | CATION<br>FOR  | <b>Board of Building Standards</b><br>6606 Tussing Road, P.O. Box 4009<br>Reynoldsburg, Ohio 43068-9009<br>(614) 644-2613 Fax: (614) 644-3147<br>dic.bbs@com.state.oh.us<br>www.com.state.oh.us/dic/dicbbs.htm |              |
|--|--|--|--------------|
| Continuir  | ng Education   | COURSE SUBMITTER:  |              |
| Course Approval  |  | Course Submitter: Lorenzo Adam   |              |
| Continuing education programs approved for<br>education credit by the Ohio Board of<br>Building Standards may be used for<br>compliance with certification requirements<br>related to code enforcement, plan review, and<br>inspection responsibilities. The credit is to be |  | Organization: Ohio Chapter IAEI  |              |
|  |  | Address: 27 Penbrooke Ct   |              |
|  |  | City: <u>Monroe</u> State: <u>Ohio</u> Zip: 45050  |              |
|  |  | F-Mail: ladam@masonoh.org  |              |
| used to renew the cert   | tifications issued by the  | Talasharan 512 220 9520 D  | —            |
| Ohio Board of Buildin  | ng Standards pursuant to   | relephone: 513-229-6520 Fax:   | —            |
| section 3781.10(E) OF  | ₹C.  | Course Sponsor: Ohio Chapter IAEI  |              |
| COURSE INFORMATION:  |  |  |              |
| Course Title: Health Care Facilities / Fault Currents / Common Defects   |  |  |              |
| New Cour   | rse Submittal: 🔲 Upo   | late Course: Prior Approval Number:  |              |
| Purpose and Objectiv   | ve: To provide atter   | ndees with an overview and explanation of the subjects presented   |              |
| and to provide   | a level of uniformity amo  | ng inspectors, contractors, professional designers and jurisdictions   |              |
|  |  |  | _            |
|  | Inst   | ructors: Various IAEI members  | _            |
|  |  |  | _            |
| Number of Instruction  | nal Contact Hours that can   | be obtained upon completion: 6 hours   | _            |
| If Multi-Session, Num  | ber of Instructional Conta   | ct Hours Per Session:  |              |
| Program Applicable f   | or the Following Particing   |  |              |
|  |  |  | <u> </u>     |
| Building Official  | Master Plans Examiner  | Building Inspector Fire Protection Inspector Mechanical Inspector  |              |
|  | Building Plans Exam.   | Plumbing Inspector   |              |
|  | Plumbing Plans Exam.   | Non-Res IU Inspector   |              |
|  | Electrical Plans Exam.   |  |              |
|  | Mechanical Plans Exam.   |  |              |
|  | Fire Protect. Plans Exam.  |  |              |
| Res Building Official  | Res Plans Examiner   | Res Building Inspector 🔽 Res Mechanical Inspector 🔽 Res IU Inspector   |              |
| Electrical Safety Inspector  | rs 🖌   |  |              |
| Location of ESI Course:  | Fairfield, Ohio  | Date(s) of ESI Course(s): Febraury 5, 2022   | -            |
| SUBMITTAL CHECKLIST:   | Make Sure all of the Following I   | nformation is <b>Submitted</b> :   | heck:<br>Off |
| Course Submitter:  | Name of contact person and t   | heir certification numbers, organization, address, fax, phone  |              |
|  | Organization sponsoring or re-   | equesting the program (if any)   |              |
| Course Title:  | Name of course (related to co  | ontent)  |              |
| Purpose/Objective:   | Describe purpose and how co  | surse will improve competency of certification(s) listed   |              |
| <b>Contact Hours:</b>  | Indicate instructional time an   | d credit requested in hours (e.g.: 0.5 hr, 1 hr, 3.5 hrs)  |              |
| Participants:  | Check off each certification for which credit is requested (for which course relates to certification)                 |  |              |
| <b>Content of Program:</b>   | Include collated agenda, time schedule, course outline; list specific sections of code, references, and topics covered |  |              |
| <b>Course Materials:</b>   | Collated workbooks, handouts, hard copy or electronic versions of program is available                                 |  |              |
| Instructor(s) Info.:   | Resume of professional/educ  | ational qualifications & teaching/training experience/BBS certifications   |              |
| Test Materials:  |  |  |              |
| <b>Completed Application:</b>  |  |  |              |

NOTE: The Board does NOT grant retroactive approval for courses presented prior to approval date.

BBS 81

#### <u>Agenda</u>

#### NEC Analysis of Changes February 5<sup>th</sup> 2022

**Topic:** See outlines for more details on these topics.

Instructors: Dewayne Jenkins, Pete Baldauf, Caty Robinson, Lorenzo Adam, Gaylord Poe, Rick Lecher

| 7:30 am to 8:00 am   | Registration              |        |
|----------------------|---------------------------|--------|
| 8:00 am to 9:00 am   | Non- Hospital Health Care | 1.00 h |
| 9:00 am to 9:30 am   | Break                     |        |
| 9:30 am to 10:30 am  | Non-Hospital Health Care  | 1.00 h |
| 10:30 am to 10:45 am | Break                     |        |
| 10:45 am to 12:00 m  | Fault Current             | 1.25 h |
| 12:00 pm to 1:00 pm  | Break for lunch           |        |
| 1:00 pm to 1:45 pm   | Fault Current             | 0.75 h |
| 1:45 pm to 2:30 pm   | Common Electrical Defects | 0.75 h |
| 2:30 pm to 2:45 pm   | Break                     |        |
| 2:45 pm to 4:00 pm   | Common Electrical Defects | 1.25 h |
| 4:00 pm              | Certificates Distributed  |        |
|                      |                           |        |

| Total | 6.00 h |
|-------|--------|
| IUIUI | 0.001  |

#### Course Outline for Jointly Sponsored Seminar Series February 5, 2022

#### Non-Hospital Health Care Facilities

All health care facilities addressed by the code are routed towards hospitals, but the misunderstanding comes when it is not a hospital. Ambulatory services, outpatient services, medical offices, dental offices and the likes, nursing homes and assisted living facilities.

The code requirements for these facilities differ from those for hospitals. We will be discussing wiring methods and how it affects which facility you are operating under.

- Definitions Art. 100
- Requirements:
  - o Art. 517
    - General Part I
    - Wiring and Protection Part II

#### Fault Current Calculations and Misunderstanding Practices

Shor circuit current rating is a requirement in all services. It states that no electrical service shall be rated less than what is capable of withstanding when it comes to fault. The importance of this subject is crucial to understanding the seriousness of a fault, not only it could affect the health of the personnel but also the loss of the infrastructure, including production time loss and lack of readily available materials.

- Definitions Art. 100
- Requirements:
  - o Art 110.9 / Interrupting Rating
  - o Art. 110.10 / Circuit Impedance, Short Circuit Current Rating
  - o Art. 110.24 / Available Fault Current
  - o Art. 230 / Services
  - o Art. 240.86 / Series Rating

#### **Common Electrical Defects**

Common electrical defects and violations are commonly found in the field. Common violations is where the consistency among inspectors and compliance among contractors would have an impact in all jurisdictions, the myth where one jurisdiction requires something while another requires exactly the opposite would tend to disappear, thus bringing the level of consistency of the NEC to uniformity. Common defects will help Inspectors, Building Officials and Contractors understand the violations that will occur during the inspection process and how to relate such violation to the respective Building Officials, according to Section 113 in 2017 Ohio Building Code and Section 109 in 2019 RCO.

- Various articles will be discussed throughout this topic as violations and defects changes from project to project.
- The presentation will focus on:
  - o Plan Review Deficiencies
  - o Field Deficiencies

These presentations will be in Power Point format and each participant will be encouraged to discuss and to participate on the subjects presented. Contractors and ESIs will benefit as well as Plans Examiners and Professional Designers by getting firsthand information on these subjects. Both, the Ohio Building Code and the Residential Code of Ohio, in chapters 27 and 33 respectively refers to NFPA 70 as the standard to comply with electrical installations

#### **INSTRUCTOR QUALIFICATIONS**

#### Lorenzo M. Adam

Lorenzo started his electrical training in 1983. In 1988, he started his own electrical company. In 1996, he obtained the State Electrical Inspector certification. In 1997, he joined the City of Troy as a Building/Electrical Inspector. Currently, he works for the City of Mason. Lorenzo has an Electrical Plans Examiner, Residential Building Official, Building Inspector, Building Official interim certification from the State of Ohio. Lorenzo is currently the secretary/treasurer for the SW Division of IAEI, Ohio Chapter, secretary/treasurer for the Ohio Chapter IAEI and Treasurer and Past President of the Southwestern Ohio Building Officials Association (SWOBOA).

Address: 27 Penbrooke Ct., Monroe, Ohio 45050

#### Gaylord K. Poe

Gaylord Poe started his longstanding career in the electrical industry in 1969. He earned his Electrical Safety Inspector Certificate (#592) in 1978. He continued to work as an electrician until 1983 when he joined the IBI team as a commercial/industrial field inspector. He was promoted to Commercial Coordinator in 1986, to Assistant Chief Electrical Inspector in 1994, and to Chief Electrical Inspector and President in 2000. He earned his Ohio Electrical Plan Examiner and IAEI Electrical Inspector-Plan Review certificates in 2005. He is the only Ohio ESI certified by the IAEI as a Master Electrical Inspector (2009).

Gaylord is a member of the UL Electrical Council, the NFPA, the Cincinnati Business Development and Permit Center Advisory Committee, the Board of Trustees for the GCEA, the Electrical Trades Advisory Committee for Scarlet Oaks JVS, and is actively involved in course development and training classes for the continuing education programs of the IAEI, IEC, GCEA, and NECA. Gaylord has been involved with the IAEI since the early 1980's. He currently has become the Past-President of the IAEI SW Division, in which he served for 17 years combine.

Address: Suite 125-W, 250 West Court Street, Cincinnati, OH 45202

#### Caty Robinson

Caty Robinson began her electrical career working as an apprentice in the Dayton, Ohio area. As a member of IBEW Local 82 Caty served a full apprenticeship and worked in the field as a journeyman wireman for Kastle Electric. Caty's Ohio certification #2647 is for ESI (2004) and EPE (2013). Caty joined Inspection Bureau, Inc. (IBI) in 2008 as a commercial Electrical Safety Inspector. Caty currently serves as IBI's Commercial Coordinator and inspects in IBI's commercial territories and Kentucky. Caty is also a member of the IAEI Ohio Chapter SW Division

Address: Suite 125-W, 250 West Court Street, Cincinnati, OH 45202

#### Peter M. Baldauf

Peter has been in the electrical industry for over 15 years. He began his electrical career working through a trade school in Dayton, Ohio. After araduation, he enrolled in the Associated Builders and Contractors State certified electrical apprenticeship program. Peter attended the program for the full four years and upon completion of the program, he relocated to Tacoma. Washington. In Tacoma, he sat for a State administered test and received State of Washington certification as a journeyman electrician, which is required by the Division of Labor and Industry in that State to perform work as an electrician. Upon his return to the State of Ohio, Peter sat for and was issued a license by the State of Ohio to perform duties associated with the installation and servicing of fire alarm systems. He also applied and sat for the test to become a State Certified Electrical Safety Inspector. He was awarded this Certification in September of 1998. Peter began his career in public service with Montgomery County Building Regulations as an Electrical Inspector in August of 1999. He is currently employed with the City of Vandalia as an Electrical Inspector. Peter also instructs classes for the Master Electrical Contractors Association, Adequate Wiring Committee, and International Association of Electrical Inspectors. He also has certification through the City of Dayton Board of Education as an Adult Education Instructor.

Address: 3600 Shroyer Road, Kettering, OH 45429

#### **Daniel Dewayne Jenkins**

Dewayne started his career in the electrical field in 1982 in Dayton, Ohio and several years of experience in the electrical industry both as a contractor and inspector. He served 4 years in an electrical apprenticeship program and has over 8 years in the field as a journeyman electrician and he has 4 years, to his credit, as an electrical estimator and project manager.

Dewayne has been a licensed electrical contractor and a certified electrical safety inspector since 1996. He also holds Ohio certifications as building inspector (1998), electrical plans examiner (2006) and residential building official (2007) and chief building official (2008). He is currently employed by the City of Kettering in the position as an electrical plans examiner, electrical safety inspector and building inspector.

Dewayne is an adjunct lecturer II for Sinclair Community College in the electrical trades for several years. A technical presenter for the Ohio Board of Building Standards (OBBS), International Association of Electrical Inspectors (IAEI), Master Electrical Contractors Association (MECA), Adequate Wiring Committee (AWC) & Greater Cincinnati Electrical Association (GCEA). He has served as President for the Ohio Chapter IAEI (2010). Dewayne has also served as President of the Miami Valley Building Officials Council (2002 & 2003). He currently is the President of the Southwest Division, IAEI and serves on the Electrical Safety Inspector Advisory Committee for the Ohio Board of Building Standards.

Address: 3600 Shroyer Road, Kettering, OH 45429

#### **Rick Lecher**

Rick has been in the electrical industry for 31 years. He received his Certification # 1671 from the State of Ohio in 1998.Rick has been employed by Inspection Bureau, Inc. (IBI) for 5 years as an Electrical Safety Inspector. Rick is currently inspecting in IBI's C-2 and R-1 territories. Rick is also an Electrical Plan Examiner for IBI.

Address: Suite 125-W, 250 West Court Street, Cincinnati, OH 45202

#### Jointly Sponsored Seminar Series 2022 Presented by GCEA and Southwest Division IAEI

#### Facility

The facility is conveniently located in Fairfield, about 1 mile west from 1-75 off Route 4. Classes are held at the **Receptions 5975 Boymel Drive**, **Fairfiled**, **Ohio**. The room occupancy is good for 300 students comfortably with tables and chairs. There are provisions for audio-visual equipment (screen, microphone and speakers). Restrooms are located nearby the room for females and males. Refreshments are served during the class; attendees have access to vending machines as well as water. Duration of the instruction is 6.00 hours. 8:00am – 4:00pm. on February 5<sup>th</sup> 2022.

#### **Course Materials**

Every attendee is responsible for bringing an edition of the NEC. We will use the NEC 2017. The instructors will also have on hand the necessary references to answer questions about other codes or standards. Most of the presentations are on a slide-format (Power Point).



#### • Circuit Breaker.

 A device designed to open and close a circuit by nonautomatic means and to open the circuit automatically on a predetermined overcurrent without damage to itself when properly applied within its rating.

- Fuse.
- An overcurrent protective device with a circuit-opening fusible part that is heated and severed by the passage of overcurrent through it.

## **Definitions**

- Interrupting Rating.
- The highest current at rated voltage that a device is intended to interrupt under standard test conditions.

- Overcurrent.
- Any current in excess of the rated current of equipment or the ampacity of a conductor. It may result from overload, short circuit, or ground fault.
- FPN: A current in excess of rating may be accommodated by certain equipment and conductors for a given set of conditions. Therefore, the rules for overcurrent protection are specific for particular situations.

## Definitions

 Overload. Operation of equipment in excess of normal, full-load rating, or of a conductor in excess of rated ampacity that, when it persists for a sufficient length of time, would cause damage or dangerous overheating. A fault, such as a short circuit or ground fault, is not an overload.

- Qualified Person. One who has skills and knowledge related to the construction and operation of the electrical equipment and installations and has received safety training on the hazards involved.
- FPN: Refer to NFPA 70E, Standard for Electrical Safety in the Workplace, for electrical safety training requirements.











## **110.9 – Interrupting Rating**



 Equipment intended to interrupt current at fault levels shall have an interrupting rating sufficient for the nominal circuit voltage and the current that is available at the line terminals of the equipment.
 Equipment intended to interrupt current at other than fault levels shall have an interrupting rating at nominal circuit voltage sufficient for the current that must be interrupted.

#### 110.10 Circuit Impedance and Other Characteristics.

- 110.10 Circuit Impedance and Other Characteristics
- The overcurrent protective devices, the total impedance, the component short-circuit current ratings, and other characteristics of the circuit to be protected shall be selected and coordinated to permit the circuit-protective devices used to clear a fault to do so without extensive damage to the electrical components of the circuit. This fault shall be assumed to be either between two or more of the circuit conductors or between any circuit conductor and the grounding conductor or enclosing metal raceway. Listed products applied in accordance with their listing shall be considered to meet the requirements of this section.
- Evidence of Extensive Damage is determined under test conditions. Equipment applied in a circuit within the ratings of the equipment should not sustain extensive damage under fault conditions


## **110.16 Flash Protection**

#### • 110.16 Flash Protection

 Electrical equipment, such as switchboards, panelboards, industrial control panels, meter socket enclosures, and motor control centers, that are in other than dwelling occupancies, and are likely to require examination, adjustment, servicing, or maintenance while energized shall be field marked to warn qualified persons of potential electric arc flash hazards. The marking shall be located so as to be clearly visible to qualified persons before examination, adjustment, servicing, or maintenance of the equipment.





#### 110.22

- 110.22 Identification of Disconnecting Means
- Each disconnecting means shall be legibly marked to indicate its purpose unless located and arranged so the purpose is evident. The marking shall be of sufficient durability to withstand the environment involved.
- Where circuit breakers or fuses are applied in compliance with the series combination ratings marked on the equipment by the manufacturer, the equipment enclosure(s) shall be legibly marked in the field to indicate the equipment has been applied with a series combination rating. The marking shall be readily visible and state the following:
- CAUTION SERIES COMBINATION SYSTEM RATED \_\_\_\_\_ AMPERES. IDENTIFIED REPLACEMENT COMPONENTS REQUIRED.

# 408.4 Circuit Directory or Circuit Identification.



 Every circuit and circuit modification shall be legibly identified as to its clear, evident, and specific purpose or use. The identification shall include sufficient detail to allow each circuit to be distinguished from all others.
Spare positions that contain unused overcurrent devices or switches shall be described accordingly. The identification shall be included in a circuit directory that is located on the face or inside of the panel door in the case of a panelboard, and located at each switch on a switchboard. No circuit shall be described in a manner that depends on transient conditions of occupancy.

## 240.60 (C)

#### • (C) Marking:

- Fuses shall be plainly marked, either by printing on the fuse barrel or by a label attached to the barrel showing the following:
  - (1) Ampere rating
- (2) Voltage rating
- (3) Interrupting rating where other than 10,000 amperes
- (4) Current limiting where applicable
- (5) The name or trademark of the manufacturer
- The interrupting rating shall not be required to be marked on fuses used for supplementary protection.



## 240.83 Marking

- (C) Interrupting Rating
- Every circuit breaker having an interrupting rating other than 5000 amperes shall have its interrupting rating shown on the circuit breaker. The interrupting rating shall not be required to be marked on circuit breakers used for supplementary protection.

#### 240.83 Marking

- (E) Voltage Marking
- Circuit breakers shall be marked with a voltage rating not less than the nominal system voltage that is indicative of their capability to interrupt fault currents between phases or phase to ground.

#### 240.85 Applications



 A circuit breaker with a straight voltage rating, such as 240V or 480V, shall be permitted to be applied in a circuit in which the nominal voltage between any two conductors does not exceed the circuit breaker's voltage rating. A twopole circuit breaker shall not be used for protecting a 3-phase, corner-grounded delta circuit unless the circuit breaker is marked 1–3 to indicate such suitability.



## 240.85 Applications

















#### 240.86 Series Ratings



A series rated system is a combination of circuit breakers or a combination of fuses and circuit breakers that can be applied at available short-circuit levels above the interrupting rating of the load-side circuit breakers but not above that of the main or line-side device. Series rated systems can consist of fuses that protect circuit breakers or of circuit breakers that protect circuit breakers. The arrangement of protective components in a series rated system can be as specified in 240.86(A) for engineered systems applied to existing installations or in 240.86(B) for tested combinations that can be applied in any new or existing installation.

#### 240.86 Series Ratings



#### 240.86 Series Ratings



Compatibility with series rated systems will in all likelihood be limited to circuit breakers that (1) remain closed during the first 1/2 cycle of a fault and (2) have an interrupting rating that is not less than the let-through current of an upstream protective device (such as a current-limiting fuse). In those cases where the opening of a circuit breaker, under any level of fault current, begins in less than 1/2 cycle, the use of a field engineered series rated system will in all likelihood be contrary to acceptable application practices specified by the circuit breaker manufacturer. Where there is any doubt over the proper application of existing downstream circuit breakers with new upstream overcurrent protective devices, the manufacturers of the existing circuit breakers and the new upstream overcurrent protective devices must be consulted.

#### <u>Component Protection</u> <u>Utilizing Fuses</u>



 The two parameters IRMS and IP must be compared to the equipment's withstand rating. The rule is simple: if the RMS and peak letthrough value of the fuses are less than the equipment withstand rating, the equipment will be protected. This philosophy holds true for various static components, such as wire and cable, busway, and motor starters. This basic protection requirement is mandated by NEC section 110.10. It will also be true for noncurrent limiting circuit breakers when their opening time is greater than one-half cycle.



#### <u>Component Protection</u> <u>Utilizing Fuses</u>

In the past, as long as the fuse let-through values were less than the breakers interrupting rating, the system was considered sound. THIS METHOD HAS A SOLID HISTORY OF SUCCESSFUL APPLICATIONS. However, due to changes in circuit breaker design, the method may not always work with circuit breakers. Selecting today's а protect current-limiting fuse to а downstream molded case circuit breaker has now become an increasingly more complex problem (emphasis added).

# <u>Component Protection</u> <u>Utilizing Fuses</u>

- Simply put, if the total clearing energy of a quicker acting molded case circuit breaker (a breaker that exhibits dynamic impedance) is less than the melting energy of a larger upstream fuse, the molded case circuit breaker will interrupt the full value of the system fault without the benefit of the fuse's current-limiting effect. This situation can have CATASTROPHIC effects on the circuit breaker as it tries to interrupt faults beyond its interrupting capacity. Currently, there is no available engineering method to predict protection of these faster breakers (emphasis added).
- (Source: Cooper / Bussmann "SPD electrical protection handbook". Copyright 1999 by Cooper Bussmann)

## AIC Rating of equipment



• In general, protective devices are required to have an interrupting rating equal to the available fault current (NEC 110.9). However. under most circumstances, the use of current limiting fuses to protect devices with inadequate interrupting ratings meets this requirement. This eliminates the need to install more expensive fully rated devices. The most common use is protecting molded case circuit breakers (MCB's).

#### **AIC Rating of equipment**

- There are three ways of selecting current-limiting fuses for this purpose:
- 1. Using circuit breaker manufacturer's UL (or other NRTL) listed series ratings for their panelboard with fuses.

#### AIC Rating of equipment



2. Reference to Underwriters Laboratories, Inc. (UL) Recognized Component Directory (the "Yellow Book"), including any supplements. The Recognized Component Directory lists manufacturers that have obtained a UL listing of their circuit breakers when tested in series with current-limiting fuses. Unless the complete equipment assembly has obtained a UL listing and is labeled for series rating with a stated maximum available fault current, the component series ratings do not qualify such equipment for use on an available fault current higher than the interrupting rating of the lowest rated breaker.

#### **AIC Rating of equipment**

3. The "Engineered" method using peak letthrough charts or software. For many years, an "engineered" method (known as the upover-and-down method) of using currentlimiting fuses has been used to successfully protect breakers with inadequate interrupting ratings. However, circa 1975, new designs of fast acting breakers began to appear. These breakers employ a "blow-apart" contact design that actually uses the repulsion energy of the fault current. The result was that current limiting fuses were not always able to protect these breakers from damage.



#### **Selective Coordination**

- Definition:
- Coordination(Selective).

Localization of an overcurrent condition to restrict outages to the circuit or equipment affected, accomplished by the choice of overcurrent protective devices and their ratings or settings.









## Trouble

 The following pictures are examples of serious problems arising from poor planning and/or design

















#### 11/17/2021





## 517.1 Scope

- The provisions of this article shall apply to electrical construction and installation criteria in health care facilities that provide services to human beings.
- The requirements in Parts II and III not only apply to single-function buildings but are also intended to be individually applied to their respective forms of occupancy within a multifunction building (e.g., a doctor's examining room located within a limited care facility would be required to meet the provisions of 517.10).

## 517.1 Scope

The requirements of Article 517 are intended to apply to all types of health care facilities. The requirements for each type of health care facility are nevertheless intended to be applied in a very specific manner. Application example: In a suite of doctors' offices within an office building, a doctor's business office would be treated as an ordinary occupancy and would be required to meet only the applicable portions of other parts of this Code. However, the examining rooms attached to the doctor's business office would be required to meet the provisions of Part II and 517.45 in Article 517.











- Definition of "Health Care Facility" was revised to include "mobile enclosures"
- Revised definition is extracted material from NFPA 99 (Healthcare Facilities Code)
- Health care facility is not limited to a traditional "brick and mortar" permanently constructed building
- Health care facility can include a mobile or portable facility such as a mobile blood bank or mobile facilities as seen at sporting events























#### 11/17/2021









#### Purpose

- 517.11 General Installation Construction Criteria.
- The purpose of this article is to specify the installation criteria and wiring methods that minimize electrical hazards by the maintenance of adequately low potential differences only between exposed conductive surfaces that are likely to become energized and could become in contact by a patient.



- 517.13(A) Wiring Methods: All branch circuits serving patient care spaces shall be provided with an effective ground-fault path.
- This is accomplished by the installation of a metal raceway system or a cable having a metallic armor or sheath assembly.
- The metal raceway or metallic cable armor or sheath assembly itself qualify as an equipment grounding conductor in accordance with 250.118




























#### 11/17/2021



#### 517.19(B) Patient Bed Location **Receptacles (Critical Care Areas)** The minimum number of receptacles required for critical care area patient bed locations of health care facilities was increased from six to fourteen receptacles. The systems required to supply at least one of these receptacles was changed from the emergency system to the critical branch as the term "emergency system" has been removed for Article 517. NFPA 99 Section 6.3.2.2.6.2 requires each patient bed location in critical care areas, where considered a Category 1 application, to be provided with a minimum of fourteen opyright © IAEI 2014 receptacles. • Category 1 covers facility systems in which failure of such equipment or system is likely to cause major injury or death of patients or caregivers.

188









#### 11/17/2021









#### 11/17/2021









Do I have to install "health care type MC/AC Cable" when I'm wiring exam rooms in a doctor's office?

- NO necessarily, complete metal raceway systems such as EMT conduit & wire is the preferred method. Listed metallic cable assemblies & fittings are permitted methods.
- Listed MC or AC Type that qualify with 250.118
- Remember the exceptions 517.13(B)

Is it necessary for all receptacles in a health care facility to have "redundant grounding" required by 517.13?

- 517.13 not only requires patient care space receptacles to be redundantly grounded, but all branch circuits serving patient care spaces.
- Note: exceptions 517.13 (B) 1 & 2
- The focus is patient care spaces and not other areas such as offices & corridors.

Where can I find the definition of redundant grounding in the NEC?

- You are not going to find the definition of redundant grounding in the NEC.
- This is a two part safe wiring scheme to minimize electrical hazards for patients who receive care in these facility spaces.

Do switches for general lighting need to have "redundant grounding" if they are in a patient care space?

- Yes, refer to 517.13(A) & (B) All branch circuits serving patient care spaces, including quitebac page including to the second service of the second se
- including switches require redundant grounding. Terms are key here!
- See 517.13(B) exception No. 3 May apply here.
- Switches located outside the patient vicinity (six feet) may choose 517.13 (A) or (B) as a compliant option.

Would lighting fixtures (luminaries) in a patient care area require "redundant grounding"?

- Yes, again refer to 517.13(A), All branch circuits serving patient care spaces.
- Again, terms are key here.
- See 517.13(B) exception No. 3 May apply here.
- Luminaires located outside the patient vicinity (7'6" above the floor ) may choose 517.13 (A) or (B) as a compliant option.

Would the NEC permit <sup>1</sup>/<sub>2</sub>" flex to be ran between device boxes for receptacles in a patient care area?

- Yes, refer to 250.118 Normally general care spaces
- Maximum length is 6 feet in the same ground fault current path.
- Does not exceed 1-1/4" in trade size
- Must have fittings listed for grounding
- For circuits 20 amps or less
- Not installed for flexibility

Would it be permitted to run PVC in a slab to feed receptacles in a patient care space?

- Absolutely Not, again see 517.13(A) Metal Raceways!
- Code change in 2005 allowed the use of PVC conduit in the slab for panel feeders and branch circuits not serving the patient care spaces. See 517.30(C)(3)(2)
- Definitely not branch circuits serving patient care spaces.

Are the requirements of Article 517 applicable to Veterinarian clinics?

## Answer #8

No, 517 does not apply to Vet clinics, only facilities for human beings.

See 517.1 Scope

Who is responsible for the determination of the level of proposed patient care spaces within a facility?

## Answer #9

See definitions. 517.2 – Governing Body

The person or persons who have the overall legal responsibility for the operation of a health care facility.

Do the quantity requirements for receptacles at patient bed locations (517.18 & 517.19) apply at general care space exam rooms?

- No, See 517.18(A) Exception No. 2
- Does not apply to patient bed locations in clinics, medical & dental offices and outpatient facilities meeting the requirements 517.10(B)(2).
- 517.19 applies to critical care areas

Do the requirements for receptacles at patient bed locations (517.19) apply to procedure rooms?

- Maybe, it would ultimately depend on the type of procedure being completed and whether or not the failure of the equipment or a system is likely to cause major injury or death of patients, staff, or visitors.
- Simple procedure rooms fall under the definition of general care spaces in definitions and would potentially only cause minor injury.

Are receptacles located in an exam room of a patient care space required to be of the "hospital grade" type?

# Hospital Grade Receptacles?



No, again see 517.18(A) exception No. 2
Does not apply to clinic, medical & dental offices and outpatient facilities.

## Question #13

How do I comply with the redundant grounding requirements when I'm installing isolated ground receptacles in a patient care areas?

- They can only be installed "outside the patient vicinity". Not permitted otherwise.
- They must meet all requirements 517.13 (A) & (B) when installed in patient care spaces and provide an insulated equipment grounding conductor with green insulation with one or more yellow stripes for the entire length per 517.16

## Question #14

Do all receptacles located in pediatric exam rooms have be tamper proof?
What about other areas within the facility?

- Yes, but not tamper proof type. Tamper resistant receptacles or tamper resistant covers shall be provided for in patient care areas.
- It not only applies to exam rooms, but rooms, bathrooms, playrooms and activity rooms. See 517.18(C)
- Other areas within clinics, medical and dental offices and outpatient facilities have to meet the requirements of 406.12



- Yes, first refer to 517.12 which allows the wiring methods in chapter 3.
- Caution should be taken when choosing the NM Cable method (romex).
- Refer to 334.10(3) Must be "concealed" within a 15-minute thermal barrier.
- 334.12 (2) is not permitted above dropped ceilings.





#### SECTION 104 OBC 2017

**104.2.1.3 Inspections.** If the plans for the erection, construction, repair, alteration, relocating, or equipment of a building are subject to inspection by the building official, under section 108, the building official shall cause to be made such inspections, investigations, and determinations as are necessary to determine whether or not the work which has been performed and the installations which have been made are in conformity with the approved construction documents.



3

#### SECTION 104 OBC 2017

**104.2.3.3 Electrical safety inspector.** An electrical safety inspector is responsible to determine electrical systems compliance with approved construction documents in accordance with section 108.



5

#### SECTION 108 OBC 2017

108.6.1 Communication process for work contrary to approved construction documents.

1. Communicate the nature of the differences to the owner or the owner's on-site representative and offer the following options:

1.1 The owner will bring the item of noncompliance into compliance,

1.2 The owner will revise the drawings and resubmit to the department,

**1.3** The items of noncompliance will not be brought into compliance and will be referred to the building official as indicated in item 4 below.

3

#### SECTIO 108 OBC 2017

**2.** The owner or the owner's on-site representative shall indicate which option (item 1 above) will be exercised

**3.** Notations on the on-site inspection record and in the inspector's log shall be made. The notations shall include the inspector's name, the date of the inspection, the type of inspection, the observed items of noncompliance, the option chosen by the owner or the owner's on-site representative, the name of the person communicated with, and the

estimated dates of compliance and follow-up inspections, if applicable.

7

#### SECTION 108 OBC 2017

**4.** If the owner or the owner's on-site representative indicates that the work will not be brought into compliance with the approved construction documents, the inspector shall submit a report to the building official for the final determination of noncompliance in accordance with section 108.7.



**108.6.2** Observation of violations not shown on plans. If an inspector, in the course of performing the assigned or requested inspections, observes a code violation that was either shown incorrectly or not adequately addressed or detailed in the approved construction documents, the inspector shall communicate the finding to the building official so that the building official can make a determination of whether the code violation is of such significance to warrant communicating the finding to the owner or the owner's representative as a recommended change.

| APPROVED<br>MASOR BUILDING DEPARTMENT<br>229-8520 | APPROVED<br>THE CIP OF MASON BLDG. DEPT.<br>513.229.8520<br>ADDRESS<br>DATEINSPECTOR<br>FOOTING SLAB<br>FRAMING ELECTRIC<br>INSULATION DRIVE APPROACH<br>SIDEWALK MASONRY<br>FIRE PROTECTION FINAL | NOT APPROVED<br>MASON BUILDING DEPARTMENT<br>229-8520<br>THE FOLLOWING ITEMS DO<br>NOT MEET THE BUILDING CODE |  |
|---|--|---|--|
|   |  | DO NOT REMOVE THIS NOTICE<br>FROM THE JOB SITE  |  |










